


## 7 Series 700R11

Indoor Split Geothermal Heat Pump 033, 042, 050 Variable Speed




Submittal Data English Language/IP Units SD2703SN 08/20

Contractor:	P.O.:	
Engineer:		
Project Name:	Unit Tag:	






### **Unit Nomenclature (Compressor Section)**



### **Unit Nomenclature (Air Handler)**



 $^{1}$ - Air flow on the 050 unit in the horizontal configurations should be limited to 1900 cfm in cooling mode, or condensate blow off may occur.

 $^{2}$  - Compressor section must be matched with identical model SVH air handler section. See Compatibility Table

 $^{3}$ - To field convert the SVH to bottomflow air discharge. The SAHBCK kit must be ordered separately.

<sup>4</sup>- UPC is not compatible with Symphony or IntelliZone2.

Rev.: 4/2/20

Contractor:	P.O.:	
Engineer:		
Project Name:	Unit Tag	



### **AHRI/ISO 13256-1 Performance Ratings**

#### 7 Series Indoor Split Residential Series AHRI Data

**ECM Motor** 

AHRI/ASHRAE/ISO 13256-1

			Wat	er Loop H	leat Pump		Groun	d Water	Heat Pump	,	Grou	nd Loop	Heat Pum	р
Model	Capacity Modulation	y Cig/Htg FWT 86°F FWT				Heating EWT 68°F		Cooling EWT 59°F		g )°F	Cool Full Loa Part Loa	nd 77°F nd 68°F	Heating Full Load 32°I Part Load 41°I	
		cfm	Capacity Btuh	EER Btuh/W	Capacity Btuh	СОР	Capacity Btuh	EER Btuh/W	Capacity Btuh	СОР	Capacity Btuh	EER Btuh/W	Capacity Btuh	СОР
033	Full	1200/1500	31,600	16.8	49,800	5.2	37,000	29.2	40,700	4.5	33,300	20.3	31,700	3.4
033	Part	650/800	10,900	20.9	16,800	7.3	12,900	46.0	13,900	5.7	13,700	36.0	12,000	5.2
042	Full	1500/1800	39,500	16.4	66,100	4.9	46,200	28.2	54,100	4.2	41,600	19.7	42,700	3.5
042	Part	900/1100	15,600	22.4	23,800	7.5	17,300	52.0	18,800	5.8	17,500	40.8	15,800	5.1
050	Full	1800/2200	46,700	14.4	77,800	4.3	55,200	24.3	64,900	3.8	49,800	17.1	50,800	3.2
050	Part	950/1200	19,400	20.9	28,900	7.4	21,200	45.6	22,800	5.8	22,000	35.5	19,800	5.0

Cooling capacities based upon 80.6°F DB, 66.2°F WB entering air temperature Heating capacities based upon 68°F DB, 59°F WB entering air temperature All ratings based upon 208V operation

3/20/20

#### **Energy Star Compliance Table**

	Tier 3										
Model	Ground Water	Ground Loop									
033	Yes	Yes									
042	Yes	Yes									
050	Yes	Yes									

10/31/19

#### **Energy Star Rating Criteria**

In order for water-source heat pumps to be Energy Star rated they must meet or exceed the minimum efficiency requirements listed below. Tier 3 represents the current minimum efficiency water source heat pumps must have in order to be Energy Start rated.

#### Tier 3: 1/1/2012 - No Effective End Date Published

Water-to-Air	EER	COP
Ground Loop	17.1	3.6
Ground Water	21.1	4.1
Water-to-Water		
Ground Loop	16.1	3.1
Ground Water	20.1	3.5






Contractor:	P.O.:
Engineer:	
Project Name:	Unit Tag:




### **Compressor Section Dimensional Data**



		Height	Width	Depth	Water	Water	Service	Valve	HWG	HWG	Low	External	Line	киоск	кноск
Models		Height	wiath	Depth	In	Out	Liquid Gas		In	Out	Voltage	Pump	Voltage	OUT	OUT
		Α	В	С	D	Е	F	G	Н	J	K	L	М	N	Р
077.050	in.	21.25	25.62	31.60	2.30	7.21	16.40	18.30	10.30	13.30	12.10	14.30	9.50	4.70	9.10
033-050	cm.	54.00	65.10	80.30	5.80	18.50	41.70	46.50	26.20	33.80	30.70	36.30	24.10	11.90	23.10

Contractor:	P.O.:
Engineer:	
Project Name:	Unit Tag:







### Air Handler Dimensional Data - SVH Air Handler

#### **Top Flow/Horizontal Unit Configuration**

#### **Top View**


#### **Bottom View**





#### **Front View**

**Right Side View** 



#### SVH Air Handler - Topflow/Horizontal

Topflow/ Horizontal		Ove	erall Ca	abinet	D E							erant ctions																			
1		Α	В	С	3/4" cond	1/2" cond	F	Н	J	K	L	M	N	0	Р	Q	R	S	T	U	٧	W	Х	Υ	Z	AA	BB	CC	DD	EE	FF
Config	uration		Depth	Height	Power Supply	Low Voltage					Suction	Liquid												Power	Supply	Low Voltage				П	
033-050	in.	24.9	21.2	58.0	56.1	53.2	2.6	1.9	4.8	6.4	9.6	10.8	1.1	1.7	2.9	4.5	20.3	21.9	23.5	2.2	20.6	2.2	18.4	1.7	4.2	6.7		18.0	3.4	18.0	1.8
033-050	cm.	63.2	53.8	147.3	142.5	135.1	6.6	4.8	12.2	16.3	24.4	27.4	2.8	4.3	7.4	11.4	51.6	55.6	59.7	5.6	52.3	5.6	46.7	4.3	10.7	17.0	3.8	45.7	8.6	45.7	4.6
	Condon	anta in	nlanta	2/4" ED	Т																										


Discharge fange is feld installed and extends 1" (25.4 mm) from cabinet NOTE: Clearance for maintenance and servicing access - minimum 30" from front of unit recommended for blower motoricoil replacement. Condensate drain lines routed to clear and panel access. Filter removal - minimum 30" recommended.


Contractor:	P.O.:	_
Engineer:		
Project Name:	Unit Tag:	




### **Air Handler Dimensional Data - SVH Air Handler**

#### **Bottom Flow Unit Configuration**







#### SVH Air Handler - Bottom flow

		Τ	Ove	verall Cabinet							gerant																	
Bot	tomflov	,				D	Е	F				Conn	ections															
Conf	iguratio	n 🗀	Α	В	С	1/2" cond	3/4" cond		G	Н	1	J	К	L	М	N	0	Р	Q	R	S	T	U	٧	W	х	Υ	Z
		I,	/idth	Denth	Height	Low	Power	Power				Suction	Liquid														$\Box$	
				- орг.		Voltage	Supply	Supply																				1 1
033-0	150 in.	2	4.9	21.2	58.0	4.4	1.9	2.6	24.0	27.0	28.5	31.3	32.8	1.1	1.7	2.8	4.5	20.2	21.9	23.5	1.2	3.4	18.0	18.0	2.1	2.2	20.5	18.5
L 33-0	cm	. 6	3.2	53.8	147.3	11.2	4.8	6.6	61.0	68.6	72.4	79.5	83.3	2.8	4.3	7.1	11.4	51.3	55.6	59.7	3.0	8.6	45.7	45.7	5.3	5.6	52.1	47.0

Condensate is plastic 3/4" FPT

Discharge flange is field installed and extends 1" (25.4 mm) from cabinet NOTE: Clearance for maintenance and servicing access - minimum 30° from front of unit recommended for blower motor/coil replacement. Condensate drain lines routed to clear filter and panel access. Filter removal - minimum 30° recommended.

Contractor:	P.O.:	-
Engineer:		-
Project Name:	Unit Tag:	



### **Compressor Section Physical Data**

	Model	NVZ033	NVZ042	NVZ050	
Compresso	r (1 each)	Va	riable Speed Sc	roll	
Factory Ch	arge R410a, oz [kg]	68 [1.93]	90 [2.55]	92 [2.61]	
Coax and Wat	ter Piping				
Water Conr	nections Size - Swivel - in [mm]	1" [25.4]	1" [25.4]	1" [25.4]	
HWG Conn	ection Size - Female Sweat I.D in [mm]	1/2" [12.7]	1/2" [12.7]	1/2" [12.7]	
	Brass Service Valve - Liquid Line - in [mm]	3/8" [9.45]			
	Brass Service Valve - Suction Line - in [mm]		[19.1]	7/8" [22.23]	
Coax & Pipi	ing Water Volume - gal [l]	1.3 [4.9]	2.3 [8.7]	2.3 [8.7]	
	Weight - Operating, lb [kg]		302 [137]	302 [137]	
	Weight - Packaged, lb [kg]	261 [118]	322 [146]	322 [146]	

Notes: All units have an EEV and 1/2 in. [12.7mm], and 3/4 in. [19.1] electrical knockouts Brass services valves are sweat type valves

03/18/20

### **Air Handler Physical Data**

Air Handler Model	Number (Refrigerant)	033	042	050				
	Air Coil Total Face Area, ft2 [m2]	6.81 [0.63]						
	Tube outside diameter - in. [mm]		3/8 [9.52]					
Evanorator Coil	Number of rows		3					
Evaporator Coil	Fins per inch		12					
Deficience	Suction line connection - in. [mm] sweat		7/8 [22.23]					
	Liquid line connection - in. [mm] sweat	3/8 [9.45]						
Refrigerant		R-410a						
Condensate drain	connection - (FPT) in. [mm]	3/4 [19.05]						
Blower Wheel Siz	e (Dia x W), in. [mm]	11 x 10 [279 x 254]						
Blower motor typ	e/speeds	Variable Speed ECM						
Blower motor out	put - hp [W]		1 [746]					
Filter Standard - 1	" [51mm] Field Supplied.		22 X 20 [559 x 508]					
Electrical charact	eristics (60hz)	208/230 - 1ph						
Shipping weight -	lbs. [kg]	206 [93.4]						
Operating weight	- lbs. [kg]	188 [85.3]						

04/07/2020

Contractor:	P.O.:	
Engineer:		-
Project Name	Unit Tag:	



### **Auxiliary Heat Compatibility**

Model	kW	Chamas	Min CFM			
Model	KVV	Stages	MIIII CFM	033	042	050
19P659-02	10	2	1300	•	•	•
19P659-03	15	2	1700		•	•
19P659-04	20	2	2000		·	•

03/12/20

## **Air Handler Auxiliary Heat Blower Settings**

Model	Variable Speed ECM DIP Setting
SVH033	10
SVH042	11
SVH050	11

6/6/2019

Contractor:	P.O.:	
Engineer:		
Project Name:	Unit Tag:	



### **Electrical Data**

#### Variable speed with external loop pump

Model	Rated Voltage	Voltage Min/Max	COMP LRA	COMP MCC	Drive RLA	Drive Internal Fuse	HWG Pump FLA	Ext Loop FLA	Total Unit FLA	Minimum Circuit Amp	Max Fuse HACR Breaker
033	208-230/60/1	187/253	10.2	18.0	22.0	30.0	0.4	5.4	27.8	33.3	35
042	208-230/60/1	187/253	12.0	23.5	28.0	35.0	0.4	5.4	33.8	40.8	45
050	208-230/60/1	187/253	12.0	30.0	33.0	40.0	0.4	5.4	38.8	47.1	50

Rated Voltage of 208/230/60/1 HACR circuit breaker in USA only All fuses Class RK-5 8/21/19

### **Air Handler Electrical Data**

Model	Electric Heat Capacity		Supply	Aux. Heat Minimum	n Rated	Voltage Min/Max	Fan Motor	Heate			Unit	Minir Circui		Maxi								
Model	KW BTUH		Circuit	· ·				pacity		FLA		pacity		Fuse/HACR								
	240v	240v		CFM			FLA	208v	240v	208v	240v	208v	240v	208v	240v							
033	0	0	-					7.0	-	1	7.0	7.0	8.8	8.8	15	15						
033	9.6	32,765	single	1,300			7.0	34.7	40.0	41.7	47.0	52.1	58.8	60	60							
	0	0	-				7.0	-	-	7.0	7.0	8.8	8.8	15	15							
	9.6	32,765	single	1,300	208-230/60/1		7.0	34.7	40.0	41.7	47.0	52.1	58.8	60	60							
042	14.4	49,147	single				7.0	52.0	60.0	59.0	67.0	73.8	83.8	80	90							
	14.4	49,147	L1/L2	1,700			7.0	34.7	40.0	41.7	47.0	52.1	58.8	60	60							
	14.4	43,147	L3/L4				208-230/60/1	208-230/60/1	208-230/60/1	208-230/60/1	208-230/60/1	208-230/60/1			-	17.3	20.0	17.3	20.0	21.6	25.0	25
	0	0	-			208-230/60/1							197/253	7.0	-	-	7.0	7.0	8.8	8.8	15	15
	9.6	32,765	single	1,300													. [	7.0	34.7	40.0	41.7	47.0
	14.4	49,147	single							7.0	52.0	60.0	59.0	67.0	73.8	83.8	80	90				
050	14.4	49,147	L1/L2	1,700			7.0	34.7	40.0	41.7	47.0	52.1	58.8	60	60							
030	14.4	49,147	L3/L4				-	17.3	20.0	17.3	20.0	21.6	25.0	25	25							
	19.2	65,530	single				7.0	69.3	80.0	76.3	87.0	95.4	108.8	100	110							
	19.2	65,530	L1/L2	2,000			7.0	34.7	40.0	41.7	47.0	52.1	58.8	60	60							
	13.2	05,550	L3/L4				-	34.7	40.0	34.7	40.0	43.4	50.0	50	50							

1/29/20

Rated Voltage of 208/230/60/1 HACR circuit breaker in USA only

Contractor:	P.O.:	
Engineer:		
Project Name:	Unit Tag:	



#### **SVH Blower Performance Data**

#### Variable Speed ECM

Model	Max ESP	Speed 1	Speed 2	Speed 3	Speed 4	Speed 5	Speed 6	Speed 7	Speed 8	Speed 9	Speed 10	Speed 11	Speed 12
033	0.75	250	400 G	550 L	650	750	850	1000	1150	1250 H	1350 Aux	1450	1600
042	0.75	250	450 G	650 L	800	950	1050	1200	1350	1450	1600 H	1750 Aux	1850
050	0.75	300	550 G	800 L	1000	1150	1300	1450	1600	1750	1900 H	2050 Aux	2200
**VS Com- pressor Speed				1-2	3-4		5-6	7-8		9-10	11-12		

4/15/2020

Factory settings are at recommended G, L, H and Aux positions

CFM is controlled within 5% up to the maximum ESP

#### **Line Set Sizes**

Unit	Air	20	feet	40	feet	60	feet	80 feet		NZ Factory	*Charge
Size	Handler	Suction	Liquid	Suction	Liquid	Suction	Liquid	Suction	Liquid	Charge (oz.)	Amount with SVH Air Handler (oz.)
NVZ033	SVH033	3/4" OD	3/8" OD	68	118						
NVZ042	SVH042	3/4" OD	3/8" OD	90	142						
NVZ050	SVH050	3/4" OD	3/8" OD	3/4" OD	3/8" OD	3/4" OD	3/8" OD	7/8" OD	3/8" OD	92	152
CAPA MULTI		1.0	00	0.9	85	0.	97	0.9	)55		

3/11/2020

Notes: \* The "Charge Amount with SVH Air Handler" column is based on the charge amount for a SVH Air Handler + Compressor Section/Split.

Additional charge will need to be added accordingly for line set length.

After charge is added, additional adjustments can be made to get appropriate subcooling and superheat measurements. Additional charge for R410A is 0.50 oz. per ft. for 3/8" and 1.0 oz. per ft. for 1/2" tube.

**NOTE:** Manufacturer recommends the total line set length not to exceed 80 ft with no more than 20 ft of vertical separation between the compressor section and air handler.

<sup>\*\*</sup> VS Compressor speed is given for the factory default cfm settings. When the cfm default settings are changed it will change the relationship to the compressor speed that is shown in the table. In cooling mode compressor speeds 10-12 are only available when SuperBoost mode is selected at the thermostat.

<sup>&</sup>quot;G" may be located anywhere within the airflow table.

<sup>&</sup>quot;L" setting should be located within the boldface CFM range

<sup>&</sup>quot;H" setting MUST be located within the shaded CFM range

<sup>&</sup>quot;Aux" setting MUST be equal to or higher than factory setting shown in the table above

Contractor:	P.O.:	-
Engineer:		_
Project Name:	Unit Tag:	



### **Operating Limits**

O	Coo	ling	Heating		
Operating Limits	(°F)	(°C)	(°F)	(°C)	
Air Limits					
Min. Ambient Air	45	7.2	45	7.2	
Rated Ambient Air	80	26.7	70	21.1	
Max. Ambient Air	100	37.8	85	29.4	
Min. Entering Air	50	10.0	40	4.4	
Rated Entering Air db/wb	80.6/66.2	27/19	68	20.0	
Max. Entering Air db/wb	110/83	43/28.3	80	26.7	
Water Limits					
Min. Entering Water	30	-1.1	20	-6.7	
Normal Entering Water	50-110	10-43.3	30-70	-1.1	
Max. Entering Water	120	48.9	90	32.2	

NOTE: Minimum/maximum limits are only for start-up conditions, and are meant for bringing the space up to occupancy temperature. Units are not designed to operate at the minimum/maximum conditions on a regular basis. The operating limits are dependent upon three primary factors: 1) water temperature, 2) return air temperature, and 3) ambient temperature. When any of the factors are at the minimum or maximum levels, the other two factors must be at the normal level for proper and reliable unit operation.

### **Definitions**

#### Abbreviations and Definitions

cfm = airflow, cubic feet/minute

EWT = entering water temperature, Fahrenheit

gpm = water flow in gallons/minute

WPD = water pressure drop, psi and feet of water

EAT = entering air temperature, Fahrenheit (dry bulb/wet bulb)

= air heating capacity, MBtu/h TC = total cooling capacity, MBtu/h SC = sensible cooling capacity, MBtu/h kW = total power unit input, kilowatts HR = total heat of rejection, MBtu/h

= total heat of extraction, MBtu/h

HWC = hot water generator capacity, MBtu/h

EER = Energy Efficient Ratio = Btu output/Watt input

COP = Coefficient of Performance

= Btu output/Btu input

LWT = leaving water temperature, °F LAT = leaving air temperature, °F ΤH = total heating capacity, MBtu/h LC = latent cooling capacity, MBtu/h S/T = sensible to total cooling ratio

Contractor:	P.O.:	
Engineer:		
Project Name:	Unit Tag:	



# **Compressor Section Pressure Drop**

Model	GPM	Pressure Drop (psi)					
Model	GPM	30° F	50° F	70°	90° F	110° F	
	11.5	3.60	3.30	3.10	2.90	2.70	
	9.0	2.30	2.10	2.00	1.90	1.70	
033	7.0	2.10	2.00	1.80	1.80	1.60	
	6.0	1.10	1.05	1.00	0.90	0.85	
	4.5	0.70	0.66	0.64	0.60	0.55	
	13.5	4.10	3.80	3.60	3.40	3.10	
	10.5	1.90	1.80	1.70	1.60	1.50	
042	7.5	1.70	1.50	1.40	1.30	1.20	
	6.0	1.00	0.90	0.80	07	0.60	
	4.0	0.40	0.38	0.36	0.34	0.30	
	17.0	6.20	5.80	5.40	5.00	4.60	
	13.5	3.90	3.70	3.50	3.10	2.90	
050	9.5	1.90	1.80	1.70	1.60	1.50	
	7.5	1.40	1.30	1.20	1.10	0.90	
	5.0	0.60	0.55	0.50	0.45	0.40	

8/21/2019

# **Compressor Section Thermistor Resistance**

for FP1, FP2, HV	stance (10k Ohm) VL, LWT and LLT ormance Option)	for compressor suction line, L	stance (1k Ohm) discharge line, AT, compressor and EWT
Thermistor	Thermistor	Thermistor	Thermistor
Temperature	Resistance	Temperature	Resistance
(°F)	(Ohms)	(°F)	(Ohms)
5	75757-70117	20	974.4-973.4
14	57392-53234	25	985.4-984.4
23	43865-40771	30	996.1-995.1
32	33809-31487	35	1007.0-1006.0
41	26269-24513	40	1017.8-1016.8
50	20570-19230	45	1028.6-1027.6
59	16226-15196	50	1039.5-1038.5
68	12889-12093	55	1050.2-1049.2
77	10310-9688	60	1061.2-1060.2
86	8300-7812	65	1072.9-1071.9
95	6723-6337	70	1082.7-1081.7
104	5480-5172	75	1093.4-1092.4
113	4490-4246	80	1103.0-1102.0
122	3700-3504	85	1115.5-1114.5
131	3067-2907	90	1126.2-1125.2
140	2554-2424	95	1136.6-1135.6
149	2149-2019	100	1147.2-1146.2
	4/24/12	105	1158.1-1157.1
		110	1168.8-1167.8
		115	1179.4-1178.4
		120	1190.1-1189.1
		125	1200.3-1199.3

4/24/12

1212.2-1211.2

Contractor:	P.O.:	
Engineer:		
Draiact Name:	Unit Tag	



### **Correction Factor Tables**

#### Air Flow Corrections (Compressor Speeds 1-3)

Airf	flow		Cooling				Heating	
CFM Per Ton of Clg	% of Nominal	Total Cap	Sens Cap	Power	Heat of Rej	Htg Cap	Power	Heat of Ext
240	60	0.940	0.740	0.967	0.951	0.943	1.106	0.902
275	69	0.950	0.783	0.973	0.959	0.953	1.088	0.918
300	75	0.960	0.827	0.978	0.967	0.962	1.070	0.935
325	81	0.970	0.870	0.984	0.975	0.972	1.053	0.951
350	88	0.980	0.913	0.989	0.984	0.981	1.035	0.967
375	94	0.990	0.957	0.995	0.992	0.991	1.018	0.984
400	100	1.000	1.000	1.000	1.000	1.000	1.000	1.000
425	106	1.030	1.022	1.024	1.026	1.009	0.982	1.016
450	113	1.060	1.045	1.048	1.051	1.019	0.965	1.033
475	119	1.091	1.067	1.071	1.077	1.028	0.947	1.049
500	125	1.121	1.089	1.095	1.103	1.038	0.930	1.065
520	130	1.151	1.111	1.110	1.129	1.047	0.912	1.082

6/29/12

#### Air Flow Corrections (Compressor Speeds 4-12)

Air	flow		Cooling				Heating	
CFM Per Ton of Clg	% of Nominal	Total Cap	Sens Cap	Power	Heat of Rej	Htg Cap	Power	Heat of Ext
240	60	0.928	0.747	0.936	0.929	0.961	1.097	0.938
275	69	0.940	0.789	0.946	0.941	0.967	1.081	0.948
300	75	0.952	0.831	0.957	0.953	0.974	1.064	0.959
325	81	0.964	0.873	0.968	0.965	0.980	1.048	0.969
350	88	0.976	0.916	0.979	0.976	0.987	1.032	0.979
375	94	0.988	0.958	0.989	0.988	0.993	1.016	0.990
400	100	1.000	1.000	1.000	1.000	1.000	1.000	1.000
425	106	1.020	1.023	1.004	1.018	1.010	0.966	1.018
450	113	1.056	1.042	1.008	1.035	1.020	0.932	1.036
475	119	1.072	1.079	1.011	1.053	1.029	0.898	1.054
500	125	1.087	1.095	1.015	1.070	1.039	0.865	1.071
520	130	1.099	1.113	1.019	1.088	1.049	0.831	1.089

6/14/12

#### **Cooling Capacity Corrections**

<b>Entering Air</b>	Total Clg		Sensi	ble Coc	ling Ca	pacity I	Multipli	ers - En	tering [	DB ° F		Power	Heat of
WB ° F	Cap	60	65	70	75	80	80.6	85	90	95	100	Input	Rejection
55	0.898	0.723	0.866	1.048	1.185	*	*	*	*	*	*	0.985	0.913
60	0.912		0.632	0.880	1.078	1.244	1.260	*	*	*	*	0.994	0.927
63	0.945			0.768	0.960	1.150	1.175	*	*	*	*	0.996	0.954
65	0.976			0.694	0.881	1.079	1.085	1.270	*	*	*	0.997	0.972
66.2	0.983			0.655	0.842	1.040	1.060	1.232	*	*	*	0.999	0.986
67	1.000			0.616	0.806	1.000	1.023	1.193	1.330	1.480	*	1.000	1.000
70	1.053				0.693	0.879	0.900	1.075	1.205	1.404	*	1.003	1.044
75	1.168					0.687	0.715	0.875	1.040	1.261	1.476	1.007	1.141

NOTE: \*Sensible capacity equals total capacity at conditions shown.

1/5/2017

#### **Heating Capacity Corrections**

Ent Air DB °F	<b>Heating Corrections</b>					
EIII AII DB F	Htg Cap	Power	Heat of Ext			
45	1.062	0.739	1.158			
50	1.050	0.790	1.130			
55	1.037	0.842	1.096			
60	1.025	0.893	1.064			
65	1.012	0.945	1.030			
68	1.005	0.976	1.012			
70	1.000	1.000	1.000			
75	0.987	1.048	0.970			
80	0.975	1.099	0.930			

1/5/17

Contractor:	P.O.:	
Engineer:		
Project Name:	Unit Tag:	



### **Antifreeze Corrections**

Catalog performance can be corrected for antifreeze use. Please use the following table and note the example given.

Antifreeze Type	Antifreeze % by wt	Heating	Cooling	Pressure Drop
EWT - °F [°C]		30 [-1.1]	90 [32.2]	30 [-1.1]
Water	0	1.000	1.000	1.000
	10	0.973	0.991	1.075
	20	0.943	0.979	1.163
Ethylene Glycol	30	0.917	0.965	1.225
	40	0.890	0.955	1.324
	50	0.865	0.943	1.419
	10	0.958	0.981	1.130
	20	0.913	0.969	1.270
Propylene Glycol	30	0.854	0.950	1.433
	40	0.813	0.937	1.614
	50	0.770	0.922	1.816
	10	0.927	0.991	1.242
	20	0.887	0.972	1.343
Ethanol	30	0.856	0.947	1.383
	40	0.815	0.930	1.523
	50	0.779	0.911	1.639
	10	0.957	0.986	1.127
	20	0.924	0.970	1.197
Methanol	30	0.895	0.951	1.235
	40	0.863	0.936	1.323
	50	0.833	0.920	1.399



WARNING: Gray area represents antifreeze concentrations greater than 35% by weight and should be avoided due to the extreme performance penalty they represent.

#### **Antifreeze Correction Example**

Antifreeze solution is Propylene Glycol 20% by weight. Determine the corrected heating and cooling performance at 30°F and 90°F respectively as well as pressure drop at 30°F for a 033 operating at 100% capacity.

The corrected cooling capacity at 90°F would be: 30,500 Btu/h x 0.969 = 29,554 Btu/h

The corrected heating capacity at  $30^{\circ}$ F would be: 34,100 Btu/h x 0.913 = 31,133 Btu/h

The corrected pressure drop at  $30^{\circ}$ F and 11.5 gpm would be: 7.9 feet of head x 1.270 = 10.03 feet of head

Contractor:	P.O.:
Engineer:	
Project Name:	Unit Tag:



### **Performance Data**

#### **NVZ033 - 50% Part Load**

		W	PD		F	IEATIN	G - EAT	70°F					WI	PD			COOL	NG - E	AT 80/6	57 °F		
°F	Flow- gpm	PSI	FT	Airflow	нс	Power	HE	LAT	СОР	нwс	°F	Flow gpm	PSI		Airflow	тс	sc	S/T	Power	HR	EER	нwс
				cfm	MBtuh	kW	MBtuh	°F		MBtuh		0.5			cfm	MBtuh	MBtuh	Ratio	kW	MBtuh		MBtuh
	3.0 4.5	0.5	1.1		Oper	ation n	ot recon	nmende	ed			2.5 3.5	0.2	0.5 1.1	ł							
20	6.0	1.2	2.7	550 750	12.4 12.7	1.48 1.37	7.2 8.0	90.6 85.7	2.43	2.2 1.9	20	4.5	0.7	1.6		(	Operatio	on not r	ecomm	ended		
	3.0	0.5	1.1	550	13.1	1.22	8.3	91.0	3.00	2.0		2.5	0.2	0.5	500	17.8	12.8	0.72	0.54	18.8	31.6	-
	3.0	0.5	1.1	750	13.6	1.25	8.7	86.1	3.04	1.7		2.5	0.2	0.5	650	18.1	14.0	0.77	0.56	19.2	30.9	-
30	4.5	0.7	1.6	550 750	13.4 14.0	1.23 1.26	8.6 9.0	91.6 86.5	3.06 3.11	2.1 1.8	30	3.5	0.5	1.1	500 650	18.0 18.3	12.9 14.1	0.71 0.77	0.51	18.9 19.3	33.7 32.5	-
	6.0	1.1	2.6	550	14.6	1.39	9.0	93.1	2.89	2.2		4.5	0.7	1.6	500	18.1	12.9	0.71	0.50	19.0	34.9	-
				750 550	14.9 15.6	1.29 1.27	9.8	87.5 95.8	3.23	1.9 2.0					650 500	18.6 19.3	14.1 13.2	0.76 0.68	0.52	19.5	34.0	-
	3.0	0.4	1.0	750	16.2	1.29	11.5	89.6	3.60	1.8		2.5	0.2	0.5	650	19.7	14.5	0.73	0.62	20.9	30.5	-
40	4.5	0.7	1.5	550 750	16.1 16.7	1.27	11.5 12.0	96.6	3.65	2.1 1.9	40	3.5	0.4	1.0	500	19.6	13.4	0.68	0.56	20.6	33.2	-
				550	17.0	1.29 1.30	12.0	90.2 98.1	3.71	2.2					650 500	19.9 19.7	14.6 13.4	0.73	0.59	21.0	32.2 34.5	-
	6.0	1.1	2.5	750	17.6	1.33	12.7	91.3	3.82	2.0		4.5	0.7	1.5	650	20.2	14.6	0.72	0.57	21.1	33.7	-
	3.0	0.4	1.0	550 750	18.2 18.8	1.31 1.33	13.7 14.2	100.6 93.2	4.06 4.13	2.5		2.5	0.2	0.5	500 650	20.6	13.2 14.7	0.64	0.63	21.8	31.2 31.4	-
50	4.5	0.6	1.5	550	18.8	1.31	14.4	101.7	4.20	2.5	50	3.5	0.4	1.0	500	20.8	13.3	0.64	0.61	21.9	32.3	-
30	4.5	0.0	1.5	750	19.4	1.33	14.9	94.0	4.28	2.3	30	3.3	0.4	1.0	650	21.4	14.7	0.69	0.63	22.5	32.6	-
	6.0	1.1	2.5	550 750	19.7 20.3	1.34 1.36	15.1 15.7	103.2 95.1	4.30	2.6		4.5	0.6	1.5	500 650	21.1 21.7	13.7 15.1	0.65 0.70	0.61	22.2	33.1 33.4	-
	3.0	0.4	1.0	550	20.7	1.33	16.1	104.8	4.55	2.7		2.5	0.2	0.5	500	20.0	13.2	0.66	0.74	21.6	25.6	1.3
	0.0	0. 1		750 550	21.2 21.5	1.34 1.33	16.6 17.0	96.2 106.2	4.63	2.5 2.8			0.2	0.0	650 500	20.5	14.6 13.3	0.71 0.66	0.76	22.1	25.9 26.6	1.4
60	4.5	0.6	1.4	750	22.0	1.34	17.4	97.2	4.83	2.6	60	3.5	0.4	1.0	650	20.7	14.7	0.71	0.74	22.2	26.8	1.3
	6.0	1.0	2.4	550	22.3	1.36	17.6	107.5	4.80	2.9		4.5	0.6	1.4	500	20.5	13.6	0.66	0.72	22.0	27.2	1.1
				750 550	22.8	1.37 1.35	18.1 18.5	98.1 108.9	4.88 5.03	2.7 3.1					650 500	21.1 19.3	15.1 13.2	0.72	0.73	22.5	27.5	1.2 1.7
	3.0	0.4	0.9	750	23.6	1.32	19.1	99.1	5.24	2.8		2.5	0.2	0.5	650	19.9	14.6	0.73	0.87	21.9	21.7	1.8
70	4.5	0.6	1.4	550 750	24.1 24.6	1.34 1.34	19.6 20.0	110.6 100.4	5.27 5.37	3.2 2.9	70	3.5	0.4	0.9	500 650	19.5 20.0	13.2 14.6	0.68	0.83	21.4 22.0	22.3	1.6 1.7
		10	2.7	550	24.8	1.37	20.0	111.7	5.29	3.3		4.5	0.0	1 /	500	19.8	13.6	0.73	0.82	21.7	22.9	1.5
	6.0	1.0	2.3	750	25.2	1.37	20.5	101.1	5.39	2.7		4.5	0.6	1.4	650	20.4	15.0	0.74	0.84	22.3	23.1	1.7
	3.0	0.4	0.9	550 750	25.4 25.8	1.34 1.33	20.9	112.8 101.8	5.57 5.68	3.7		2.5	0.2	0.4	500 650	18.5 19.0	12.9 14.3	0.70 0.75	0.93	20.8	18.8	2.3
80	4.5	0.6	1.3	550	26.6	1.33	22.1	114.9	5.87	3.9	80	3.5	0.4	0.9	500	18.6	13.0	0.69	0.91	20.9	19.5	2.2
•	7.5	0.0	1.5	750 550	27.0 27.0	1.32 1.36	22.5	103.3 115.5	5.99 5.84	3.5 4.0		3.5	0.4	0.5	650 500	19.2 19.0	14.3 13.3	0.75 0.70	0.93	21.4	19.7	2.4
	6.0	1.0	2.2	750	27.3	1.35	22.7	103.7	5.95	3.7		4.5	0.6	1.3	650	19.5	14.7	0.75	0.90	21.7	20.0	2.2
	3.0	0.4	0.9	550	27.7	1.33	23.2	116.7	6.12	4.3		2.5	0.2	0.4	500	17.6	12.6	0.71	1.02	20.3	16.5	3.0
				750 550	27.9 29.1	1.31	23.5	104.5 119.1	6.25	4.0					650 500	18.1 17.8	13.9 12.7	0.77 0.71	0.99	20.8	16.7 17.1	3.2 2.9
90	4.5	0.6	1.3	750	29.3	1.30	24.9	106.2	6.63	4.1	90	3.5	0.4	0.9	650	18.3	14.0	0.77	1.01	20.9	17.3	3.1
	6.0	0.9	2.2	550 750	29.3 29.4	1.34 1.32	24.7 24.9	119.3 106.3	6.40	4.6		4.5	0.6	1.3	500 650	17.6 18.6	12.3 14.4	0.70 0.77	1.17	20.8	14.4	2.8
	7.0	0.4	0.0	750	29.4	1.32	24.9	106.3	0.55	4.3		2.5	0.0	0.4	500	16.7	12.4	0.77	1.34	20.5	11.9	3.6
	3.0	0.4	0.8									2.5	0.2	0.4	650	17.2	13.7	0.80	1.36	21.0	12.0	3.8
100	4.5	0.5	1.2								100	3.5	0.4	0.8	500 650	16.9 17.4	12.4 13.8	0.74 0.79	1.30	20.5	12.4 12.5	3.3
	6.0	0.9	2.1						4.5	0.5	12	500	17.2	12.8	0.74	1.29	20.7	12.7	3.0			
	0.0	0.5								1.0	0.0	1.2	650 500	17.6 15.8	14.1 12.1	0.80	1.32 1.66	21.3	12.8 9.1	3.4 4.7		
	3.0	0.3	0.8									2.5	0.2	0.4	650	16.3	13.4	0.77	1.69	21.3	9.2	5.0
110	4.5	0.5	1.2		Oper	ation n	ot recon	nmende	ed		110	3.5	0.3	0.8	500	16.0	12.2	0.76	1.61	20.7	9.4	4.4
			2 2									4.5	0.5	1.0	650 500	16.4 16.2	13.5 12.5	0.82	1.64 1.60	21.3	9.5 9.7	4.8 4.1
	6.0	0.9	2.0									4.5	0.5	1.2	650	16.7	13.9	0.83	1.63	21.5	9.8	4.6
	3.0	0.3	0.8									2.5	0.2	0.4	500 650	13.2 13.5	12.1 13.2	0.92 0.98	1.95 2.00	19.2 19.6	6.4	6.2 6.0
120	4.5	0.5	1.2								120	3.5	0.3	ΩS	500	13.4	12.2	0.91	1.84	19.0	6.9	5.5
.20	7.5	0.5	1.2								.20	3.5	0.0	0.0	650	13.6	13.2	0.97	1.89	19.4	6.8	5.9
	6.0	0.8	1.9									4.5	0.5	1.2	500 650	13.5 13.8	12.2 13.2	0.90 0.96	1.78 1.84	18.9 19.4	7.2 7.1	5.0 5.6

Performance capacities shown in thousands of Btuh.

3/27/2020

Contractor:	P.O.:
Engineer:	
Project Name:	Unit Tag:



#### NVZ033 - 100% Full Load

14 4 2	-033			% Ful	LUa							1	T						<b>-</b>			
EWT	Flow	W	PD		1	HEATIN	IG - EAT	70°F			EWT	Flow	W	PD		С	OOLING	- EAT	80/67 °	F		
°F	gpm	PSI	FT	Airflow cfm	HC MBtuh	Power kW	HE MBtuh	°F	СОР	HWC MBtuh	°F	gpm	PSI	FT	Airflow cfm	TC MBtuh	SC MBtuh	S/T Ratio	Power kW	HR MBtuh	EER	HWC MBtuh
	6.0 9.0	1.5 2.3	3.5 5.4		Оре	eration r	not reco	mmen	ded			4.5 6.5	0.7 1.5	1.6 3.5								
20	12.0	4.1	9.5	1150	27.6	2.94	17.6	92.2	2.75	3.0	20	9.0	2.3	5.4			Operati	on not	recomn	nended		
				1500 1150	28.7 31.7	2.80	19.1 22.5	87.7 95.5	3.00	2.7 3.1					1000	34.6	22.1	0.64	1.14	38.5	30.4	-
	6.0	1.5	3.4	1500	32.6	2.79	23.1	90.1	3.42	2.8		4.5	0.7	1.6	1200	35.2	24.3	0.69	1.18	39.3	29.8	-
30	9.0	2.3	5.3	1150	32.5	2.74	23.1	96.2	3.48	3.2	30	6.5	1.5	3.4	1000	35.1	22.3	0.64	1.08	38.7	32.5	-
				1500 1150	33.4 32.8	2.82	23.8 22.6	90.6 96.4	3.47	2.9 3.2			<del> </del>		1200 1000	35.6 35.2	24.4	0.68	1.14	39.5 38.8	31.3 33.6	-
	12.0	4.0	9.2	1500	34.1	2.85	24.4	91.0	3.51	2.9		9.0	2.3	5.3	1200	36.1	24.4	0.68	1.10	39.9	32.8	-
	6.0	1.4	3.3	1150	35.4	2.84	25.7	98.5	3.66	3.3		4.5	0.7	1.5	1000	35.4	23.6	0.67	1.31	39.9	27.1	-
				1500 1150	36.5 36.5	2.91	26.5 26.7	92.5 99.4	3.67	3.1 3.4					1200 1000	36.1 35.8	25.9 23.9	0.72 0.67	1.36 1.24	40.7 40.1	26.5 28.8	-
40	9.0	2.2	5.1	1500	37.7	2.96	27.6	93.2	3.73	3.1	40	6.5	1.4	3.3	1200	36.5	26.1	0.71	1.30	40.9	28.0	-
	12.0	3.9	8.9	1150	37.3	2.92	27.3	100.0	3.74	3.5		9.0	2.2	5.1	1000	36.1	23.9	0.66	1.20	40.2	30.0	-
				1500 1150	38.5 39.2	2.99	28.3 29.0	93.7 101.5	3.78	3.2 3.7		1			1200 1000	36.9 34.7	26.1	0.71 0.66	1.26 1.47	41.2 39.7	29.3	-
	6.0	1.4	3.2	1500	40.3	3.02	30.0	94.9	3.91	3.4		4.5	0.6	1.5	1200	36.5	25.7	0.70	1.55	41.8	23.6	-
50	9.0	2.1	4.9	1150	40.6	3.05	30.2	102.7	3.90	3.8	50	6.5	1.4	3.2	1000	35.5	23.4	0.66	1.39	40.2	25.6	-
"	3.0	2.1	7.5	1500	41.9	3.09	31.3	95.9	3.97	3.5	50	0.5	1	5.2	1200	37.3	25.9	0.70	1.45	42.2	25.6	-
	12.0	3.7	8.6	1150 1500	41.5 42.8	3.08 3.12	31.0 32.2	103.4 96.4	3.95 4.02	3.9 3.6		9.0	2.1	4.9	1000	35.8 37.7	24.9	0.70	1.35 1.42	40.4 42.5	26.5 26.5	-
	6.0	1.3	3.1	1150	43.4	3.03	33.1	105.0	4.20	4.1		4.5	0.6	1.4	1000	32.9	23.4	0.71	1.68	38.6	19.6	1.9
	0.0	1.3	3.1	1500	44.8	3.05	34.4	97.7	4.31	3.8		4.5	0.0	1.4	1200	34.5	26.0	0.75	1.75	40.4	19.7	2.1
60	9.0	2.1	4.8	1150 1500	45.4 46.8	3.11 3.13	34.7 36.1	106.5 98.9	4.27	4.3 3.9	60	6.5	1.3	3.1	1000 1200	33.6 35.2	23.7	0.70	1.59 1.66	39.1 40.9	21.1 21.2	1.8 2.0
	12.0	7.0	0.4	1150	46.5	3.15	35.7	107.4	4.33	4.4			2.1	4.0	1000	34.0	24.9	0.73	1.55	39.3	21.9	1.7
	12.0	3.6	8.4	1500	48.0	3.16	37.2	99.6	4.45	4.0		9.0	2.1	4.8	1200	35.7	27.7	0.78	1.63	41.2	21.9	1.9
	6.0	1.3	3.0	1150 1500	47.7 49.1	3.07 3.15	37.2 38.4	108.4	4.55 4.57	4.6		4.5	0.6	1.4	1000 1200	31.0 32.1	23.7	0.76 0.79	1.92 1.98	37.6 38.9	16.2 16.2	2.4
				1150	50.2	3.17	39.3	110.4	4.63	4.8			t		1000	31.8	24.0	0.79	1.80	38.0	17.7	2.2
70	9.0	2.0	4.6	1500	51.8	3.17	41.0	102.0	4.78	4.4	70	6.5	1.3	3.0	1200	33.2	26.5	0.80	1.87	39.6	17.8	2.4
	12.0	3.5	8.1	1150	51.4	3.21	40.5	111.4	4.69	4.9		9.0	2.0	4.6	1000	32.2	24.9	0.77	1.76	38.2	18.3	2.0
	Н			1500 1150	53.2 51.0	3.20 3.18	42.3 40.1	102.8	4.87	4.5 5.2		1			1200 1000	33.6 29.6	27.6	0.82	1.83 2.14	39.8 36.9	18.4 13.8	2.3
	6.0	1.3	2.9	1500	52.8	3.16	42.0	102.6	4.90	4.9		4.5	0.6	1.3	1200	30.8	26.2	0.75	2.21	38.4	14.0	3.1
80	9.0	1.9	4.5	1150	53.9	3.31	42.7	113.4	4.78	5.4	80	6.5	1.3	2.9	1000	30.5	23.8	0.78	2.07	37.5	14.7	2.7
				1500 1150	55.8 55.5	3.27	44.6 44.1	104.4	4.99	5.0 5.6			-		1200 1000	31.7 30.8	26.4 24.4	0.83	2.13	38.9 37.7	14.9 15.2	3.0 2.5
	12.0	3.4	7.8	1500	57.4	3.30	46.1	105.4	5.10	5.1		9.0	1.9	4.5	1200	32.1	27.1	0.73	2.09	39.2	15.4	2.8
	6.0	1.2	2.8	1150	54.3	3.29	43.1	113.7	4.84	5.9		4.5	0.6	1.3	1000	28.3	23.4	0.83	2.40	36.4	11.8	3.7
	0.0	1.2	2.0	1500	56.2	3.24	45.2	104.7	5.09	5.5			0.0		1200	29.3	26.0	0.89	2.46	37.6	11.9	3.9
90	9.0	1.9	4.3	1150 1500	57.7 59.8	3.44	46.0 48.3	116.5 106.9	4.92 5.19	6.1 5.7	90	6.5	1.2	2.8	1000	29.1 30.2	23.7	0.82	2.33	37.0 38.3	12.5 12.6	3.4
	12.0	3.3	7.5	1150	59.6	3.49	47.7	117.9	5.01	6.3		9.0	1.9	4.3	1000	29.8	24.0	0.81	2.33	37.7	12.8	3.2
	12.0	5.5	7.5	1500	61.6	3.40	50.0	108.0	5.31	5.8		1 3.0	1.9	7.5	1200	30.5	26.5	0.87	2.34	38.5	13.0	4.1
	6.0	1.2	2.7									4.5	0.5	1.2	1000 1200	26.8 27.6	23.2 25.7	0.87	2.73	36.1 37.1	9.8 9.9	4.4 4.8
100	9.0	1.8	4.2								100	6.5	1.2	27	1000	27.7	23.5	0.85	2.68	36.8	10.3	4.1
100	9.0	1.0	4.2								100	0.5	1.2	2./	1200	28.6	26.1	0.91	2.72	37.9	10.5	4.5
	12.0	3.1	7.3									9.0	1.8	4.2	1000	28.0	23.4 25.9	0.84	2.63	37.0 38.0	10.6 10.8	3.8 4.3
	60	11	26							1		1 -	O.F.	12	1000	25.3	23.0	0.91	3.06	35.8	8.3	5.6
	6.0	1.1	2.6									4.5	0.5	1.2	1200	26.0	25.5	0.98	3.10	36.6	8.4	5.9
110	9.0	1.7	4.0		Оре	eration r	not reco	mmen	ded		110	6.5	1.1	2.6	1000 1200	26.3 27.0	23.2 25.8	0.88	3.03	36.7 37.4	8.7 8.9	5.2 5.6
	12.0	7.0	7.0										17	4.0	1000	26.6	22.9	0.96	2.98	36.7	8.9	4.8
	12.0	3.0	7.0									9.0	1.7	4.0	1200	27.3	25.3	0.93	3.01	37.6	9.1	5.3
	6.0	1.1	2.5									4.5	0.5	1.2	1000	24.4	22.1	0.90	3.60	36.7	6.8	6.7
													<u> </u>		1200 1000	25.0 24.7	24.1	0.97	3.69 3.41	37.5 36.4	6.8 7.3	7.1 6.2
120	9.0	1.7	3.8								120	6.5	1.1	2.5	1200	25.2	24.2	0.96	3.49	37.1	7.2	6.7
	12.0	2.9	6.7									9.0	1.7	3.8	1000	25.0	22.3	0.89	3.30	36.2	7.6	6.4
	ш		<u> </u>		thousan										1200	25.5	24.2	0.95	3.40	37.1	7.5	7.1

Performance capacities shown in thousands of Btuh.

3/27/2020

Contractor:	P.O.:	
Engineer:		
Project Name:	Unit Tag:	



#### NVZ042 - 50% Part Load

		I	PD	Part			NC EAT	T 70°E				Ι	w				6001	INC F	- AT 90/	'67 °E		
EWT	Flow	VV	PD		_		NG - EA		ı		EWT	Flow	VV.	עק			1		EAT 80/	1 1		
°F	gpm	PSI	FT	Airflow cfm	HC MBtuh	Power kW	HE MBtuh	°F	СОР	HWC MBtuh	°F	gpm	PSI	FT	Airflow cfm		SC MBtuh	S/T Ratio	Power kW	HR MBtuh	EER	HWC MBtuh
	3.7 5.2	0.4	1.6		Ope	ration	not reco	mmen	ded			3.0 4.4	0.2	0.5 1.4								
20	6.7	1.2	2.7	700	16.6	1.73	10.7	91.9	2.81	2.7	20	5.8	0.9	2.2		(	Operati	on not	recomn	nended		
			2.,	900 700	16.9 17.1	1.66 1.56	11.2 11.8	87.4 92.6	2.98 3.20	2.3		0.0	0.0		650	23.3	15.7	0.67	0.59	24.2	37.8	T -
	3.7	0.3	0.8	900	17.7	1.59	12.2	88.2	3.26	2.2		3.0	0.2	0.5	750	23.8	17.2	0.73	0.59	24.7	36.9	-
30	5.2	0.7	1.6	700	18.5	1.63	12.9	94.4	3.31	2.7	30	4.4	0.6	1.3	650	23.7	15.9	0.67	0.56	24.4	40.3	-
				900 700	19.0 19.2	1.65 1.74	13.4 13.3	89.6 95.4	3.39	2.3			$\vdash$		750 650	24.0	17.3 15.9	0.72	0.59	24.9 24.5	38.8 41.7	-
	6.7	1.1	2.6	900	19.6	1.67	13.9	90.2	3.44	2.4		5.8	0.9	2.1	750	24.4	17.3	0.71	0.57	25.1	40.7	-
	3.7	0.3	0.8	700	19.9	1.60	14.4	96.3	3.64	2.8		3.0	0.2	0.5	650	24.4	16.1	0.66	0.67	25.5	34.4	-
			1.5	900 700	20.5	1.61 1.66	15.0 15.8	91.1 98.4	3.73 3.78	2.4		<b>-</b>			750 650	24.9	17.6 16.2	0.71	0.70	26.1 25.7	33.7 36.7	-
40	5.2	0.7	1.5	900	22.2	1.66	16.5	92.8	3.91	2.5	40	4.4	0.6	1.3	750	25.1	17.7	0.70	0.67	26.2	35.6	-
	6.7	1.1	2.5	700 900	22.1	1.67 1.69	16.4 17.2	99.3 93.6	3.88 3.98	3.0 2.6		5.8	0.9	2.0	650 750	24.9 25.4	16.2 17.7	0.65	0.62	25.8 26.4	38.1 37.2	-
	77	0.7	0.7	700	22.7	1.64	17.1	100.0	4.06	3.1		7.0	0.2	0.5	650	25.0	15.3	0.61	0.85	26.7	27.9	-
	3.7	0.3	0.7	900	23.4	1.64	17.8	94.1	4.19	2.8		3.0	0.2	0.5	750	25.8	18.0	0.70	0.89	27.6	27.6	-
50	5.2	0.6	1.5	700 900	24.4	1.69 1.68	18.7 19.6	102.3 96.1	4.24	3.3 2.9	50	4.4	0.5	1.2	650 750	25.5 26.3	15.3 18.1	0.60	0.74	26.8 27.7	33.0 32.4	-
	6.7	1.1	2.5	700	25.4	1.70	19.6	103.6	4.37	3.4		5.8	0.9	2.0	650	25.7	15.3	0.60	0.69	26.8	35.2	-
	0.7	1.1	2.5	900	26.2	1.70	20.4	97.0	4.52	3.0		3.0	0.3	2.0	750	26.5	18.1	0.68	0.73	27.7	34.5	1.7
	3.7	0.3	0.7	700 900	25.2 26.1	1.68 1.67	19.4 20.4	103.3 96.8	4.39 4.58	2.9		3.0	0.2	0.5	650 750	23.6	15.0 17.7	0.64	1.03	25.9 26.7	22.8	1.3
60	5.2	0.6	1.4	700	27.2	1.72	21.4	106.0	4.64	3.0	60	4.4	0.5	1.2	650	24.0	15.1	0.63	0.88	25.9	26.1	1.2
	J.2	0.0		900 700	28.3	1.70 1.74	22.5 22.5	99.1 107.6	4.88 4.79	2.6 3.2			0.5	1.2	750 650	24.8	17.8 15.2	0.72	0.92	26.7 26.0	25.7 27.8	1.4
	6.7	1.0	2.4	900	29.4	1.74	23.5	100.2	5.02	2.7		5.8	0.8	1.9	750	25.0	17.9	0.02	0.87	26.8	27.4	1.3
	3.7	0.3	0.7	700	27.7	1.72	21.8	106.6	4.72	3.4		3.0	0.2	0.5	650	22.3	14.8	0.66	1.12	25.1	18.9	2.2
				900 700	30.5 30.0	1.72 1.75	24.6 24.1	101.4 109.7	5.20	3.0					750 650	22.9	16.5 14.9	0.72	1.18	25.8 24.9	18.5 21.1	2.3
70	5.2	0.6	1.4	900	31.2	1.72	25.4	102.1	5.32	3.2	70	4.4	0.5	1.2	750	23.2	17.6	0.76	1.06	25.8	20.8	2.2
	6.7	1.0	2.3	700 900	31.4 32.6	1.77 1.73	25.4 26.7	111.6 103.5	5.20 5.52	3.8 3.5		5.8	0.8	1.8	650 750	22.9	15.0 17.6	0.66	0.97	25.1 25.9	22.5	1.8 2.0
		0.7	0.7	700	29.7	1.77	23.6	109.2	4.91	4.2		7.0		0.4	650	23.6	13.7	0.75	1.30	24.2	15.3	2.3
	3.7	0.3	0.7	900	30.8	1.74	24.9	101.7	5.19	3.7		3.0	0.2	0.4	750	21.5	16.1	0.75	1.35	25.1	15.1	2.6
80	5.2	0.6	1.3	700 900	32.2 33.5	1.79 1.74	26.1 27.6	112.6 104.5	5.27 5.63	3.9	80	4.4	0.5	1.1	650 750	20.9	13.9 16.3	0.66	1.20	24.0 24.8	16.6 16.4	2.0
	6.7	1.0	2.2	700	33.8	1.81	27.7	114.8	5.48	4.6		5.8	0.8	1.8	650	21.4	14.0	0.65	1.15	24.3	17.7	1.8
	0.7	1.0	2.2	900	35.2	1.76	29.2	106.2	5.86	4.1		5.6	0.6	1.0	750	22.1	16.4	0.75	1.20	25.1	17.5	2.2
	3.7	0.3	0.6	700 900	31.6 32.9	1.82 1.78	25.4 26.8	111.8 103.8	5.09 5.41	5.1 4.6		3.0	0.2	0.4	650 750	19.3 19.9	12.7 14.9	0.66	1.47 1.52	23.4	12.6 12.5	3.7 4.0
90	5.2	0.6	1.3	700	34.4	1.83	28.1	115.5	5.51	5.4	90	4.4	0.5	1.1	650	19.3	12.8	0.66	1.39	23.1	13.2	3.3
				900 700	35.8 36.3	1.77 1.85	29.8 30.0	106.8 118.0	5.93 5.75	4.8 5.6			$\vdash$		750 650	19.9 19.8	15.1 14.1	0.76	1.44	23.8 23.6	13.1 13.8	3.8
	6.7	0.9	2.2	900	37.8	1.79	31.7	108.9	6.19	5.0		5.8	0.7	1.7	750	20.5	15.2	0.74	1.39	24.2	14.0	3.5
	3.7	0.3	0.6									3.0	0.2	0.4	650	17.8	12.0	0.67	1.68	22.7	10.1	5.1
												<del> </del>	_		750 650	18.4 17.7	14.1 12.2	0.77	1.75 1.64	23.5 22.4	10.0	5.7 4.7
100	5.2	0.5	1.2								100	4.4	0.4	1.0	750	18.2	14.3	0.78	1.70	23.2	10.2	5.3
	6.7	0.9	2.1									5.8	0.7	1.7	650 750	18.4 18.9	12.3 14.5	0.67	1.58 1.65	22.9 23.6	11.1 10.9	4.3
	3.7	0.7	0.6									3.0	0.2	0.4	650	16.3	11.4	0.70	1.89	22.0	8.2	7.3
	J./	0.3	0.0									J.0	0.2	0.4	750	16.8	13.3	0.79	1.97	22.7	8.1	7.8
110	5.2	0.5	1.2		Ope	eration	not reco	mmen	ded		110	4.4	0.4	1.0	650 750	16.1 16.6	11.5 13.5	0.72	1.88	21.7 22.5	8.1 8.1	6.8 7.5
	6.7	0.9	2.0									5.8	0.7	1.6	650	16.9	11.7	0.70	1.82	22.3	8.8	6.2
													$\vdash$		750 650	17.3 14.2	13.8 12.3	0.79	1.90	23.0 21.4	8.7 5.8	7.0
	3.7	0.2	0.6									3.0	0.2	0.4	750	14.5	13.4	0.92	2.38	21.9	5.8	10.9
120	5.2	0.5	1.2								120	4.4	0.4	1.0	650 750	14.4 14.6	12.4 13.4	0.86	2.19	21.2 21.6	6.2	9.3
	6.7	00	10									E 0	0.7	1 =	650	14.5	12.4	0.92	2.25	21.6	6.5	8.0
	6.7	0.8	1.9									5.8	0.7	1.5	750	14.8	13.4	0.91	2.19	21.6	6.4	9.1

Performance capacities shown in thousands of Btuh.

3/27/2020

Contractor:	P.O.:
Engineer:	
Project Name:	Unit Tag:




#### NVZ042 - 100% Full Load

=1		w	PD			HEATIN	NG - EA	T 70°F			_,	L.	w	PD			COOL	ING - E	AT 80/	67 °F		
°F	Flow gpm			Airflow	нс	Power	HE	LAT	СОР	HWC	ewt °F	Flow gpm		FT	Airflow	1	sc	S/T	Power	HR	EER	HWC
	9.0	1.9	4.3	cfm	MBtuh	kW	MBtuh	°F		MBtuh		6.0	0.9	2.2	cfm	MBtuh	MBtuh	Ratio	kW	MBtuh		MBtuh
20	12.0	3.5	8.1		Ope	ration r	not reco	mmen	ded		20	8.5	1.6	3.8			Operatio	on not	racam"	nendad		
20	15.0	5.0	11.6	1600 1800	36.8 37.4	3.84 3.84	23.7	91.3 89.2	2.81 2.85	3.5 3.1	20	11.0	2.5	5.7			peratio	JII HOL I	ecomin	ienaea		
	9.0	1.8	4.2	1600	37.8	3.68	25.3	91.9	3.01	3.5		6.0	0.9	2.1	1200	38.7	24.1	0.62	1.40	43.5	27.6	-
	3.0	1.0	4.2	1800 1600	39.1 40.9	3.74 3.85	26.4 27.7	90.1 93.7	3.07 3.11	3.2		0.0	0.5	2.1	1400 1200	39.4 39.2	26.5 24.3	0.67	1.46	44.4 43.8	27.0 29.4	-
30	12.0	3.4	7.9	1800	42.1	3.88	28.9	91.7	3.19	3.2	30	8.5	1.6	3.7	1400	39.2	26.6	0.62	1.41	44.7	28.3	-
	15.0	4.9	11.3	1600	42.7	3.93	29.3	94.7	3.18	3.9		11.0	2.4	5.5	1200	39.4	24.3	0.62	1.30	43.9	30.4	-
				1800 1600	43.4 43.0	3.93 3.81	30.0 30.0	92.3 94.9	3.24	3.4					1400 1200	40.4	26.6 28.0	0.66	1.36 1.61	45.0 47.8	29.7 26.2	-
	9.0	1.8	4.1	1800	44.4	3.84	31.3	92.8	3.39	3.5		6.0	0.9	2.0	1400	43.1	30.6	0.71	1.68	48.9	25.7	-
40	12.0	3.3	7.6	1600 1800	46.4 48.0	3.96 3.96	32.9 34.5	96.8 94.7	3.44 3.56	4.2 3.7	40	8.5	1.5	3.6	1200 1400	42.8 43.6	28.3 30.9	0.66	1.53	48.0 49.1	27.9 27.1	-
	15.0	17	11.0	1600	47.9	3.98	34.3	97.7	3.53	4.4		11.0	2.3	5.3	1200	43.1	28.3	0.66	1.49	48.2	29.0	-
	15.0	4.7	11.0	1800	49.6	4.01	35.9	95.5	3.62	3.9		11.0	2.3	5.5	1400	44.1	30.9	0.70	1.56	49.4	28.4	-
	9.0	1.7	3.9	1600 1800	48.2 49.7	3.94 3.94	34.8 36.3	97.9 95.6	3.59 3.70	4.4		6.0	0.9	2.0	1200 1400	45.1 46.5	29.6 35.0	0.66 0.75	2.04	52.1 53.8	22.1 21.9	-
50	12.0	3.2	7.4	1600	51.9	4.06	38.1	100.1	3.75	4.8	50	8.5	1.5	3.5	1200	46.1	29.8	0.65	1.77	52.1	26.1	-
			-	1800 1600	53.9 53.9	4.04	40.2	97.7 101.2	3.91 3.86	4.4 5.1		-			1400 1200	47.5 46.4	35.1 29.8	0.74	1.85 1.66	53.8 52.1	25.6 27.9	-
	15.0	4.6	10.6	1800	55.7	4.09	41.7	98.7	3.99	4.6		11.0	2.2	5.2	1400	47.8	35.1	0.73	1.75	53.8	27.3	-
	9.0	1.7	3.8	1600 1800	53.3 55.2	4.09 4.06	39.4 41.4	100.8 98.4	3.82 3.98	5.2 4.7		6.0	0.8	1.9	1200 1400	43.4 44.7	28.8 34.0	0.66 0.76	2.25	51.1 52.8	19.3 19.0	2.6
	12.0	71	72	1600	57.7	4.00	43.4	103.4	4.04	5.6	60	0.5	1.4	77	1200	44.1	29.0	0.76	2.00	50.9	22.1	2.4
60	12.0	3.1	7.2	1800	59.9	4.14	45.8	100.8	4.24	5.1	80	8.5	1.4	3.3	1400	45.5	34.2	0.75	2.09	52.6	21.8	2.6
	15.0	4.4	10.3	1600 1800	60.1 62.3	4.23 4.18	45.7 48.0	104.8	4.17 4.37	6.0 5.4		11.0	2.2	5.0	1200 1400	44.6	29.1 34.3	0.65	1.90 1.98	51.1 52.7	23.5 23.2	2.2
	9.0	1.6	3.7	1600	58.4	4.24	44.0	103.8	4.04	6.0		6.0	0.8	1.8	1200	41.6	28.0	0.67	2.46	50.0	16.9	3.4
	3.0	1.0	5.7	1800 1600	65.4 63.4	4.20	51.1 48.7	103.6 106.7	4.56 4.31	5.5 6.5		0.0	0.0	1.0	1400 1200	44.0 42.1	33.1 28.3	0.75 0.67	2.42	52.3 49.7	18.2 18.9	3.6 3.1
70	12.0	3.0	6.9	1800	65.9	4.24	51.4	103.9	4.56	6.0	70	8.5	1.4	3.2	1400	43.4	33.3	0.77	2.33	51.3	18.7	3.4
	15.0	4.3	9.9	1600	63.7	4.28	49.1	106.9	4.36	6.9		11.0	2.5	4.9	1200	42.8	28.4	0.66	2.13	50.0	20.1	2.8
				1800 1600	68.8 61.8	4.26 4.38	54.3 46.8	105.4 105.8	4.73 4.13	7.2 7.1					1400 1200	44.1 38.4	33.4 27.1	0.76	2.21	51.6 47.7	20.0 14.1	3.2 4.5
	9.0	1.5	3.6	1800	64.2	4.31	49.5	103.0	4.37	6.5		6.0	0.8	1.8	1400	39.6	31.8	0.80	2.85	49.3	13.9	4.8
80	12.0	2.9	6.7	1600 1800	67.1 69.8	4.43	52.0 55.1	108.8	4.44	7.6 7.0	80	8.5	1.4	3.1	1200 1400	38.6 39.8	27.4 32.2	0.71	2.53	47.3 48.8	15.2 15.1	4.1 4.4
	15.0	4.2	9.6	1600	70.5	4.48	55.2	110.8	4.61	8.1		11.0	2.0	4.7	1200	39.5	27.6	0.70	2.42	47.8	16.3	3.8
	10.0	1.2	0.0	1800 1600	73.4 65.2	4.36 4.53	58.5 49.7	107.7 107.7	4.93 4.21	7.5 8.4		11.0	2.0	1,	1400 1200	40.7 35.2	32.4 26.1	0.80	2.53	49.3 45.4	16.1 11.8	4.2 6.0
	9.0	1.5	3.4	1800	67.7	4.44	52.6	104.8	4.48	7.7		6.0	0.7	1.7	1400	36.3	30.7	0.74	3.12	46.9	11.7	6.3
90	12.0	2.8	6.5	1600	70.9	4.56	55.3	111.0	4.55	8.9	90	8.5	1.3	3.0	1200	35.2	26.4	0.75	2.84	44.9	12.4	5.3
	15.0	4.0	0.7	1800 1600	73.8 74.8	4.41 4.61	58.7 59.0	108.0	4.90 4.75	9.5		11.0		4.5	1400	36.2 36.1	31.1 29.2	0.86	2.94	46.2 45.6	12.3 12.9	5.8 5.0
	15.0	4.0	9.3	1800	77.9	4.46	62.7	110.1	5.12	8.7		11.0	2.0	4.5	1400	37.3	31.4	0.84	2.84	47.0	13.1	6.3
	9.0	1.4	3.3									6.0	0.7	1.7	1200 1400	32.6 33.6	24.4 28.7	0.75 0.85	3.32 3.46	43.9 45.4	9.8 9.7	7.0 7.5
100	12.0	27	6.2								100	8.5	1.3	2.9	1200	32.4	24.7	0.76	3.23	43.4		6.7
100												0.5	1.5	2.5	1400 1200	33.4 33.6	29.1 25.1	0.87 0.75	3.36 3.11	44.8 44.2	9.9 10.8	7.3 6.3
	15.0	3.9	8.9									11.0	1.9	4.4	1400	34.6	29.5	0.75	3.25	45.6	10.6	7.1
	9.0	1.4	3.2									6.0	0.7	1.6	1200	30.0	22.7	0.76	3.64	42.4	8.2	9.0
					-										1400 1200	30.8 29.5	26.7 23.0	0.87 0.78	3.79 3.62	43.7 41.9	8.1 8.2	9.8 8.6
110	12.0	2.6	6.0		Ope	ration i	not reco	mmen	ded		110	8.5	1.2	2.8	1400	30.5	27.1	0.89	3.77	43.4	8.1	9.4
	15.0	3.7	8.6									11.0	1.8	4.2	1200 1400	30.9 31.8	23.4 27.5	0.76 0.86	3.51 3.66	42.9 44.3	8.8 8.7	8.2 9.2
	9.0	17	71									6.0	0.7	1 =	1200	26.7	23.9	0.86	4.35	41.5	6.1	11.9
	9.0	1.3	3.1									6.0	0.7	1.5	1400	27.2	26.1	0.96	4.45	42.4	6.1	12.4
120	12.0	2.5	5.8								120	8.5	1.2	2.7	1200 1400	27.0 27.5	24.1 26.2	0.89	4.11 4.21	41.0 41.9	6.6 6.5	11.1 12.0
	15.0	3.6	8.2									11.0	1.7	4.0	1200	27.2	24.1	0.89	3.97	40.8	6.8	10.2
				ios show				L		1400	27.8	26.2	0.94	4.10	41.8	6.8	7/2020					

Performance capacities shown in thousands of Btuh.

3/27/2020

Contractor:	P.O.:
Engineer:	
Project Name:	Unit Tag:



#### NVZ050 - 50% Part Load

		_	PD	Part			3 - EAT 2	70°F				L.	wı	PD			COOLI	NG - E	AT 80/6	57 °F		
EWT °F	Flow gpm	PSI	FT	Airflow		Power	HE	LAT	СОР	HWC	°F	Flow gpm	PSI	FT	Airflow	тс	sc	S/T	Power	HR	EER	HWC
	3.7	0.1	0.3	cfm	MBtuh	kW	MBtuh	°F		MBtuh		3.2	0.1	0.3	cfm	MBtuh	MBtuh	Ratio	kW	MBtuh		MBtuh
20	5.1	0.6	1.4		Oper	ation no	ot recom	mend	ed		20	4.6	0.5	1.1			)noratio	n not r	ocomm.	andad		
20	7.5	1.2	2.7	850 980	21.5 21.6	2.29	14.0 14.1	93.7 90.4	2.78	3.9 3.7	20	6.0	0.8	1.9			Operatio	II HOL I	ecomm	ended		
	3.7	0.1	0.3	850	23.8	2.32	15.0	95.0	2.90	4.0		3.2	0.1	0.3	750	23.2	15.5	0.67	0.64	24.3	34.6	-
	3./	0.1	0.3	980	24.7	2.35	15.7	92.4	2.96	3.6		3.2	0.1	0.3	850	23.7	17.0	0.72	0.67	24.8	33.8	-
30	5.1	0.6	1.3	850 980	23.7	2.35 2.38	14.8 15.5	94.8 92.3	2.84 2.90	4.1 3.7	30	4.6	0.5	1.1	750 850	23.6 23.9	15.7 17.1	0.66	0.61 0.64	24.5 25.0	36.8 35.5	-
	7.5	11	2.6	850	25.3	2.48	16.1	96.8	2.91	4.1		6.0	0.8	1.8	750	23.7	15.7	0.66	0.59	24.6	38.2	-
	7.5	1.1	2.6	980	25.4	2.38	16.3	93.1	3.00	3.5		6.0	0.8	1.8	850	24.3	17.1	0.71	0.62	25.2	37.3	-
	3.7	0.1	0.3	850 980	28.2 29.1	2.39	19.1 19.9	99.7 96.5	3.35	4.2 3.8		3.2	0.1	0.3	750 850	27.0 27.5	18.4 20.1	0.68	0.86 0.89	28.6 29.3	30.0 29.4	-
40	F 1	0.0	17	850	28.4	2.42	19.2	99.9	3.32	4.3	40	1.0	0.4	10	750	27.3	18.6	0.73	0.81	28.8	32.0	-
40	5.1	0.6	1.3	980	29.2	2.43	19.9	96.7	3.40	3.9	40	4.6	0.4	1.0	850	27.8	20.3	0.73	0.85	29.4	31.1	-
	7.5	1.1	2.5	850 980	29.4 30.2	2.43	20.0	100.9	3.41	4.4		6.0	0.8	1.8	750 850	27.5 28.1	18.6 20.3	0.67	0.79 0.83	28.9 29.6	33.2 32.5	-
				850	32.6	2.44	23.2	104.4		4.5					750	31.0	20.5	0.72	1.04	33.0	28.4	-
	3.7	0.1	0.2	980	33.5	2.45	24.1	100.7		4.2		3.2	0.1	0.2	850	31.9	23.2	0.73	1.10	34.1	27.7	-
50	5.1	0.5	1.2	850	33.1	2.50	23.6	105.0		4.7	50	4.6	0.4	1.0	750	31.0	20.6	0.67	1.00	33.0	29.5	-
				980 850	33.9 34.1	2.48 2.52	24.3 24.5	101.0 106.0		4.3 4.8					850 750	31.9 31.1	23.4	0.73	1.05 0.98	34.0 33.0	29.0 30.2	-
	7.5	1.1	2.5	980	34.9	2.52	25.3	101.9	3.96	4.6		6.0	0.7	1.7	850	32.0	23.4	0.88	1.03	34.0	29.6	-
	3.7	0.1	0.2	850	36.4	2.53	26.6	108.4		4.3		3.2	0.1	0.2	750	30.0	20.0	0.67	1.26	32.9	22.7	2.4
	3./	0.1	0.2	980	37.2	2.51	27.5	104.0		3.9		J.Z	0.1	0.2	850	30.9	22.6	0.73	1.32	34.0	22.3	2.6
60	5.1	0.5	1.2	850 980	37.5 38.1	2.57 2.54	27.6 28.3	109.6 104.9		4.4	60	4.6	0.4	1.0	750 850	30.2 31.1	20.2 22.8	0.67	1.22 1.27	32.9 33.9	23.5	2.3
	7.5	1.0	2.4	850	38.4	2.60	28.4	110.5	_	4.6			0.7	17	750	30.3	20.2	0.67	1.20	32.9	24.1	2.2
	7.5	1.0	2.4	980	39.0	2.56	29.1	105.7		4.1		6.0	0.7	1.7	850	31.2	22.8	0.73	1.25	34.0	23.8	2.4
	3.7	0.1	0.2	850	40.1 39.4	2.61	30.0	112.4 106.0	4.38	4.8		3.2	0.1	0.2	750 850	29.1	19.5	0.67	1.48	32.8	18.7	3.3
				980 850	41.8	2.57 2.65	29.3 31.5	114.2	4.49	4.4 5.0			<u> </u>		750	29.6 29.3	22.1 19.7	0.74	1.66 1.44	33.9 32.8	17.0 19.4	3.4 3.1
70	5.1	0.5	1.2	980	42.3	2.59	32.2	108.8		4.6	70	4.6	0.4	0.9	850	30.2	22.2	0.74	1.50	33.9	19.1	3.3
	7.5	1.0	2.3	850	42.6	2.68	32.2	115.1	4.53	5.2		6.0	0.7	1.6	750	29.4	19.8	0.67	1.41	32.8	19.9	2.9
				980 850	43.1	2.62 2.68	32.9 30.1	109.5 112.7	4.68	4.8 5.7					850 750	30.3 27.2	22.3 19.5	0.73	1.47 1.75	33.9 31.9	19.7 14.8	3.1 3.4
	3.7	0.1	0.2	980	43.9	2.62	30.6	107.4		5.2		3.2	0.1	0.2	850	28.0	21.7	0.74	1.75	32.9	14.7	3.4
80	5.1	0.5	1.1	850	46.0	2.72	32.2	115.2	4.46	5.9	80	4.6	0.4	0.9	750	27.5	19.7	0.68	1.71	32.0	15.3	3.1
"	5.1	0.5	1.1	980	46.2	2.64	32.6	109.4		5.4	00	7.0	0.7	0.5	850	28.3	22.0	0.74	1.77	33.0	15.2	3.5
	7.5	1.0	2.2	850 980	46.5 46.7	2.76 2.68	32.5 33.0	115.7 109.8	4.45 4.60	6.1 5.6		6.0	0.7	1.6	750 850	27.6 28.5	19.8 22.2	0.68	1.68 1.74	32.1 33.1	15.7 15.6	2.9 3.3
	77	0.1	0.2	850	46.9	2.75	30.2	113.1	4.21	6.6		7.0	0.1	0.2	750	25.4	19.4	0.69	2.02	31.0	11.9	4.8
	3.7	0.1	0.2	980	47.0	2.68	30.5	107.5		6.1		3.2	0.1	0.2	850	26.1	21.6	0.74	2.08	32.0	12.0	5.1
90	5.1	0.5	1.1	850 980	50.1 50.1	2.80	32.7 33.0	116.0 109.9	_	6.9 6.3	90	4.6	0.4	0.9	750 850	25.6 26.4	19.6 21.9	0.69	1.98 2.04	31.2 32.1	12.4	4.4 4.9
				850	50.4	2.70	32.8	116.3	4.38	7.1					750	25.9	19.7	0.76	1.97	31.4	12.5	4.9
	7.5	0.9	2.2	980	50.3	2.74	33.1	110.1	4.54	6.5		6.0	0.7	1.5	850	26.7	22.1	0.74	2.01	32.3	12.6	4.6
	3.7	0.1	0.2									3.2	0.1	0.2	750	24.1	18.5	0.73	2.32	30.9	9.9	6.2
				1											850 750	24.8 24.4	20.4 18.7	0.78	2.38	31.7 31.0	9.9	6.8 5.8
100	5.1	0.4	1.0								100	4.6	0.4	0.8	850	25.1	20.7	0.78	2.35	31.9	10.2	6.4
	7.5	0.9	2.1									6.0	0.6	1.5	750	24.6	18.9	0.73	2.26	31.1	10.4	5.4
	7.0	0.0										0.0			850	25.4	20.9	0.78	2.31	32.1	10.5	6.0
	3.7	0.1	0.2									3.2	0.1	0.2	750 850	22.8 23.5	17.5 19.3	0.77	2.62 2.67	30.7 31.5	8.3	8.4 8.9
110	5.1	0.4	10	1	Oper	ation no	ot recom	mend	pd		110	4.6	0.3	0.8	750	23.1	17.7	0.77	2.60	30.9	8.5	7.9
	J.1	ij. <del>+</del>	1.0		Open	acion n	or recom	iena	cu			7.0	U.J	0.0	850	23.8	19.5	0.82	2.65	31.7	8.6	8.6
	7.5	0.9	2.0									6.0	0.6	1.4	750 850	23.4 24.2	18.0 19.7	0.77	2.56 2.61	31.0 31.9	8.7 8.8	7.3 8.1
	77	0.1	0.2									7.2	01	0.3	750	21.4	17.4	0.81	3.18	31.3	6.4	11.5
	3.7	U.I	0.2									3.2	0.1	0.2	850	21.9	18.9	0.87	3.25	32.0	6.4	12.0
120	5.1	0.4	1.0								120	4.6	0.3	0.8	750	21.7	17.5	0.81	3.01	30.9	6.9	10.4
												-		_	850 750	22.1 21.9	19.0 17.5	0.86	3.08 2.91	31.6 30.8	6.8 7.2	11.1 9.1
	7.5	0.8	1.9									6.0	0.6	1.3	850	22.4	19.0	0.85	3.00	31.5	7.1	10.2

Performance capacities shown in thousands of Btuh.

3/27/2020

Contractor:	P.O.:	_
Engineer:		_
Project Name:	Unit Tag:	

7 Series 7	00R11
033, 042, 050 ton	60Hz
Smarter from the Ground Up	


#### **NVZ050 - 100% Full Load**

		wı	PD		F	HEATIN	G - EAT	70°F				l	w	PD			COOL	ING - E	AT 80/	′67 °F		
EWT	Flow			Airflow	нс	Power	HE	LAT		HWC	EWT	Flow			Airflow	тс	sc	S/T	Power	HR		HWC
°F	gpm	PSI	FT	cfm	MBtuh	kW	MBtuh	°F	СОР	MBtuh	°F	gpm	PSI	FT	cfm	MBtuh	MBtuh	Ratio	kW	MBtuh	EER	MBtuh
	9.0	2.0			Oper	ration n	ot reco	mmen	ded			9.0	0.8	1.9								
20	13.5	4.6		1800	47.3	5.16	29.6	94.3	2.68	5.5	20	11.5	2.0	4.6	1	C	peratio	on not	recomr	nended		
	18.0	7.2	16.7	2200	49.6	5.21	31.8	90.9	2.79	5.0		14.0	3.2	7.3								
	9.0	1.9	4.5	1800 2200	51.5	4.97	34.5	96.5	3.03	5.6		9.0	0.8	1.8	1400	46.9 47.8	29.7 32.5	0.63	1.88	53.4 54.5	25.0 24.4	-
	17.5		10.0	1800	52.7 55.1	5.23	34.8 38.0	92.2 98.3	2.95 3.22	5.0 5.7		11.5	1.0	4.5	1600 1400	47.8	29.9	0.68	1.96 1.79	53.7	26.6	-
30	13.5	4.4	10.2	2200	56.6	5.34	38.4	93.8	3.11	5.2	30	11.5	1.9	4.5	1600	48.4	32.7	0.68	1.88	54.8	25.7	-
	18.0	7.0	16.2	1800 2200	54.5 57.2	5.34	36.3 38.8	98.0 94.1	2.99 3.11	5.9 5.3		14.0	3.1	7.1	1400 1600	47.8 49.0	29.9 32.7	0.63	1.73 1.82	53.7 55.2	27.6 26.9	-
	9.0	1.9	4.3	1800	58.7	5.23	40.8	100.2	3.29	6.0		9.0	0.8	1.8	1400	51.0	33.0	0.65	2.15	58.4	23.8	-
	5.0	1.5	7.5	2200 1800	60.0 62.4	5.44	41.4 44.2	95.2 102.1	3.23	5.6 6.3		J.0	0.0	1.0	1600 1400	52.0 51.6	36.1 33.3	0.69	2.24	59.7 58.6	23.3 25.3	-
40	13.5	4.3	9.9	2200	63.8	5.54	44.2	96.8	3.38	5.8	40	11.5	1.9	4.3	1600	52.6	36.4	0.69	2.04	59.9	24.6	-
	18.0	6.8	15.7	1800	63.3	5.40	44.9	102.6	i	6.5		14.0	3.0	6.9	1400	52.0	33.3	0.64	1.98	58.8	26.3	-
				2200 1800	64.8 65.8	5.59 5.48	45.7 47.1	97.3	3.39	5.9 6.8					1600 1400	53.2 55.2	36.4 36.2	0.68	2.07	60.3 62.9	25.7 24.3	-
	9.0	1.8	4.2	2200	67.2	5.65	47.9	98.3	3.48	6.3		9.0	0.7	1.7	1600	56.3	39.4	0.70	2.41	64.5	23.3	-
50	13.5	4.2	9.6	1800 2200	69.6 71.0	5.59	50.6 51.5	105.8 99.9	3.65	7.0 6.4	50	11.5	1.8	4.2	1400 1600	55.7 56.8	36.5	0.66	2.22	63.3 64.9	25.1 24.1	-
	10.0	<i></i>	15.0	1800	70.8	5.73 5.65	51.5	106.4	3.63	7.2		14.0		67	1400	56.3	39.8 36.9	0.70	2.36 2.18	63.7	25.8	1.7
	18.0	6.6	15.2	2200	72.3	5.79	52.5	100.4		6.6		14.0	2.9	6.7	1600	57.4	40.1	0.70	2.32	65.3	24.7	1.9
	9.0	1.8	4.1	1800 2200	74.2 75.8	5.77 5.87	54.5 55.8	108.2	3.76 3.78	7.6 7.0		9.0	0.7	1.7	1400 1600	52.7 54.0	35.4 38.5	0.67	2.54 2.70	61.3 63.2	20.8	3.0 3.1
60	13.5	4.0	93	1800	77.6	5.87	57.6	109.9	3.87	7.8	60	11.5	1.8	4.1	1400	53.2	35.7	0.67	2.49	61.7	21.4	2.8
	10.0	1.0	0.0	2200 1800	79.3 79.3	5.95 5.94	59.0 59.0	103.4	3.91 3.91	7.2 8.1		11.0			1600 1400	54.6 53.7	38.8 36.1	0.71	2.64	63.6 62.1	20.7	3.0 2.6
	18.0	6.4	14.7	2200	81.1	6.01	60.6	104.1	3.96	7.4		14.0	2.8	6.5	1600	55.1	39.2	0.71	2.60	64.0	21.2	2.8
	9.0	1.7	3.9	1800	82.5	6.06	61.9	112.5	3.99	8.5		9.0	1.6	1.6	1400	50.2	34.6	0.69	2.81	59.8	17.9	3.8
				2200 1800	83.4 85.6	6.10	62.6 64.6	105.1 114.0	4.01	7.9 8.8			_		1600 1400	52.3 50.7	38.2 34.9	0.73	3.08 2.75	62.8 60.1	17.0 18.4	4.0 3.5
70	13.5	3.9	9.0	2200	87.5	6.16	66.5	106.8	4.16	8.1	70	11.5	2.6	3.9	1600	52.3	37.9	0.72	2.93	62.3	17.9	3.8
	18.0	6.2	14.3	1800 2200	87.7 89.8	6.22	66.5 68.6	115.1 107.8	4.13	9.1 8.3		14.0	3.6	6.2	1400 1600	51.2 52.8	35.2 38.3	0.69	2.71 2.88	60.4 62.6	18.9 18.3	3.2
	9.0	1.6	3.8	1800	88.0	6.19	66.9	115.3	4.17	9.6		9.0	0.7	1.6	1400	47.2	33.7	0.71	3.22	58.2	14.7	4.9
	9.0	1.0	3.0	2200 1800	90.0	6.15	69.0 68.7	107.9 116.3	4.29 4.21	8.9		9.0	0.7	1.0	1600 1400	48.9 47.7	36.6 34.0	0.75	3.43 3.16	60.7 58.5	14.3 15.1	5.2 4.5
80	13.5	3.8	8.7	2200	92.2	6.20	71.1	108.8	4.36	9.9 9.1	80	11.5	1.6	3.8	1600	49.4	37.0	0.75	3.36	60.9	14.7	4.8
	18.0	6.0	13.8	1800	92.8	6.34	71.2	117.8	4.29	10.2		14.0	2.6	6.0	1400	48.2	34.4	0.71	3.10	58.7	15.5	4.2
				2200 1800	95.2 93.4	6.27	73.8 71.9	110.0 118.1	4.45	9.4					1600 1400	50.0 44.2	37.4 32.9	0.75	3.31 3.63	61.2 56.6	15.1 12.2	4.6 6.4
	9.0	1.6	3.7	2200	95.7	6.22	74.5	110.3	4.51	9.9		9.0	0.7	1.5	1600	46.2	35.7	0.77	3.87	59.4	11.9	6.7
90	13.5	3.6	8.4	1800 2200	94.7 97.0	6.38	72.9 75.7	118.7 110.8	4.35 4.55	11.1	90	11.5	1.6	3.7	1400 1600	44.7 46.6	33.1 36.1	0.74	3.56 3.79	56.9 59.5	12.6 12.3	5.7 6.2
	10.0	F 7	17 7	1800	97.9	6.46	75.9	120.4	4.44	11.4		140	٦٢	5.8	1400	45.7	34.1	0.75	3.65	58.2	12.5	5.4
	18.0	5.7	13.3	2200	100.5	6.31	79.0	112.3	4.67	10.6		14.0	2.5	5.8	1600	47.1	36.4	0.77	3.73	59.8	12.6	6.5
	9.0	1.5	3.5									9.0	0.6	1.5	1400 1600	41.3 43.3	31.9 34.7	0.77	4.13 4.40	55.4 58.3	10.0 9.8	8.1 8.6
100	13.5	3.5	81								100	11.5	1.5	3.5	1400	41.7	32.2	0.77	4.05	55.5	10.3	7.8
	10.0											11.0			1600 1400	43.7 42.1	35.0 32.6	0.80	4.31 3.97	58.4 55.7	10.1 10.6	8.4 7.4
	18.0	5.5	12.8									14.0	2.4	5.6	1600	44.2	35.4	0.80	4.24	58.6	10.4	8.2
	9.0	1.5	3.4									9.0	0.6	1.4	1400	38.3	30.9	0.81	4.63	54.1	8.3	10.1
110	17 -	7 4	7.0	Operation not recommended					110	11 -			1600 1400	40.4 38.8	33.6 31.2	0.83	4.93 4.53	57.2 54.2	8.2 8.6	10.9 9.7		
110	13.5	3.4	7.8		Oper	ation n	ot reco	ınmen	ued		110	11.5	1.5	3.4	1600	40.8	33.9	0.83	4.83	57.3	8.5	10.5
	18.0	5.3	12.3	3								14.0	2.3	5.4	1400 1600	39.1 41.2	31.6 34.3	0.81	4.45 4.75	54.3 57.4	8.8 8.7	9.3
	9.0	1.4	3 3	3								9.0	0.6	1.3	1400	33.6	30.0	0.90	5.65	52.8	5.9	13.0
	5.0		5.5									J.0		1.5	1600 1400	34.3 34.0	32.8	0.96	5.78 5.34	54.0 52.2	5.9 6.4	13.5 12.2
120	13.5	3.2	2 7.5		120	11.5	1.4	3.3	1600	34.6	30.3 32.9	0.89		53.3	6.3	13.1						
	18.0	5.1	11.8									14.0	2.2	5.2	1400	34.3	30.3	0.88	5.17	51.9	6.6	11.3
		8.0 5.1 11.8								L		1600	35.0	32.9	0.94	5.33	53.2	6.6	12.5			

Performance capacities shown in thousands of Btuh.

3/27/2020


Contractor:	P.O.:
Engineer:	



\_\_ Unit Tag: \_

#### **Aurora Variable Speed Indoor Split**

Project Name:




Contractor:	P.O.:	
Engineer:		
Project Name:	Unit Tag:	







#### **Aurora Variable Speed Indoor Split**









#### Notes


- 4 Variable speed pump low voltage harness provided with Variable Speed Flow Center
- 5 Low voltage wiring CLASS 2. 7 EEV board JUMPER must be removed.
- 10 Communication cable routed through Ferrite Toroid four times.
- 11 Compressor power cable routed through Ferrite Toroid three times.
- 12 Variable speed pump power wires to connect the pump to L1 and L2 on the AXB board are provided with Variable Speed Flow Center.
- 14 Wiring harness supplied with valve.

97P928-01A

ce. Please contact WaterFurnace at 1-888-929-2837 for latest design and formation contained herein are not express warranties and do not form the www.waterfurnace.com.


WaterFurnace works continually to improve its products. As a result, the design and specifications of each product at the time of ord specifications. Purchaser's approval of this data set signifies that the equipment is acceptable under the provisions of the job specifications. Purchaser's approval to the parties, but are merely WaterFurnace's opinion or commendation of its products. The latest version in

Contractor:	P.O.:	
Engineer:		
Project Name:	Unit Tag:	






### **Aurora Variable Speed Indoor Split**



WaterFurnace works continually to improve its products. As a result, the design and specifications of each product at the time of order may be changed without notice. Please contact WaterFurnace at 1-888-929-2837 for latest design and specifications. Purchaser's approval of this data set signifies that the equipment is acceptable under the provisions of the job specification. Statements and other information contained herein are not express warranties and do not form the basis of any bargain between the parties, but are merely WaterFurnace's opinion or commendation of its products. The latest version of this document is available at www.waterfurnace.com.


HOME AUTOMATION ACCESSORIES


Contractor:	P.O.:	_
Engineer:		
Project Name:	Unit Tag:	






#### **Aurora Variable Speed Indoor Split**





10-799-17 038-870

NOTE 10



Aurora LED Flash Codes				
Slow Flash	1 second on and 1 second of	f		
Fast Flash 100 milliseconds on and 100 milliseconds off				
Flash Code	100 milliseconds on and 4	100 milliseconds o	ff with a 2 second pause before repeating	
	Fault LED (LED 1, Red	)	Random Start Delay (Alternat	ing Colors)
Normal Mode	e	OFF	Status LED (LED1, Green)	Fast Flash
Input Fault L	ockout	Flash Code 1	Configuration LED (LED 2, Yellow)	Fast Flash
High Pressu	re Lockout	Flash Code 2	FaultLED (LED 3, Red)	Fast Flash
Low Pressur	re Lockout	Flash Code 3	Configuration LED (LED 2,	Yellow)
Freeze Dete	ction- FP2	Flash Code 4	No Software Overide	OFF
Freeze Dete	ection - FP1	Flash Code 5	DIP Switch Overide	Slow Flash
Reserved		Flash Code 6	Status LED (LED 3, Gre	en)
Condensate	Overflow Lockout	Flash Code 7	Normal Mode	ON
Over/Under	Voltage Shutdown	Flash Code 8	Control is Non - Functional	OFF
Future Use	•	Flash Code 9	Test Mode	Slow Flash
			Lockout Active	Fast Flash
Fault- FP1 a	and FP2 Sensor Error	Flash Code 11	Dehumidification Mode	Flash Code 2
Future Use		Flash Code 12	Future Use	Flash Code 3
Non-Critical	I AXB Sensor Error	Flash Code 13	Future Use	Flash Code 4
Critical AXB	Sensor Error	Flash Code 14	Load Shed	Flash Code 5
Alarm - Hot \	Water	Flash Code 15	ESD	Flash Code
Fault Variable Speed Pump		Flash Code 16	Future Use	Flash Code
Future Use		Flash Code 17	Fault LED (LED 1, Red) (	Cont.
Non-Critical	I Communication Error	Flash Code 18	Safe Mode - Ambient Temp Sensor	Flash Code
Fault - Critic	cal Communication Error	Flash Code 19	Fault - Discharge Temperature Sensor	Flash Code 5
Alarm - Low	Loop Pressure	Flash Code 21	Fault - Suction Pressure Sensor	Flash Code
	unication ECM Fan Motor Error		Fault - Condensing Pressure Sensor	Flash Code 5
Alarm - Hon	ne Automation 1	Flash Code 23	Fault - Low Supply Voltage	Flash Code 5
Alarm - Hon	ne Automation 2	Flash Code 24	Fault - Compressor Out of Envelope	Flash Code
Fault - EEV	Error	Flash Code 25	Fault - Over Current	Flash Code 5
Derate - Dri	ve Temperature	Flash Code 41	Fault - Over/Under Voltage	Flash Code 5
	gh Discharge Temperature	Flash Code 42	Fault - High Drive Temperature	Flash Code
	w Suction Temperature	Flash Code 43	Fault - Drive Internal Error MOC/AOC	Flash Code
	w Condensing Pressure	Flash Code 44	Fault - Multiple Safe Modes	Flash Code 6
	gh Condensing Pressure	Flash Code 45	EEV2 Fault - Loss of Charge	Flash Code
	ter Power Limit	Flash Code 46	EEV2 Safe Mode - Suc Temp Sensor	Flash Code
	EEV (Indoor) Communication		EEV2 Safe Mode - LAT Temp Sensor	Flash Code
	EV (Outdoor) Communication		EEV2 Safe Mode - Max Op Pressure	Flash Code
		. Jan Out 40	EEV1 Fault - Loss of Charge	Flash Code
			EEV1Safe Mode - Suction Temp Sensor	Flash Code 7

POWERTO COMPRESSOR	T3 0 T2 0 T1 0
-----------------------	----------------

AXB Accessory 2 DIP Settings		
SW1-4	SW1-5	DESCRIPTION
ON	ON	Cycles with Blower
OFF	ON	Cycles with CC first stage compressor or compressor spd 1-12
ON	OFF	Cycles with CC2 second stage of compressor or comp spd 7-12
OFF	OFF	Cycles with DH from ABC board

ABC SW2 Accessory Relay		
DESCRIPTION	SW2-4	SW2-5
Cycle with Blower	ON	ON
Cycle with Compressor	OFF	OFF
Water Valve Slow Opening	ON	OFF
Cycle with Comm. T-stat Hum Cmd	OFF	ON

97P928-01B


Contractor:	P.O.:
Engineer:	




\_\_Unit Tag: \_

#### **Aurora Variable Speed Indoor Split with UPC**

Project Name:\_\_\_\_\_




Contractor:	P.O.:	_
Engineer:		
Project Name:	Unit Tag:	







#### **Aurora Variable Speed Indoor Split with UPC**




LED3

Y1 6 CC








#### Notes

- 4 Variable speed pump low voltage harness provided with Variable Speed Flow Center
- 5 Low voltage wiring CLASS 2.
  7 EEV board JUMPER must be removed.
- 10 Communication cable routed through Ferrite Toroid four times.
- 11 Compressor power cable routed through Ferrite Toroid three times.
- 12 Variable speed pump power wires to connect the pump to L1 and L2 on the AXB board are provided with Variable Speed Flow Center.
- 14 Wiring harness supplied with valve.


97P928-02A

Contractor:	P.O.:	
Engineer:		
Project Name:	Unit Tag:	






#### **Aurora Variable Speed Indoor Split**




Contractor:	P.O.:
Engineer:	
Project Name:	Unit Tag:



#### **Aurora Variable Speed Indoor Split**






	<u> </u>	Aurora LE	D Flash Codes					
Slow Flash	1 second on and 1 second off							
Fast Flash	100 milliseconds on and 10	0 milliseconds off						
Flash Code	100 milliseconds on and 400 milliseconds off with a 2 second pause before repeating							
	Fault LED (LED 1, Red	)	Random Start Delay (Alternating Colors					
Normal Mod	e	OFF	Status LED (LED1, Green)	Fast Flash				
Input Fault I	Lockaut	Flash Code 1	Configuration LED (LED 2, Yellow)	Fast Flash				
High Pressu	ure Lockout	Flash Code 2	Fault LED (LED 3, Red)	Fast Flash				
Low Pressu	re Lockout	Flash Code 3	Configuration LED (LED 2	Yellow)				
Freeze Deta	ection- FP2	Flash Code 4	No Software Overide	OFF				
Freeze Det	ection - FP1	Flash Code 5	DIP Switch Overide	Slow Flash				
Reserved		Flash Code 6	Status LED (LED 3, Gro	en)				
Condensat	e Overflow Lockout	Flash Code 7	Normal Mode	ON				
Over/Unde	r Voltage Shutdown	Flash Code 8	Control is Non - Functional	OFF				
Future Use		Flash Code 9	Test Mode	Slow Flash				
			Lockout Active	Fast Flash				
Fault- FP1	and FP2 Sensor Error	Flash Code 11	Dehumi dification Mode	Flash Code 2				
Future Use		Flash Code 12	Future Use	Flash Code 3				
Non-Critica	I AXB Sensor Error	Flash Code 13	Future Use	Flash Code 4				
Critical AXE	3 Sens or Error	Flash Code 14	Load Shed	Flash Code 5				
Alarm - Hot Water		Flash Code 15	ESD	Flash Code 6				
FaultVarial	ble Speed Pump	Flash Code 16	Future Use	Flash Code 7				
Future Use		Flash Code 17	Fault LED (LED 1, Red)	Cont.				
Non-Critica	I Communication Error	Flash Code 18	Safe Mode - Ambient Temp Sensor	Flash Code 4				
Fault - Criti	ical Communication Error	Flash Code 19	Fault - Discharge Temperature Sensor	Flash Code 5				
Alarm - Low	v Loop Pressure	Flash Code 21	Fault - Suction Pressure Sensor	Flash Code 5				
Fault - Comm	unication ECM Fan Motor Error	Flash Code 22	Fault - Condensing Pressure Sensor	Flash Code 5				
Alarm - Hor	me Automation 1	Flash Code 23	Fault - Low Supply Voltage	Flash Code 5				
Alarm - Hor	me Automation 2	Flash Code 24	Fault - Compressor Out of Envelope	Flash Code 5				
Fault - EEV	Error	Flash Code 25	Fault - Over Current	Flash Code 5				
Derate - Dri	ive Temperature	Flash Code 41	Fault - Over/Under Voltage	Flash Code 5				
Derate - Hi	igh Discharge Temperature	Flash Code 42	Fault - High Drive Temperature	Flash Code 5				
Derate - Lo	ow Suction Temperature	Flash Code 43	Fault - Drive Internal Error MOC/AOC	Flash Code 5				
Derate - Lo	w Condensing Pressure	Flash Code 44	Fault - Multiple Safe Modes	Flash Code 6				
Derate - Hi	igh Condensing Pressure	Flash Code 45	EEV2 Fault - Loss of Charge	Flash Code 7				
Derate - Ou	ıter Power Limit	Flash Code 46	EEV2 Safe Mode - Suc Temp Sensor	Flash Code 7				
Safe Mode -	EEV (Indoor) Communication	Flash Code 47	EEV2 Safe Mode - LAT Temp Sensor	Flash Code 7				
Safe Mode - E	EV (Outdoor) Communication	Flash Code 48	EEV2 Safe Mode - Max Op Pressure	Flash Code 7				
			EEV1 Fault - Loss of Charge	Flash Code 7				
			EEV1 Safe Mode - Suction Temp Sensor	Flash Code 7				
			EE V1 Safe Mode - LAT Temp Sensor	Flash Code 7				

	AXB Accessory 2 DIP Settings					
SW1-4	SW1-5	DESCRIPTION				
ON	ON	Cycles with Blower				
OFF	ON	Cycles with CC first stage compressor or compressor spd 1-12				
ON	OFF	Cycles with CC2 second stage of compressor or comp spd 7-12				
OFF	OFF	Cycles with DH from ABC board				

ABC SW2 Accessory Relay						
DESCRIPTION	SW2-4	SW2-5				
Cycle with Blower	ON	ON				
Cycle with Compressor	OFF	OFF				
Water Valve Slow Opening	ON	OFF				
Cycle with Comm. T-stat Hum Cmd	OFF	ON				

97P928-02B


Contractor:	P.O.:
Engineer:	



Project Name: \_\_\_

SVH Air Handler: No Electric Heat

\_\_\_ Unit Tag: \_



Contractor:	P.O.:	
Engineer:		
Project Name:	Unit Tag:	




#### 97P929-01 1/28/2020

7 SeriesAir Handler Air Flow													
Model	Max ESP	Speed 1	Speed 2	Speed 3	Speed 4	Speed 5	Speed 6	Speed 7	Speed 8	Speed 9	Speed 10	Speed 11	Speed 12
033	0.75	250	400 G	550 L	650	750	850	1000	1150	1250 H	1350 Aux	1450	1600
042	0.75	250	450 G	650 L	800	950	1050	1200	1350	1450	1600 H	1750 Aux	1850
050	0.75	300	550 G	800 L	1000	1150	1300	1450	1600	1750	1900 H	2050 Aux	2200
**VS Compressor Speed				1-2	3-4		5-6	7-8		9-10	11-12		

11/29/2018

Factory settings are at recommended G, L, H and Aux positions

CFM is controlled within 5% up to the maximum ESP



- Notes: 1 To operate in 208V mode replace the blue transformer wire connected to PB1-L2 with red transformer wire.
- 2 Low voltage wiring CLASS 2.
- 3 DIP switch 1 on SW1 must be set in the OFF position.
- 4 Jumper must be in place on Air Handler EEV. DO NOT REMOVE.

#### Legend Factory Low voltage wiring Factory Line voltage wiring Light emitting diode - Gr Field low voltage wiring Field line voltage wiring FL Fused Limit Optional block DC Voltage PCB traces Breaker Internal junction Polarized connector 0 Quick connect terminal P Thermal Limit Switch TS PB-Power block Field wire lug L1 SW1 -DIP package 4 position Ground Heater element HE -+N.O., N.C. Current Transducer

<sup>\*\*</sup> VS Compressor speed is given for the factory default cfm settings. When the cfm default settings are changed it will change the relationship to the compressor speed that is shown in the table. In cooling mode compressor speeds 10-12 are only available when SuperBoost mode is selected at the thermostat.

<sup>&</sup>quot;G" may be located anywhere within the airflow table.

<sup>&</sup>quot;L" setting should be located within the boldface CFM range


<sup>&</sup>quot;H" setting MUST be located within the shaded CFM range

<sup>&</sup>quot;Aux" setting MUST be equal to or greater than "H" setting


Contractor:	P.O.:
Engineer:	
Project Name:	Unit Tag:



SVH Air Handler: 10kW Electric Heat



Contractor:	P.O.:
Engineer:	
Droject Name:	Unit Tag:




97P929-02 1/28/2020

7 SeriesAir Handler Air Flow													
Model	Max ESP	Speed 1	Speed 2	Speed 3	Speed 4	Speed 5	Speed 6	Speed 7	Speed 8	Speed 9	Speed 10	Speed 11	Speed 12
033	0.75	250	400 G	550 L	650	750	850	1000	1150	1250 H	1350 Aux	1450	1600
042	0.75	250	450 G	650 L	800	950	1050	1200	1350	1450	1600 H	1750 Aux	1850
050	0.75	300	550 G	800 L	1000	1150	1300	1450	1600	1750	1900 H	2050 Aux	2200
**VS Compressor Speed				1-2	3-4		5-6	7-8		9-10	11-12		

11/29/2018

Factory settings are at recommended G, L, H and Aux positions

CFM is controlled within 5% up to the maximum ESP



#### Notes:

- 1 To operate in 208V mode replace the blue transformer wire connected to PB1-L2 with red transformer wire.
- 2 Low voltage wiring CLASS 2.
- 3 DIP switch 1 on SW1 must be set in the OFF position.
- $4-\mbox{Jumper}$  must be in place on Air Handler EEV. DO NOT REMOVE.

		Legen	<del></del>
		Legen	u
	Factory Low voltage wiring Factory Line voltage wiring		
	Factory Line voltage wiring	\~/	
	Field low voltage wiring	(g)	Light emitting diode - Green
. — — —	Field line voltage wiring	<i>/-</i> \	
	Optional block	FL	Fused Limit
• •	DC Voltage PCB traces Internal junction  Quick connect terminal P	123	Breaker Polarized connector
TS	Thermal Limit Switch		
	Field wire lug	PB -	Power block
L11 ±	Ground	SW1 - HF -	DIP package 4 position Heater element
+1 <del>-3/</del>	N.O., N.C.		Current Transducer

s. As a result, the design and specifications of each product at the time of order may be changed without notice. Please contact WaterFurnace at 1-888-929-2837 for latest design and iffies that the equipment is acceptable under the provisions of the job specification. Statements and other information contained herein are not express warranties and do not form the WaterFurnace's opinion or commendation of its products. The latest version of this document is available at www.waterfurnace.com.

<sup>\*\*</sup> VS Compressor speed is given for the factory default cfm settings. When the cfm default settings are changed it will change the relationship to the compressor speed that is shown in the table. In cooling mode compressor speeds 10-12 are only available when SuperBoost mode is selected at the thermostat.

<sup>&</sup>quot;G" may be located anywhere within the airflow table.

<sup>&</sup>quot;L" setting should be located within the boldface CFM range
"H" setting MUST be located within the shaded CFM range

<sup>&</sup>quot;Aux" setting MUST be equal to or greater than "H" setting

Contractor:_	P.O.:	_
Engineer:		_


Project Name: \_\_\_\_\_Unit Tag: \_





### **Air Handler Wiring Schematics cont.**

SVH Air Handler: 15kW Electric Heat



Contractor:	P.O.:	
Engineer:		
Project Name:	Unit Tag:	




97P929-03 1/28/2020

					7 SeriesA	ir Handler Ai	r Flow						
Model	Max ESP	Speed 1	Speed 2	Speed 3	Speed 4	Speed 5	Speed 6	Speed 7	Speed 8	Speed 9	Speed 10	Speed 11	Speed 12
033	0.75	250	400 G	550 L	650	750	850	1000	1150	1250 H	1350 Aux	1450	1600
042	0.75	250	450 G	650 L	800	950	1050	1200	1350	1450	1600 H	1750 Aux	1850
050	0.75	300	550 G	800 L	1000	1150	1300	1450	1600	1750	1900 H	2050 Aux	2200
**VS Compressor Speed				1-2	3-4		5-6	7-8		9-10	11-12		

11/29/2018

Factory settings are at recommended G, L , H and Aux positions

CFM is controlled within 5% up to the maximum ESP



		Legen	d
• • • • • • • • • • • • • • • • • • •	Factory Low voltage wiring Factory Line voltage wiring Field low voltage wiring Optional block DC Voltage PCB traces Internal junction Quick connect terminal P Thermal Limit Switch Field wire lug Ground N.O., N.C.	FL 123 PB- SW1- HE-	Light emitting diode - Green Fused Limit  Breaker Polarized connector Power block DIP package 4 position Heater element Current Transducer

nect to the COMM STAT (C R + -) conductor, 20 AWG wire will need

- 1 To operate in 208V mode replace the blue transformer
- wire connected to PB1-L2 with red transformer wire.

  2 Use manufacturer's part number 19P592-01 (jumper bar assembly) when single source power is required.
- 3 DIP switch 1 on SW1 must be set in the OFF position.
- 4 Jumper must be in place on Air Handler EEV. DO NOT REMOVE.
- 5 Low voltage wiring CLASS 2.

#### **Dual Power Supply Connections**

If two separate circuits are used to supply power to the auxiliary heat kit, the Installer will need to verify that each leg of the auxiliary heat circuit breakers are wired from the power supply correctly in order for the electric heat kit to operate properly. This can be done by measuring the supply side voltage of the auxiliary heat circuit breakers. Put a voltmeter on the L2 side of Circuit Breaker One and on the L2 side of Circuit Breaker Two. The voltmeter should read approximately 0 volts. If the meter reads high voltage, the auxiliary heat breakers need to be rewired so that breakers in the auxiliary heat kit match the wiring of the Disconnect Panel breakers. Meaning, L1 and L2 from one breaker in the disconnect panel must connect to L1 and L2 at one of the auxiliary heat circuit breakers and L1 and L2 from the other breaker in the disconnect panel must connect to L1 and L2 of the other auxiliary heat circuit breaker, making sure that the L1 and L2 from each disconnect breaker matches the L1 and L2 at each of the auxiliary heat breakers.

oducts. As a result, the design and specifications of each product at the time of order may be changed without notice. Please contact WaterFurnace at 1-888-929-2837 for latest design and et signifies that the equipment is acceptable under the provisions of the job specification. Statements and other information contained herein are not express warranties and do not form the nerely WaterFurnace's opinion or commendation of its products. The latest version of this document is available at www.waterfurnace.com.

<sup>\*\*</sup> VS Compressor speed is given for the factory default cfm settings. When the cfm default settings are changed it will change the relationship to the compressor speed that is shown in the table. In cooling mode compressor speeds 10-12 are only available when SuperBoost mode is selected at the thermostat.


<sup>&</sup>quot;G" may be located anywhere within the airflow table.

<sup>&</sup>quot;L" setting should be located within the boldface CFM range

<sup>&</sup>quot;H" setting MUST be located within the shaded CFM range


<sup>&</sup>quot;Aux" setting MUST be equal to or greater than "H" setting

Contractor:	P.O.:	_
Engineer:		_
Project Name:	Unit Tag:	






SVH Air Handler: 20kW Electric Heat



Contractor:	P.O.:	
Engineer:		
Project Name:	Unit Tag:	



97P929-04 1/28/2020


7 SeriesAir Handler Air Flow													
Model	Max ESP	Speed 1	Speed 2	Speed 3	Speed 4	Speed 5	Speed 6	Speed 7	Speed 8	Speed 9	Speed 10	Speed 11	Speed 12
033	0.75	250	400 G	550 L	650	750	850	1000	1150	1250 H	1350 Aux	1450	1600
042	0.75	250	450 G	650 L	800	950	1050	1200	1350	1450	1600 H	1750 Aux	1850
050	0.75	300	550 G	800 L	1000	1150	1300	1450	1600	1750	1900 H	2050 Aux	2200
**VS Compressor Speed				1-2	3-4		5-6	7-8		9-10	11-12		

\*\* VS Compressor speed is given for the factory default cfm settings. When the cfm default settings are changed it will change the relationship to the compressor speed that is shown in the table. In cooling mode compressor speeds 10-12 are only available when SuperBoost mode is selected at the thermostat.

Factory settings are at recommended G, L, H and Aux positions

- "G" may be located anywhere within the airflow table.
- "L" setting should be located within the boldface CFM range
- "H" setting MUST be located within the shaded CFM range
- "Aux" setting MUST be equal to or greater than "H" setting

CFM is controlled within 5% up to the maximum ESP



#### Notes:


- To operate in 208V mode replace the blue transformer wire connected to PB1-L2 with red transformer wire.
- Use manufacturer's part number 19P592-01
   (jumper bar assembly) when single source power is required.
- $3-\mbox{DIP}$  switch 1 on SW1 must be set in the OFF position.
- 4 Jumper must be in place on Air Handler EEV. DO NOT REMOVE.
- 5 Low voltage wiring CLASS 2.

#### **Dual Power Supply Connections**

If two separate circuits are used to supply power to the auxiliary heat kit, the Installer will need to verify that each leg of the auxiliary heat circuit breakers are wired from the power supply correctly in order for the electric heat kit to operate properly. This can be done by measuring the supply side voltage of the auxiliary heat circuit breakers. Put a voltmeter on the L2 side of Circuit Breaker One and on the L2 side of Circuit Breaker Two. The voltmeter should read approximately 0 volts. If the meter reads high voltage, the auxiliary heat breakers need to be rewired so that breakers in the auxiliary heat kit match the wiring of the Disconnect Panel breakers. Meaning, L1 and L2 from one breaker in the disconnect panel must connect to L1 and L2 at one of the auxiliary heat circuit breakers and L1 and L2 from the other breaker in the disconnect panel must connect to L1 and L2 of the other auxiliary heat circuit breaker, making sure that the L1 and L2 from each disconnect breaker matches the L1 and L2 at each of the auxiliary heat breakers.


	L	egen	d
	Factory Low voltage wiring		
	Factory Line voltage wiring Field low voltage wiring	Q	Light emitting diode - Green
	Field line voltage wiring	FL	Fused Limit
	Optional block DC Voltage PCB traces	4	D 1
•	Internal junction —		Breaker
0	Quick connect terminal P	2 3	Polarized connector
TS	Thermal Limit Switch Field wire lug	В-	Power block
<u>_</u> <u>↓</u>	Ground	W1 - IE -	DIP package 4 position Heater element
11 <del>-1/</del>	N.O., N.C.		Current Transducer

Contractor:	P.O.:	_
Engineer:		_
Project Name:	Unit Tag:	





#### **Aurora UPC**



Contractor:	P.O.:	
Engineer:		
Project Name <sup>.</sup>	Unit Tag	



### **Engineering Guide Specifications**

#### General

Furnish and install WaterFurnace Water Source Heat Pumps, as indicated on the plans. Equipment shall be completely assembled, piped and internally wired. Capacities and characteristics as listed in the schedule and the specifications that follow. The reverse cycle heating/cooling units shall be either suspended type with horizontal air inlet and discharge or floor mounted type with horizontal air inlet and vertical upflow, or downflow air discharge. Units shall be AHRI/ISO 13256-1 certified and listed by a nationally recognized safety-testing laboratory or agency, such as ETL Testing Laboratory. Each unit shall be computer runtested at the factory with conditioned water and operation verified to catalog data. Each unit shall be mounted on a pallet and shipped in a corrugated box or stretch-wrapped. The units shall be designed to operate with entering liquid temperature between 20°F and 120°F [-6.7°C and 48.9°C].

#### **Casing and Cabinet**

The cabinet shall be fabricated from heavy-gauge galvanized steel and finished with corrosion-resistant powder coating. This corrosion protection system shall meet the stringent 1000 hour salt spray test per ASTM B117. The interior shall be insulated with 1/2-inch thick, multi-density, cleanable aluminum foil coated glass fiber with edges sealed or tucked under flanges to prevent the introduction of glass fibers into the discharge air. Standard cabinet panel insulation must meet NFPA 90A requirements, air erosion and mold growth limits of UL- 181, stringent fungal resistance test per ASTM-C1071 and ASTM G21, and shall meet zero level bacteria growth per ASTM G22. Unit insulation must meet these stringent requirements or unit(s) will not be accepted.

Three compressor compartment access panels shall be 'liftout' removable. The front access panel shall be lift-out to provide easy access to the electrical/compressor section. The control box shall be hinged and removable to allow easy access to the compressor. The internal component layout shall provide for service access from the front side for restricted installations.

The air handler shall be provided with two large access panels and shall be removable with supply and return ductwork in place. The internal components layout shall provide for major service with the unit in-place for restricted access installations. The blower assembly access shall be slide-out serviceable via a 'works-in-a-drawer' design. The cabinet shall be convertible to horizontal or downflow applications by reconfiguring the cabinet using only a nut driver. The unit shall be 'zero clearance' approved on any of its external surfaces. A duct collar shall be provided for field installation on the supply air opening. The air handler shall be supplied with an integral return air filter rack (air filter is field supplied).

#### **Refrigerant Circuit**

All units shall contain a sealed refrigerant circuit including a hermetic motor-compressor, oil seperator, electronic expansion valve, reversing valve, coaxial tube water-to-refrigerant heat exchanger, optional hot water generator

coil, and service ports. Compressors shall be high-efficiency variable speed scroll type designed for heat pump duty and mounted on double vibration isolators. Compressor motors shall be permanent magnet type. All air handlers shall provide an electronic expansion valve, enhanced fin and tube air-to-refrigerant heat exchanger of the "A" coil design. The finned tube coil shall be sized for low-face velocity and constructed of lanced aluminum fins bonded to aluminum tubes in a staggered pattern. The coil shall include a composite drain pan.

Both electronic expansion valves shall provide proper superheat over the entire liquid temperature range with minimal "hunting."

Refrigerant to air heat exchangers shall utilize aluminum tube construction rated to withstand 600 psig (4135 kPa) refrigerant working pressure. Refrigerant to water heat exchangers shall be of copper (cupronickel optional) inner water tube and steel refrigerant outer tube design, rated to withstand 600 psig (4135 kPa) working refrigerant pressure and 450 psig (3101 kPa) working water pressure.

All units shall have the source coaxial tube refrigerant-to water heat exchanger and the optional hot water generator coil coated with ThermaShield insulation. Refrigerant suction lines shall be insulated to prevent condensation at low liquid temperatures.


#### **Blower Motor and Assembly**

The blower shall be an oversized direct drive centrifugal type with a dynamically balanced wheel. The housing and wheel shall be designed for quiet low outlet velocity operation and of galvanized or galvalume steel construction. Tight blower housing geometry shall not be permitted. The blower housing shall be removable from the cabinet without disconnecting the supply air ductwork for servicing of the blower motor through a 'works-in-a-drawer' design. The high efficiency blower motor shall be a variable speed ECM type. The blower motor shall be isolated from the housing by rubber grommets. The motor shall be permanently lubricated ball bearings and have thermal overload protection.

#### **Electrical**

A control box shall be located within the compressor and air handler compartments (air handler shall contain a 100VA transformer) and the compressor compartment shall contain a 24 Volt activated, 2 pole compressor contactor, circuit breakers for protecting loop pumps and compressor drive, removable terminal block for thermostat wiring, variable speed compressor drive and solid-state controller for complete unit operation. Electromechanical operation WILL NOT be accepted. Units shall be name-plated for use with time delay fuses or HACR circuit breakers. Unit controls shall be communicating type and provide heating or cooling as required by the remote thermostat/sensor. An Aurora Advanced VS Control, a microprocessor based controller, interfaces with a digital communicating thermostat to monitor and control unit operation shall be provided. The control shall provide operational sequencing, blower speed

Contractor:	P.O.:
Engineer:	
Project Name:	Unit Tag



### **Engineering Guide Specifications cont.**

control, blower failure, high and low pressure switch monitoring, freeze detection, hot water limit thermistor sensing, condensate overflow sensing, auxiliary heat staging, lockout mode control, hot water and loop pump control, LED status and fault indicators, fault memory, field selectable options, compressor envelope management, energy consumption measurement, and accessory output. The fault signals shall be plain English text and displayed on the thermostat. The Aurora Advanced VS Control shall also feature an On Peak input signal for utility controlled demand programs, intelligent hot water generation with user adjustable temperature limit, loop pump linking for multiple units driving a common flow center and up to two optional home automation inputs to drive dedicated alarms for sump pump, security system, and smoke/CO2 or dirty air filter sensors. As standard, the energy, performance and refrigerant monitoring kits will provide real time data including total power consumption, entering and leaving water temperature, flow rate and heat of extraction/rejection capacity data, refrigerant superheat and subcooling. The capability for communicating to advanced zoning packages with up to six zones shall also be provided with complete fault and information display on the zoning MasterStat.

A detachable terminal block with screw terminals will be provided for field control wiring. All units shall have knockouts for entrance of low and line voltage wiring. The blower motor and control box shall be harness plug wired for easy removal.

The air handler shall contain integral circuit breakers on all units employing 15 kW or 20 kW electric heat. The 100VA transformer shall be protected by internal circuit breaker.

An Aurora Interface Diagnostic (AID) Tool shall communicate with the Aurora control allowing quick and easy access to setup, monitoring, and troubleshooting of any Aurora control. The device shall include the features of ECM airflow setup, VS pump and modulating water valve setup, fault description and history, manual operation capability, sensor readings, timings, and other diagnostic tools.

Option: An Aurora Unitary Protocol Converter (UPC) shall be included that communicates directly with the Aurora Heat Pump Control and allows access/control of a variety of internal Aurora heat pump operations such as sensors, relay operation, faults and other information. In turn, the UPC shall convert the internal Aurora Modbus protocol to BACnet MS/TP protocol for communication over a HAS system. Additional individual unit configuration items such as ECM fan speeds or freeze detection settings shall be directly available over the HAS without the need for access to the actual heat pump.

#### **Piping**

Supply and return water connections shall be 1 in. [25.4 mm] FPT brass swivel fittings, which provide a union and eliminate the need for pipe wrenches and sealants when making field connections. The optional hot water generator shall have sweat type connections. All source water piping shall be insulated to prevent condensation at low liquid temperatures. Refrigeration connections shall be made using sweat copper joints. The air handler condensate connections shall be a 3/4 in. NPT.

# Options and Accessories Cupronickel Heat Exchanger

An optional cupronickel water-to-refrigerant heat exchanger shall be provided.

#### **Hot Water Generator**

An optional ThermaShield coated heat reclaiming hot water generator coil of vented double-wall copper construction suitable for potable water shall be provided. The coil and hot water circulating pump shall be factory mounted inside the unit with integral electronic high limit temperature monitoring and external on/off switch. Hot water set point is selectable through the AID Tool.

#### Thermostat (field-installed)

A communicating auto-changeover electronic digital thermostat shall be provided. The thermostat shall offer variable speed heating and cooling staging with precise temperature control. An OFF-HEAT-AUTO-COOL-EMERG system switch, OFF-AUTO-INTERMITTENT blower switch, and indicating display shall be provided. The thermostat shall display in °F or °C. The thermostat shall provide real time energy consumption data of the unit.

#### **Color Touchscreen Thermostat (field-installed)**

A color touchscreen communicating auto-changeover electronic digital thermostat shall be provided. The thermostat shall offer variable speed heating and cooling staging with precise temperature control. An OFF-HEAT-AUTO-COOL-EMERG system switch, OFF-AUTO-INTERMITTENT blower switch, and indicating display shall be provided. The thermostat shall display in °F or °C. The thermostat shall provide real time and historical energy consumption data of the unit.

#### Earth Loop Flow Center (field-installed)

A self-contained module shall provide all liquid flow, fill and connection requirements for ground source closed loop systems up to 20 gpm. The pumps shall be wired to a power block located in the nearest unit. The heat pump units shall contain low voltage pump linking control so that two units may share one flow center.

Contractor:	P.O.:	
Engineer:		
Project Name:	Unit Tag:	

7 Series 700R11
033, 042, 050 ton 60Hz
Smarter from the Ground Up

### **Revision Guide**

Pages:	Description:	Date:	Ву:
All	Document created	26 Feb 2020	MA