SAMSUNG

SUBMITTAL AM036TXMDCH/AA

Page 1 of 2

Samsung DVM S Eco Series, Heat Pump Condensing Unit

Job Name	Location			
Purchaser	Engineer	Engineer		
Submitted to	Reference	Approval	Construction	
Unit Designation	Schedule #			

Unit Design	ation				
		System Specifications			
	US Ton (nominal)	Oydidiii Opddiiidalidiid	3.0		
Performance ¹	Capacity (Btu/h)	Nominal Cooling	38,000		
		Nominal Heating	42,000		
	System Modulation down to (Btu/h)		7,500		
	SEER2	Ducted / Non-Ducted	16.5 / 22.0		
	EER2	Ducted / Non-Ducted	11.2 / 12.5		
	HSPF2	Ducted / Non-Ducted	8.2 / 10.0		
	Voltage	(ø/V/Hz)	1 / 208-230 / 60		
Power	Maximum Circuit Breaker (MCCB/ELB/ELCB)		40		
	Minimum Circuit Ampacity (MCA)		23		
Indoor Units	Total Capacity (%)		50 - 130% Of Outdoor Capacity		
	Maximum Indoor Unit Quantity		8		
Compressor	Туре		Twin BLDC Rotary X1		
	RLA	A	17.3		
	Туре		R410A		
Refrigerant	Factory Charge	lbs.	7.1		
Pipe Connections	Liquid X Suction		3/8 X 5/8		
Connections	Max. Distance - ODU to IDU (feet)		492 (574 equivalent)		
Installation	Vertical Separation ODU to IDU ³		164 / 131		
Limitation ²	(feet)	Highest/Lowest IDU	49		
	Total Refrigerant Pipe (feet)		984		
	Fan	Туре	Propeller X 2		
0		Output (CFM)	3,885		
Condenser Fan	Motor	Туре	BLDC		
		Output (W) / FLA (A)	125 X 2 / 0.6		
Dimensions	WXHXD	Inches	37 X 47 5/8 X 13		
	Weight	lbs.	216.1		
Sound Level	Max. dB (A)	Cooling / Heating	50 / 52		
Operating Temperature Range	Cooling ⁴	°F	0°F ~ 118°F (-18°C ~ 48°C)		
	Heating	°F	-13°F ~ 75°F (-25°C ~ 24°C)		
Accessories	W. 15 W	Front	WBF-1M2		
	Wind Baffles	Back	WBB-2M-B		
	Wi-Fi Adapter		MIM-H04UN		
	Mode Selector Switch For HP Systems		MCM-C200U		
	Base Pan Heater Kit		MHC-015EE		
	External contact control interface module (operation and error output, night silent mode manual activation)		MIM-B14		
Safety Certificati	ons	ETL (UL 1995)			
	within unit design limitations and				
Protection Devices	High pressure sensor, low pressure sensor, over-voltage protection,				

¹ Certified in accordance with AHRI 210/240 (2023). Et	Effective January 1st, 2023.
---	------------------------------

² Other pipe restrictions and requirements exist. Please consult installation manuals or technical data book for full details.

protection, fan motor thermal protection, high voltage fuses

compressor over-current protection, current transformer, fan motor voltage

Proper sizing and installation of equipment is critical to achieve optimal performance. Split system air conditioners and heat pumps (excluding ductless systems) must be matched with appropriate coil components to meet ENERGY STAR criteria. Ask your contractor for details or visit www.energystar.gov.



Compatibility

Only compatible with Samsung DVM S indoor units (AM****N***H***) and MCM-D211UN Universal Communication Kit.

Construction

The unit shall be galvanized steel with a baked on powder coated finish

Refrigerant pipe connections inside unit chassis with penetrations available on front, back, right, and bottom sides for versatile installation

Heat Exchanger

The heat exchanger shall be mechanically bonded fin to copper tube.

Salt spray test method: ASTM-B117-18 - the heat exchanger showed no unusual rust or corrosion development to 2,280 hours.

Controls

The unit shall be operated via NASA Protocol with controls provided by Samsung

Control wiring shall be 16 AWG X 2 shielded wire.

Refrigerant System

The compressors shall be Samsung hermetically sealed, inverter driven, twin BLDC Rotary type.

Refrigerant flow shall be controlled by EEV (electronic expansion valve) throughout the system.

A flat plate subcooler device will improve capacity at extreme system refrigerant pipe lengths and reduce refrigerant noise.

Other Features

Optional night quiet modes to reduce outdoor unit sound

Optional snow blowing logic to prevent snow drifting on idle outdoor units








³ Vertical separation: 131' when outdoor unit is lower than the indoor units, 164' when the outdoor unit is higher than the indoor units.

⁴ When cooling in outside temperatures between 0°F ~ 23°F, wind baffles are required. When outside temperature is between $0^{\circ}F \sim 23^{\circ}F$, minimum 50% operating capacity should be maintained to ensure reliability while in cooling mode.



- (3) Condensate drain holes
- (1) Gas refrigerant pipe opening 2 Liquid refrigerant pipe opening
- (4) Communication conduit opening (2 X Ø1 3/8")