

7 August 2018

2/7 Millner Ave
Horsley Park NSW 2175

Tridonic Australia Pty Ltd.

Dear Sir / Madam,

APPROVAL OF PRESCRIBED EQUIPMENT

Enclosed is the Certificate(s) in respect to your recent application received by Energy Safe Victoria.


Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the approval.

Should you have any queries, please contact Jean Marie Ntahnkiriye on telephone (03) 9203 9700, or email jntahnkiriye@esv.vic.gov.au

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Energy Safe Victoria of any change of registered Address within 20 business days.

Yours sincerely



DIRECTOR OF ENERGY SAFETY

Ref: ESV180387/00

Certificate Number: ESV180387/00

Certificate of Approval

This is to certify that the Director of Energy Safety has approved the electrical equipment described hereunder.

Registered Declarant: Tridonic Australia Pty Ltd.
2/7 Millner Ave
Horsley Park NSW 2175

Required Marking: **ESV180387**


Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, must be clearly and indelibly marked with the required marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Energy Safe Victoria prior to the equipment being supplied or offered for supply.

Notification must be given to Energy Safe Victoria of any change to the name or address of the holder of the certificate within 20 business days.

ARTICLE DETAILS

Electrical Equipment:	Level 3 Power Supply or Charger Dimming constant current 2 channel LED driver:- independent type
Relevant Standards:	AS/NZS IEC 61347.2.13:2013 & AS/NZS 61347.1:2016
Expiry Date:	07 August 2023
Conditions of Approval:	



Certificate Number: ESV180387/00

Approval details

Model	LCA 38W 350-1050mA 2xCH SR PRE
Rated at	Input: 220-240 V, 26.4 A, 50/60 Hz Output: 60 Vdc, 38 W, 350-1050 mA
Trade Name	TRIDONIC
Comments	

Model	LCA 38W 350-1050mA DT8 SR PRE
Rated at	Input: 220-240 V, 26.4 A, 50/60 Hz Output: 60 Vdc, 38 W, 350-1050 mA
Trade Name	TRIDONIC
Comments	

