

Job Name _____
 Purchaser _____
 Submitted to _____
 Unit Designation _____

Location _____
 Engineer _____
 Reference _____ Approval _____ Construction _____
 Schedule # _____

Specifications

Model	US Code		RNS24CMB
	Model Number		AR24BSFCMWKNCV
Performance	Nominal Capacity	Cooling (Btu/h)	22,000
		Heating (Btu/h)	24,000
Power	Voltage	Ø / V / Hz	1 / 208-230 / 60
	Operating Current (Max.)	Cooling (A)	0.5
		Heating (A)	0.5
Evaporator Fan	Type	BLDC motor with cross-flow fan	
	Consumption	Watts	27 X 1
	FLA	Amps	0.12
Airflow	Air Volume (L/M/H/Turbo)	Cooling (CFM)	465 / 525 / 584 / 623
		Heating (CFM)	470 / 529 / 589 / 629
Refrigerant	Type	R410A	
	Control Method	Electronic Expansion Valve (at outdoor unit)	
Pipe Connections	Indoor & Outdoor	High side (flare)	1/4"
		Low side (flare)	5/8"
Dimensions	W X H X D	in.	41 1/2 X 11 3/4 X 8 7/16
	Weight	lbs.	25.4
	Condensate Connection		11/16" OD
Sound Pressure Level	Low / High	dB(A)	28 / 45
Accessories	Wired Controllers ¹	Advanced	MWR-WG00UN
		Simple Touch	MWR-SH11UN
	Wired Controller Sub-PCB		MIM-A00UN
	24VAC Thermostat Adapter ¹		MIM-A60UN
	Condensate Pump	Aspen Mini Orange	ASP-MO-UNIV 110-250
		Blue Diamond	BD-BLUE-230
	External Temperature Sensor		MRW-TA
	External Contact Control Interface Module ²		MIM-B14
Line sets - insulated and flared, interconnect cables included		25' - ILS2509	
		50' - ILS5009	
Safety Certifications			ETL (UL 1995)



General Information

- The indoor unit shall feature WindFree™ mode. In cooling mode, as room temperature nears set temperature, the unit will close its louver and will disperse air into the space through thousands of micro-holes on the front of the indoor unit preventing cold air drafts on occupants.
- The indoor unit shall have Wi-Fi capability as standard
- The indoor unit shall be powered by the outdoor unit

Construction

- Indoor unit chassis shall be UL94 V0 with a galvanized steel mounting bracket
- The indoor unit shall have easy-access to wire, pipe, and drain connections via access panel on the bottom of the unit for simple installation and service

Heat Exchanger

- The heat exchangers shall be mechanically bonded fin to copper tube

Indoor Fan

- The indoor fan shall be a single, antibacterial cross-flow type
- Three fan speed settings and auto setting
- Automatic (motorized) vertical swing (up/down) and horizontal swing (left/right) louvers

Controls

- The system shall have a built in Wi-Fi adapter as standard to allow control and monitoring using the Samsung SmartThings app (Android, iOS)
- Dual set temperature support when connected to MWR-WG00UN Advanced Wired Controller and supported central control options.
- The indoor unit shall have a simple connection for overflow detection devices or any other normally closed contact for simple unit shutdown
- The indoor unit shall ship with a wireless controller, holder, and batteries
- Wired controller options available
- Interconnect control wire between outdoor and indoor unit shall be 16AWG X 2

Convenience

- System energy consumption can be viewed using the Samsung SmartThings mobile app (not revenue grade, for reference only)
- Auto Clean Function
- 7-segment digital display on front of unit to display temperature and unit status
- Auto changeover
- Good sleep mode
- Quiet mode
- Dry mode
- Simple ON/OFF time function – Using the wireless controller specify the ON and/or OFF times
- Electro-static, washable, main filter as standard accessible from the top of unit
- Filter cleaning reminder

Compatibility

Will only operate with Samsung outdoor unit model numbers:
 AR24BSFCMWKNCV (RXS24CMB), AJ036BXJ4CH/AA (JXH36J4B), AJ048BXJ5CH/AA (JXH48J5B), AJ030BXS4CH/AA (JXH30S4B), AJ036BXS4CH/AA (JXH36S4B), AJ036TXJ4CH/AA (JXH36J4T), AJ048TXJ5CH/AA (JXH48J5T), AJ030TXS4CH/AA (JXH30S4T), AJ036TXS4CH/AA (JXH36S4T)

^{*}The WindFree™ unit delivers an air current that is under 0.15 m/s while in WindFree™ mode. Air velocity that is below 0.15 m/s is considered "still air" as defined by ASHRAE (American Society of Heating, Refrigerating, and Air-Conditioning Engineers).

¹ Sub-PCB model MIM-A00UN is required when connecting optional wired controllers or MIM-A60UN 24VAC thermostat adapter.

² When applying MIM-B14 external contact control interface module, MIM-A00UN wired controller sub-PCB is required.

Samsung HVAC maintains a policy of ongoing development, specifications are subject to change without notice. Refer to www.AHRIdirectory.org for current reference numbers.



Unit: inches

