

# SIEMENS

**SIMATIC S7-1500  
TIM 1531 IRC V2.0  
Protocol IEC 60870-5-101**

**Interoperability list  
V1.2**



## 1 VERSION HISTORY

Version	Date	Author	Review	Remarks
1.0	08.02.2018	Joerg Hahn		First draft
1.1	08.22.2018	Joerg Hahn		Release before conformance test
1.2	11.05.2018	Joerg Hahn		Release after conformance test

## 2 SCOPE OF THIS DOCUMENT

The scope of this document is to describe in a detailed way the implementation of the IEC 60870-5 communication interface as indicated in the first page. It contains a default template as in IEC 60870-5-101Ed.2 that shows the minimum information to describe 101 function, which is integrated in a customized way by additional sections, notes, figures and data that the manufacturer wants to show to whoever it may concern.

## 3 OBJECTIVE OF THIS DOCUMENT

The objective is:

For a Manufacturer PID: to provide utilities, system integrators, and whoever is interested in using/purchasing this implementation, the necessary information to evaluate quality, features, and interoperability risks when the product is integrated in a given multi-vendor network or substation.

For an Utility PID: provide manufacturers which are the minimum requirements for their devices to be integrated into the utility network and guarantee interoperability in a multi-vendor network (this latter still to be verified by dedicated interoperability testing). This document can be used as a technical specification during a tender process.

## 4 PROTOCOL IMPLEMENTATION CONFORMANCE STATEMENT (PICS)

### IMPORTANT

The Protocol Implementation Conformance Statement (PICS) in this paragraph is the basis for the applicable test cases in Chapter 5. This PICS gives an overview of the tested protocol implementation, but this isn't a guarantee that the complete function or ASDU, as enabled in the PICS, is tested and supported. Partial testing is possible and the completeness of the tests for the specific function or ASDU should be consulted in Chapter 5.

The selected parameters should be marked in the white boxes as follows:

- Function or ASDU is not used
- Function or ASDU is used as standardized (default)
- Function or ASDU is used in reverse mode
- Function or ASDU is used in standard and reverse mode

The possible selection (blank, X, R, or B) is specified for each specific clause or parameter.

NOTE: In addition, the full specification of a system may require individual selection of certain parameters for certain parts of the system, such as the individual selection of scaling factors for individually addressable measured values.

### 4.1 System or device

(System-specific parameter, indicate the definition of a system or a device by marking one of the following with 'X').

---

- System definition
- Controlling station definition
- Controlled station definition

## 4.2 Network configuration

(Network-specific parameter, all configurations that are used are to be marked 'X').

- Point-to-point
- Multipoint-partyline
- Multiple point-to-point
- Multipoint-star

## 4.3 Physical layer

(Network-specific parameter, all interfaces and data rates that are used are to be marked 'X').

### Transmission speed (control direction)

Unbalanced interchange Circuit V.24/V.28 Standard	Unbalanced interchange Circuit V.24/V.28 Recommended if >1 200bit/s	Balanced interchange Circuit X.24/X.27	
<input type="checkbox"/> 100 bit/s	<input checked="" type="checkbox"/> 2 400 bit/s	<input type="checkbox"/> 2 400 bit/s	<input type="checkbox"/> 56 000 bit/s
<input type="checkbox"/> 200 bit/s	<input checked="" type="checkbox"/> 4 800 bit/s	<input type="checkbox"/> 4 800 bit/s	<input type="checkbox"/> 56 000 bit/s
<input type="checkbox"/> 300 bit/s	<input checked="" type="checkbox"/> 9 600 bit/s	<input type="checkbox"/> 9 600 bit/s	<input type="checkbox"/> 64 000 bit/s
<input type="checkbox"/> 600 bit/s	<input checked="" type="checkbox"/> 19 200 bit/s	<input type="checkbox"/> 19 200 bit/s	
<input checked="" type="checkbox"/> 1 200 bit/s	<input checked="" type="checkbox"/> 38 400 bit/s	<input type="checkbox"/> 38 400 bit/s	
<input type="checkbox"/>	<input checked="" type="checkbox"/> 115 200 bit/s	<input type="checkbox"/>	

### Transmission speed (monitor direction)

Unbalanced interchange Circuit V.24/V.28 Standard	Unbalanced interchange Circuit V.24/V.28 Recommended if >1 200bit/s	Balanced interchange Circuit X.24/X.27	
<input type="checkbox"/> 100 bit/s	<input checked="" type="checkbox"/> 2 400 bit/s	<input type="checkbox"/> 2 400 bit/s	<input type="checkbox"/> 56 000 bit/s
<input type="checkbox"/> 200 bit/s	<input checked="" type="checkbox"/> 4 800 bit/s	<input type="checkbox"/> 4 800 bit/s	<input type="checkbox"/> 56 000 bit/s
<input type="checkbox"/> 300 bit/s	<input checked="" type="checkbox"/> 9 600 bit/s	<input type="checkbox"/> 9 600 bit/s	<input type="checkbox"/> 64 000 bit/s
<input type="checkbox"/> 600 bit/s	<input checked="" type="checkbox"/> 19 200 bit/s	<input type="checkbox"/> 19 200 bit/s	
<input checked="" type="checkbox"/> 1 200 bit/s	<input checked="" type="checkbox"/> 38 400 bit/s	<input type="checkbox"/> 38 400 bit/s	
<input type="checkbox"/>	<input checked="" type="checkbox"/> 115 200 bit/s	<input type="checkbox"/>	

## 4.4 Link layer

(Network-specific parameter, all options that are used are to be marked 'X'. Specify the maximum frame length. If a non-standard assignment of class 2 messages is implemented for unbalanced transmission, indicate the type ID and COT of all messages assigned to class 2.)

Frame format FT 1.2, single character 1 and the fixed time out interval are used exclusively in this companion standard.

### Link transmission

- Balanced transmission  
 Unbalanced transmission

### Address field of the link

- not present (balanced transmission only)  
 One octet  
 Two octets

### Frame length

- Structured  
 Unstructured  
 Maximum length L<sup>1</sup> (control dir.)

<sup>1</sup> L in the frame from the Control field octet 1, therefore excluding START and L fields itself, max 253

253 Maximum length L<sup>1</sup> (monitor dir.)

When using an unbalanced link layer, the following ASDU types are returned in class 2 messages (low priority) with the indicated causes of transmission:

The standard assignment of ASDUs to class 2 messages is used as follows:

Type identification	Cause of transmission
9, 11, 13, 21	<1>

A special assignment of ASDUs to class 2 messages is used as follows:

Type identification	Cause of transmission

Note: In response to a class 2 poll, a controlled station may respond with class 1 data when there is no class 2 data available.



<input checked="" type="checkbox"/>	<9> :=	Measured value, normalized value	M_ME_NA_1
<input type="checkbox"/>	<10> :=	Measured value, normalized value with time tag	M_ME_TA_1
<input checked="" type="checkbox"/>	<11> :=	Measured value, scaled value	M_ME_NB_1
<input type="checkbox"/>	<12> :=	Measured value, scaled value with time tag	M_ME_TB_1
<input checked="" type="checkbox"/>	<13> :=	Measured value, short floating point value	M_ME_NC_1
<input type="checkbox"/>	<14> :=	Measured value, short floating point value with time tag	M_ME_TC_1
<input checked="" type="checkbox"/>	<15> :=	Integrated totals	M_IT_NA_1
<input type="checkbox"/>	<16> :=	Integrated totals with time tag	M_IT_TA_1
<input type="checkbox"/>	<17> :=	Event of protection equipment with time tag	M_EP_TA_1
<input type="checkbox"/>	<18> :=	Packed start events of protection equipment with time tag	M_EP_TB_1
<input type="checkbox"/>	<19> := with time tag	Packed output circuit information of protection equipment	M_EP_TC_1
<input type="checkbox"/>	<20> := detection	Packed single-point information with status change	M_PS_NA_1
<input type="checkbox"/>	<21> :=	Measured value, normalized value without quality descriptor	M_ME_ND_1
<input checked="" type="checkbox"/>	<30> :=	Single-point information with time tag CP56Time2a	M_SP_TB_1
<input checked="" type="checkbox"/>	<31> :=	Double-point information with time tag CP56Time2a	M_DP_TB_1
<input checked="" type="checkbox"/>	<32> :=	Step position information with time tag CP56Time2a	M_ST_TB_1
<input checked="" type="checkbox"/>	<33> :=	Bitstring of 32 bit with time tag CP56Time2a	M_BO_TB_1
<input checked="" type="checkbox"/>	<34> := CP56Time2a	Measured value, normalized value with time tag	M_ME_TD_1
<input checked="" type="checkbox"/>	<35> :=	Measured value, scaled value with time tag CP56Time2a	M_ME_TE_1
<input checked="" type="checkbox"/>	<36> := CP56Time2a	Measured value, short floating point value with time tag	M_ME_TF_1



<input checked="" type="checkbox"/>	<37> :=	Integrated totals with time tag CP56Time2a	M_IT_TB_1
<input type="checkbox"/>	<38> :=	Event of protection equipment with time tag CP56Time2a	M_EP_TD_1
<input type="checkbox"/>	<39> :=	Packed start events of protection equipment with time tag CP56Time2a	M_EP_TE_1
<input type="checkbox"/>	<40> :=	Packed output circuit information of protection equipment with time tag CP56Time2a	M_EP_TF_1

Either ASDUs of the set <2>, <4>, <6>, <8>, <10>, <12>, <14>, <16>, <17>, <18>, <19> or of the set <30 –40> are used.

#### Process information in control direction

(station-specific parameter, mark each type ID 'X' if it is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions).

<input checked="" type="checkbox"/>	<45> :=	Single command	C_SC_NA_1
<input checked="" type="checkbox"/>	<46> :=	Double command	C_DC_NA_1
<input checked="" type="checkbox"/>	<47> :=	Regulating step command	C_RC_NA_1
<input checked="" type="checkbox"/>	<48> :=	Set point command, normalized value	C_SE_NA_1
<input checked="" type="checkbox"/>	<49> :=	Set point command, scaled value	C_SE_NB_1
<input checked="" type="checkbox"/>	<50> :=	Set point command, short floating point value	C_SE_NC_1
<input checked="" type="checkbox"/>	<51> :=	Bitstring of 32 bit	C_BO_NA_1

#### System information in monitor direction

(station-specific parameter, mark 'X' if it is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions)

<input checked="" type="checkbox"/>	<70> :=	End of initialization	M_EI_NA_1
-------------------------------------	---------	-----------------------	-----------

#### System information in control direction

(station-specific parameter, mark each type ID 'X' if it is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions)

<input checked="" type="checkbox"/>	<100>:=	Interrogation command	C_IC_NA_1
<input checked="" type="checkbox"/>	<101>:=	Counter interrogation command	C_CI_NA_1

—

<input type="checkbox"/> <102>: = Read command	C_RD_NA_1
<input checked="" type="checkbox"/> <103>: = Clock synchronization command	C_CS_NA_1
<input checked="" type="checkbox"/> <104>: = Test command	C_TS_NA_1
<input type="checkbox"/> <105>: = Reset process command	C_RP_NA_1
<input type="checkbox"/> <106>: = Delay acquisition command	C_CD_NA_1

## Parameter in control direction

(station-specific parameter, mark each type ID 'X' if it is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions)

<input type="checkbox"/> <110>: = Parameter of measured value, normalized value	P_ME_NA_1
<input type="checkbox"/> <111>: = Parameter of measured value, scaled value	P_ME_NB_1
<input type="checkbox"/> <112>: = Parameter of measured value, short floating point value	P_ME_NC_1
<input type="checkbox"/> <113>: = Parameter activation	P_AC_NA_1

## File Transfer

(station-specific parameter, mark each type ID 'X' if it is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions)

<input type="checkbox"/> <120>: = File ready	F_FR_NA_1
<input type="checkbox"/> <121>: = Section ready	F_SR_NA_1
<input type="checkbox"/> <122>: = Call directory, select file, call file, call section	F_SC_NA_1
<input type="checkbox"/> <123>: = Last section, last segment	F_LS_NA_1
<input type="checkbox"/> <124>: = Ack file, ack section	F_AF_NA_1
<input type="checkbox"/> <125>: = Segment	F_SG_NA_1
<input type="checkbox"/> <126>: = Directory {blank or X, only available in monitor (standard) direction}	F_DR_TA_1
<input type="checkbox"/> <127>: = Query log – Request archive file	F_SC_NB_1

Type identifier and cause of transmission assignments  
(station-specific parameters)

Shaded boxes are not defined in this companion standard and shall not be used.

Blank = function or ASDU is not used.

Mark type identification/cause of transmission combinations:

'X' if only used in the standard direction

'R' if only used in the reverse direction

'B' if used in both directions

Type identification		Cause of transmission																		
		1	2	3	4	5	6	7	8	9	10	11	12	13	20 to 36	37 to 41	44	45	46	47
<1>	M_SP_NA_1			X											X					
<2>	M_SP_TA_1																			
<3>	M_DP_NA_1			X											X					
<4>	M_DP_TA_1																			
<5>	M_ST_NA_1			X											X					
<6>	M_ST_TA_1																			
<7>	M_BO_NA_1			X											X					
<8>	M_BO_TA_1																			
<9>	M_ME_NA_1			X											X					
<10>	M_ME_TA_1																			
<11>	M_ME_NB_1			X											X					
<12>	M_ME_TB_1																			
<13>	M_ME_NC_1			X											X					
<14>	M_ME_TC_1																			
<15>	M_IT_NA_1			X												x				
<16>	M_IT_TA_1																			
<17>	M_EP_TA_1																			
<18>	M_EP_TB_1																			
<19>	M_EP_TC_1																			
<20>	M_PS_NA_1																			
<21>	M_ME_ND_1																			
<30>	M_SP_TB_1			X																
<31>	M_DP_TB_1			X																
<32>	M_ST_TB_1			X																
<33>	M_BO_TB_1			X																
<34>	M_ME_TD_1			X																
<35>	M_ME_TE_1			X																
<36>	M_ME_TF_1			X																
<37>	M_IT_TB_1			X																
<38>	M_EP_TD_1																			
<39>	M_EP_TE_1																			
<40>	M_EP_TF_1																			
<45>	C_SC_NA_1						X	X	X	X	X						X	X	X	X
<46>	C_DC_NA_1						X	X	X	X	X						X	X	X	X

Type identification		Cause of transmission																		
		1	2	3	4	5	6	7	8	9	10	11	12	13	20 to 36	37 to 41	44	45	46	47
<47>	C_RC_NA_1						X	X	X	X	X						X	X	X	X
<48>	C_SE_NA_1						X	X	X	X	X						X	X	X	X
<49>	C_SE_NB_1						X	X	X	X	X						X	X	X	X
<50>	C_SE_NC_1						X	X	X	X	X						X	X	X	X
<51>	C_BO_NA_1						X	X			X						X	X	X	X
<70>	M_EI_NA_1				X															
<100>	C_IC_NA_1						X	X	X	X	X						X	X	X	X
<101>	C_CI_NA_1						X	X			X						X	X	X	X
<102>	C_RD_NA_1																			
<103>	C_CS_NA_1						X	X									X	X	X	X
<104>	C_TS_NA_1						X	X									X	X	X	X
<105>	C_RP_NA_1																			
<106>	C_CD_NA_1																			
<110>	P_ME_NA_1																			
<111>	P_ME_NB_1																			
<112>	P_ME_NC_1																			
<113>	P_AC_NA_1																			
<120>	F_FR_NA_1																			
<121>	F_SR_NA_1																			
<122>	F_SC_NA_1																			
<123>	F_LS_NA_1																			
<124>	F_AF_NA_1																			
<125>	F_SG_NA_1																			
<126>	F_DR_TA_1*																			

\*) blank or X only

NOTE: Cause of transmission (COT) 44 shall only be marked for Type identifications which are not supported

## 4.6 Basic application functions

Station initialization

(station-specific parameter, mark 'X' if function is used).

Remote initialization

Cyclic data transmission

(station-specific parameter, mark 'X' if function is used only in the standard direction, 'R' if used only in the reverse direction, and 'B' if used in both directions).

Cyclic data transmission

## Read procedure

(station-specific parameter, mark 'X' if function is used only in the standard direction, 'R' if used only in the reverse direction, and 'B' if used in both directions).

Read procedure

## Spontaneous transmission

(station-specific parameter, mark 'X' if function is used only in the standard direction, 'R' if used only in the reverse direction, and 'B' if used in both directions).

Spontaneous transmission

## Double transmission of information objects with cause of transmission spontaneous

(station-specific parameter, mark each information type 'X' where both a type ID without time and corresponding type ID with time are issued in response to a single spontaneous change of a monitored object).

The following type identifications may be transmitted in succession caused by a single status change of an information object. The particular information object addresses for which double transmission is enabled are defined in a project-specific list.

- Single-point information M\_SP\_NA\_1, M\_SP\_TA\_1, M\_SP\_TB\_1 and M\_PS\_NA\_1
- Double-point information M\_DP\_NA\_1, M\_DP\_TA\_1 and M\_DP\_TB\_1
- Step position information M\_ST\_NA\_1, M\_ST\_TA\_1 and M\_ST\_TB\_1
- Bitstring of 32 bit M\_BO\_NA\_1, M\_BO\_TA\_1 and M\_BO\_TB\_1 (if defined for a specific project)
- Measured value, normalized value M\_ME\_NA\_1, M\_ME\_TA\_1, M\_ME\_ND\_1 and M\_ME\_TD\_1
- Measured value, scaled value M\_ME\_NB\_1, M\_ME\_TB\_1 and M\_ME\_TE\_1
- Measured value, short floating point number M\_ME\_NC\_1, M\_ME\_TC\_1 and

## Station interrogation

(station-specific parameter, mark 'X' if function is used only in the standard direction, 'R' if used only in the reverse direction, and 'B' if used in both directions)

- global
- group 1                       group 7                       group 13
- group 2                       group 8                       group 14
- group 3                       group 9                       group 15
- group 4                       group 10                       group 16

group 5

group 11

group 6

group 12

Information Object Addresses assigned to each group must be shown in a separate table

## Clock synchronization

(station-specific parameter, mark 'X' if function is used only in the standard direction, 'R' if used only in the reverse direction, and 'B' if used in both directions)

- Clock synchronization
- Day of week used
- RES1, GEN (Time tag substituted/not substituted) used
- SU-bit (summertime) used

## Command transmission

(object-specific parameter, mark 'X' if function is used only in the standard direction, 'R' if used only in the reverse direction, and 'B' if used in both directions)

- Direct command
- Direct set point command transmission
- Select and execute command (Only for the commands without timetag)
- Select and execute set point command (Only for the commands without timetag)
- C\_SE ACTTERM used
- No additional definition
- Short pulse duration (duration determined by a system parameter in the outstation)
- Long pulse duration (duration determined by a system parameter in the outstation)
- Persistent output

## Transmission of integrated totals

(station- or object-specific parameter, mark 'X' if function is used only in the standard direction, 'R' if used only in the reverse direction, and 'B' if used in both directions)

- Mode A: Local freeze with spontaneous
- Mode B: Local freeze with counter

—

- Mode C: Freeze and transmit by counter interrogation
- Mode D: Freeze by counter interrogation command, frozen values reported
- Counter read
- Counter freeze without reset
- Counter freeze with reset
- Counter reset
- General request
- Request counter group 1
- Request counter group 2
- Request counter group 3
- Request counter group 4

## Parameter loading

(object-specific parameter, mark 'X' if function is used only in the standard direction, 'R' if used only in the reverse direction, and 'B' if used in both directions)

- Threshold value
- Smoothing factor
- Low limit for transmission of measured
- High limit for transmission of measured

## Parameter activation

(object-specific parameter, mark 'X' if function is used only in the standard direction, 'R' if used only in the reverse direction, and 'B' if used in both directions)

- Act/deact of persistent cyclic or periodic transmission of the addressed

## Test procedure

(station-specific parameter, mark 'X' if function is used only in the standard direction, 'R' if used only in the reverse direction, and 'B' if used in both directions)

- Test procedure

—

## File transfer

(station-specific parameter, mark 'X' if function is used)

### File transfer in monitor direction

- Transparent file
- Transmission of disturbance data of protection
- Transmission of sequences of events
- Transmission of sequences of recorded analogue values

### File transfer in control direction

- Transparent file

## Background scan

(station-specific parameter, mark 'X' if function is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions)

- Background scan

## Acquisition of transmission delay

(station-specific parameter, mark 'X' if function is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions)

- Acquisition of transmission delay



## 5 ADDITIONAL INFORMATION

Value range of Integrated totals is 0 - 0x7FFF FFFF, because only the positive part will be processed.