SUBMITTAL AM048TXMDCH/AA

Page 1 of 2

Samsung DVM S Eco Series, Heat Pump Condensing Unit

Job Name	Location	Location		
Purchaser	Engineer			
Submitted to	Reference	Approval	Construction	
Unit Designation	Schedule #			

Unit Design	nation			
		0		
	US Ton (nominal)	System Specifications	4.0	
	00 Ton (nominal)	Nominal Cooling	48,000	
	Capacity (Btu/h)	Nominal Heating	,	
Performance ¹	System Modulatio		54,000 7,500	
CHOMINANCE	SEER2 Ducted / Non-Ducted		17.5 / 20.5	
	EER2	Ducted / Non-Ducted		
	HSPF2	Ducted / Non-Ducted	10.2 / 11.5	
			8.8 / 10.0	
Power	Voltage (ø/V/Hz) Maximum Circuit Breaker		1 / 208-230 / 60	
	(MCCB/ELB/ELCB)		50	
	Minimum Circuit Ampacity (MCA)		29	
Indoor Units	Total Capacity (%)		50 - 130% Of Outdoor Capacity	
	Maximum Indoor Unit Quantity		9	
0	Туре		Twin BLDC Rotary X1	
Compressor	RLA	A	22.1	
Defrigerent	Туре		R410A	
Refrigerant	Factory Charge	lbs.	7.1	
Pipe Connections	Liquid X Suction		3/8 X 5/8	
Installation Limitation ²	Max. Distance - ODU to IDU (feet)		492 (574 equivalent)	
	Vertical Separation ODU to IDU ³		164 / 131	
	(feet)	Highest/Lowest IDU	49	
	Total Refrigerant Pipe (feet)		984	
	Fan	Туре	Propeller X 2	
0		Output (CFM)	3,885	
Condenser Fan	Motor	Туре	BLDC	
		Output (W) / FLA (A)	125 X 2 / 0.6	
<u>.</u>	WXHXD	Inches	37 X 47 5/8 X 13	
Dimensions	Weight	lbs.	216.1	
Sound Level	Max. dB (A)	Cooling / Heating	51 / 53	
Operating	Cooling ⁴	°F	0°F ~ 118°F (-18°C ~ 48°C)	
Temperature Range	Heating	°F	-13°F ~ 75°F (-25°C ~ 24°C)	
Accessories	Wind Baffles	Front	WBF-1M2	
		Back	WBB-2M-B	
	Wi-Fi Adapter		MIM-H04UN	
	Mode Selector Switch For HP Systems		MCM-C200U	
	Base Pan Heater Kit		MHC-015EE	
	External contact control interface module (operation and error output, night silent mode manual activation)		MIM-B14	
			I	

Safety Certifications		ETL (UL 1995)	
Protection Devices	Intelligent logic to ensure proper operation within unit design limitations and		
	operational parameters High pressure sensor, low pressure sensor, over-voltage protection,		
	compressor over-current protection, current transformer, fan motor voltage protection, fan motor thermal protection, high voltage fuses		

¹ Certified in accordance with AHRI 210/240 (2023). Effective January 1st, 2023.

Proper sizing and installation of equipment is critical to achieve optimal performance. Split system air conditioners and heat pumps (excluding ductless systems) must be matched with appropriate coil components to meet ENERGY STAR criteria. Ask your contractor for details or visit www.energystar.gov.



Compatibility

Only compatible with Samsung DVM S indoor units (AM****N***H***) and MCM-D211UN Universal Communication Kit.

Construction

The unit shall be galvanized steel with a baked on powder coated finish

Refrigerant pipe connections inside unit chassis with penetrations available on front, back, right, and bottom sides for versatile installation

Heat Exchanger

The heat exchanger shall be mechanically bonded fin to copper tube.

Salt spray test method: ASTM-B117-18 - the heat exchanger showed no unusual rust or corrosion development to 2,280 hours.

Controls

The unit shall be operated via NASA Protocol with controls provided by Samsung

Control wiring shall be 16 AWG X 2 shielded wire.

Refrigerant System

The compressors shall be Samsung hermetically sealed, inverter driven, twin BLDC Rotary type.

Refrigerant flow shall be controlled by EEV (electronic expansion valve) throughout the system.

A flat plate subcooler device will improve capacity at extreme system refrigerant pipe lengths and reduce refrigerant noise.

Other Features

Optional night quiet modes to reduce outdoor unit sound

Optional snow blowing logic to prevent snow drifting on idle outdoor units








² Other pipe restrictions and requirements exist. Please consult installation manuals or technical data book for full details.

³ Vertical separation: 131' when outdoor unit is lower than the indoor units, 164' when the outdoor unit is higher than the indoor units.

 $^{^4}$ When cooling in outside temperatures between 0°F $\sim 23^\circ F,$ wind baffles are required. When outside temperature is between 0°F $\sim 23^\circ F,$ minimum 50% operating capacity should be maintained to ensure reliability while in cooling mode.



FRONT

- (3) Condensate drain holes
- 2 Liquid refrigerant pipe opening

(1) Gas refrigerant pipe opening

4 Communication conduit opening (2 X Ø1 3/8")

1

888-699-6067 www.SamsungHVAC.com