

Model: CNH**4DB (AC***BN4DCH/AA), CNH**HDB (AC***BNHDCH/AA), CNH**ZDK(AC***KNZDCH/AA) CXH**SCB (AC***BXSCCH/AA)

History

Version	Modification	Date	Remark
Ver.1.0	Released 2021 CAC Max Heat Line up for North America	21. 12. 23	

Features & Benefits

CAC - World-class energy efficiency

Maintain optimal comfort and control with energy and cost-efficient technologies


Featuring a suite of energy-optimizing technologies, Samsung CAC Single delivers top-class energy efficiency to support business in saving costs and the environment.

Quick, efficient heating and cooling

Smart inverter technology offers powerful, quick cooling and heating with minimal electricity consumption, which means real cost savings and less energy waste.

Up to 50 percent less energy use

After reaching changes its operation mode to economical. By avoiding inefficient and frequent switching on and off of the compressor, the digital inverter saves up to 50 percent in energy consumption compared to non-inverter air conditioners.



Wind-Free Cooling with Micro holes


- The Wind-Free Air conditioner pushes air out through 15,000 micro holes in the panel, producing a dispersed and gentle flow of air actually defined as "still air" and the key here is all of those holes create a still, cooled air flow that infiltrates the room gently and softly.
- ** Still Air condition : According to ASHRAE, If velocity of wind is lower than 0.15m/s, People can not detect wind. And they define that condition is "Still Air"

No Direct Wind & Cold Draft



* Wind-Free 4Way(600x600) : 9,000 Micro Holes

[Comparison of Room Temp.]



* Internal Test (14.0kW Model @ 122m²)

Features & Benefits

CAC Single - Superior performance

Stabilize the atmosphere with broad temperature allowance and control


Samsung is dedicated to supporting comfortable living and working environments based on the strength of its technologies. With a single unit, CAC Single delivers reliable comfort and control over multiple areas to ensure a pleasant atmosphere in any climate.

Wide temperature performance

No matter how extreme the temperature, the highperforming CAC Single can handle the conditionwithout the need for an additional unit. Featuring a wide temperature allowance, it can cool in heat of up to 50 and provide warmth in the freezing cold of -20°C to ensure a constant and comfortable home environment.

Ideal comfort in minutes

The CAC Single digital inverter air conditioner works at maximum capacity at startup. As soon as the temperature reaches the desired or set temperature, CAC Single performs fine adjustments to cope with any changes. This means less temperature fluctuation and ideal comfort in a matter of minutes.



Versatile piping installation


CAC Single outdoor units offer a selection of pipe directions. The internal pipe connection ports allow four different pipe directions, supporting a neater, more organized-looking unit upon installation.



Nomenclature

US Code

Model Name



(1) Classification

С	CAC

(5-2) Feature1 (Outdoor Unit)

Α	Inv+Side+General Temp
S	Inv+Side+Low Temp
Q	Inv+Side+Tropical Temp
F	Inv+Top+Tropical Temp

(2) Product Type

N	Indoor Unit
Χ	Outdoor Unit

(6) Feature

F	Flagship	
S	Standard	
D	Deluxe	
Р	Premium	
С	Deluxe + Low Temp.	

(3) Mode

Α	Universal	
С	Cooling Only	
Н	Heat Pump	

(7) Version

В	2022
K	2016

(4) Capacity

X1,000 Btu	ı/h (2 digits)

(5-1) Product Notation (Indoor Unit)

1	1 Way Cassette / Wind-Free 1Way Cassette
NI	4 Way Cassette (600x600)
N	Wind-Free 4 Way Cassette (600x600)
4	4 Way Cassette, 360 Cassette
4	Wind-Free 4 Way Cassette
L	LSP Duct
Н	HSP Duct
С	Ceiling
J	Console
Α	AR9500 (Wall Mounted)
Т	MAX4 (Wall Mounted)
Z	Multi-position AHU

Nomenclature

Indoor Unit

Model Name



(1) Classification

AC	CAC
(2) Capacity	
	X1,000 Btu/h (3 digits)
(3) Version	

В	2022
K	2016

(4) Product Type

N	Indoor Unit
X	Outdoor Unit

(5) Product Notation

1	1 Way Cassette
NI	4 Way Cassette (600x600)
N	Wind-Free 4 Way Cassette (600x600)
4	4 Way Cassette, 360 Cassette
4	Wind-Free 4 Way Cassette
L	LSP Duct
Н	HSP Duct
С	Ceiling
J	Console
Α	AR9500 (Wall Mounted)
T	MAX4 (Wall Mounted)
Z	Multi-position AHU

(6) Feature

F	Flagship
S	Standard
D	Deluxe
Р	Premium

(7) Rating Voltage

_	14 200 2701//011
C	IΨ, 208-230V,60Hz


(8) Mode

С	Cooling Only
Н	Heat Pump

Nomenclature

Outdoor Unit

Model Name



(1) Classification

AC	CAC

(5) Feature1

Α	Inv+Side+General Temp
S	Inv+Side+Low Temp
Q	Inv+Side+Tropical Temp
F	Inv+Top+Tropical Temp

(2) Capacity

x 1000 Btu/h (3 digits)

(6) Feature2

F	Flagship
S	Standard
D	Deluxe
Р	Premium
	Deluxe + Low Temp.

(3) Version

В	2022

(7) Rating Voltage

С	1Ф, 208~230V, 60Hz
Н	3Ф, 400V, 60Hz

(4) Product Type

N	Indoor Unit (NASA)
Х	Outdoor Unit (NASA)

(8) Mode

Н	Heat Pump(R410A)
С	Cooling Only(R410A)
Е	Heat Pump(R22)
D	Cooling Only(R22)

Line-up

Indoor unit

Madal	Capacity	(kBtu/h)
Model	30	36
Wind-Free 4Way Cassette		
Duct S		
Multi-position AHU		

Outdoor Unit

	Capacity	(kBtu/h)
Model	30	36
CXH**SCB (AC***BXSCCH/AA)	EAMSUND COMPANY OF THE PARK OF	EAMSUND

Contents

Wind-Free 4Way Cassette	10
Duct S	23
Multi-position AHU	40
Outdoor Units	51
Installation	62

Wind-Free 4Way Cassette

1. Specification	12
2. Summary Table	14
3. Capacity Table	15
4. Dimensional Drawing	17
5. Center of Gravity	18
6. Electrical Wiring Diagram	19
7. Sound Data	20
8. Temperature and air flow distribution	22

Features & Benefits

Wind-Free 4Way Cassette

Stage a beautiful yet comfortable environment

With its newly improved design, Wind-Free 4Way Cassette supports a clean, aesthetically appealing atmosphere and adds a sense of sophistication to work and living spaces. Not only is this unit attractively designed, but it also uses advanced technologies to optimize comfort in any environment.



The Samsung Wind-Free 4Way Cassette indoor air conditioning system delivers polish, comfort and efficiency with features such as:

- Stylishly clean design. Add panache to interior spaces with a choice of clean, streamlined panel patterns in a lightweight build.
- **Robust operation.** Control the atmosphere perfectly with an advanced design for superior airflow and cooling/heating performance.
- Low maintenance and simple installation. Ease installation and minimize maintenance with a detachable, no-drip design.

Wind-Free 4Way Cassette - Stylishly clean design

Aesthetic panel and display

Wind-Free 4Way Cassette offers two different pattern designs for the panel. The simple display design with rounded corners adds a chic sophistication to the interior.




Neat and clean design

The indoor Wind-Free 4Way Cassette boasts a smart design that promotes a neat and clean look. The completely hermetic blade structure keeps the indoor unit clean by preventing dust or other foreign substances from entering it. The internal parts of the indoor unit are also out of sight when the blade is shut, thus improving the unit's appearance.

Lightweight build

The Samsung Wind-Free 4Way Cassette indoor unit is now lighter in weight at 17 kg. It is one of the lightest indoor units in the industry, about 40 percent lighter than conventional products.



1. Specification

Wind-Free 4Way Cassette

Model Na	ame	Indoor Unit			AC030BN4DCH/AA	AC036BN4DCH/AA				
		Outdoor Unit			AC030BXSCCH/AA	AC036BXSCCH/AA				
JS Code		Indoor Unit			CNH304DB	CNH364DB				
		Outdoor Unit			CXH30SCB	CXH36SCB				
	Mode	ı		-	Heat Pump	Heat Pump				
				kW	3.81/8.79/10.55	4.10/10.55/12.31				
			Cooling	Btu/h	13,000 / 30,000 / 36,000	14,000 / 36,000 / 42,000				
	Performance	Capacity		US RT	1.08/2.50/3.00	1.17/3.00/3.50				
	T CITOTINATICE	(Min/Std/Max)		kW	2.93/9.96/11.72	3.08/11.72/13.19				
			Heating	Btu/h	10,000 / 34,000 / 40,000	10,500 / 40,000 / 45,000				
				US RT	0.83/2.83/3.33	0.88/3.33/3.75				
		Power Input	Cooling	kW	0.80 / 2.27 / 3.20	0.85 / 2.77 / 3.90				
		(Min/Std/Max)	Heating	KVV	0.53 / 2.59 / 4.50	0.55 / 3.05 / 4.80				
	Power	Current Input	Cooling	Α	4.2 / 10.3 / 14.3	4.5 / 12.5 / 17.1				
	Fower	(Min/Std/Max)	Heating	A	2.8 / 11.9 / 19.8	2.9 / 13.8 / 21.1				
		Current	MCA	А	30.4	30.4				
		Current	MFA	А	40	40				
		rrp.	Cooling	-	3.87	3.81				
		EER	Cooling(US)	(Btu/h)/W	13.2	13.0				
	Efficiency	COP	Heating	W/W	3.85	3.85				
		SEER	,	-	22.0	21.0				
/stem		HSPF		-	10.6	10.6				
				Туре	Flare	Flare				
		Liquid Pipe		Φ, mm(inch)	9.52 (3/8)	9.52 (3/8)				
				Type	Flare	Flare				
		Gas Pipe		Φ, mm(inch)	15.88 (5/8)	15.88 (5/8)				
	Pipe	Heat Insulation		φ, ππη(πτεπ) -	Both liquid and gas pipes	Both liquid and gas pipes				
	Connections	Ticat ilisatation	Standard	m (ft)	7.5 (24.6)	7.5 (24.6)				
		Pipe Length	Max.	m (ft)	7.5 (24.0)	7.5 (24.0)				
		(ODU-IDU)	Elevation	m (ft)	30 (98.4)	30 (98.4)				
		(000-100)								
V	M/inim m		Chargeless	m (ft)	7.5 (24.6)	7.5 (24.6)				
	Wiring	Communication	Min.	mm ²	0.75	0.75				
	Connections	-	Remark	-	F1,F2	F1,F2				
		Туре		-	R410A	R410A				
	Refrigerant	Factory Charging		kg	4.0	4.0				
				lbs	8.82	8.82				
	Option Code	Standard		-	0143FF-195418-275A5E-370040	0143FF-19546A-276975-370040				
	·	Install		-	020010-100001-200000-300000	020010-100001-200000-300000				
	Power Supply	1		Ф,#,V,Hz	1,2,208-230,60	1,2,208-230,60				
		Туре		-	Fin & Tube	Fin & Tube				
	Heat	Material	Fin	-	Al	Al				
	Exchanger	riateriat	Tube	-	Cu	Cu				
		Fin Treatment		-	Green Hydrophile	Green Hydrophile				
		Туре		-	Turbo(3D)	Turbo(3D)				
		Quantity		EA	1	1				
				m ³ /min	28.2/23.6/17.8	34.2/25.8/19.0				
	Fan	Air Flow Rate	H/M/L	ft³/min	996/833/629	1208/911/671				
				l/s	470/393/297	570/430/317				
		External Static	Min/Std/Max	In Wg						
door		Pressure	. IIII/ Std/ Max	III VV G	2125					
iit	Fan Motor	Туре		-	BLDC	BLDC				
		Output		Wxn	97 x 1	97 x 1				
	Drain	Drain Pipe		Φ, mm	OD26.67	OD26.67				
	Sound	Sound Pressure Level	H/M/L	dB(A)	37/34/30	43/38/33				
		Sound Power Lev	rel	dB(A)	53	59				
		Net Weight		kg(lbs)	19.0(21.9)	21.2(46.7)				
		Gross Weight		kg(lbs)	22.5(49.6)	24.8(54.7)				
	External	N. I. Dir.	W II 5)	mm	840 x 288 x 840	840 x 288 x 840				
	Dimension	Net Dimensions ((WXHXD)	inch	33.07 x 11.34 x 33.07	33.07 x 11.34 x 33.07				
				mm	898 x 357 x 898	898 x 357 x 898				
		Net Dimensions (NA E.	111111	070 X JJ/ X 070	35.35 x 14.06 x 35.35				

1. Specification

Wind-Free 4Way Cassette

Model Na		Indoor Unit			AC030BN4DCH/AA	AC036BN4DCH/AA				
Model Na	ime	Outdoor Unit			AC030BXSCCH/AA	AC036BXSCCH/AA				
IC C-4-		Indoor Unit			CNH304DB	CNH364DB				
JS Code		Outdoor Unit			CXH30SCB	CXH36SCB				
	Casing	Material		-	Polypropylene	Polypropylene				
		Model Name		-	PC4NUFMUN	PC4NUFMUN				
		Type		=	Wind-Free Type	Wind-Free Type				
		Material		=	HIPS	HIPS				
		Color		=	DA White	DA White				
	Panel	Net Weight		kg(lbs)	6.3 (13.9)	6.3 (13.9)				
	lanet	Gross Weight		kg(lbs)	8.7 (19.2)	8.7 (19.2)				
ndoor		Net Dimensions ((M^H^D)	mm	950 x 64 x 950	950 x 64 x 950				
Jnit		Net Dimensions ((WAITAD)	inch	37.4 x 2.5 x 37.4	37.4 x 2.5 x 37.4				
Jilic		Net Dimensions ((M^H^D)	mm	1,010 x 117 x 1,000	1,010 x 117 x 1,000				
	Cantani	INEL DIFFICIONS ((VVXI IXD)	inch	39.8 x 4.6 x 39.4	39.8 x 4.6 x 39.4				
	Control	Infrared remote of			AR-EH04U	AR-EH04U				
	System	Wired remote cor	ntrol	-	MWR-WG00UN / MWR-SH11UN	MWR-WG00UN / MWR-SH11UN				
	Drain Pump	Drain Pump		-	Included	Included				
	Drain r unip	Max.lifting Height / D	isplacement	in / gal/h	29-5/16 6.34gal/h	29-5/16 6.34gal/h				
	Additional Accessories	Air Filter		-	Removable / Washable	Removable / Washable				
	Power Supply			Ф,#,V,Нz	1,2,208-230,60	1,2,208-230,60				
		Туре		-	Fin & Tube	Fin & Tube				
	Heat	Material	Fin	-	Al	Al				
	Exchanger	Material	Tube	-	Cu	Cu				
		Fin Treatment		-	Anti-Corrosion	Anti-Corrosion				
	Compressor	Model		-	ATQ420D1UNT1	ATQ420D1UNT1				
		Туре		-	Twin BLDC	Twin BLDC				
		Output		kW	3.44	3.44				
		Oil	Туре	-	POE	POE				
			Initial Charge	cc (fl oz)	1500	1500				
		Type		=	Propeller	Propeller				
		Discharge directi	on	=	Front	Front				
	Fan	Quantity		EA	2	2				
	rall			m³/min	125	125				
Outdoor		Air Flow Rate	H/M/L	ft³/min	4,414	4,414				
Jnit				l/s	2,083	2,083				
	Fan Mata	Туре		-	BLDC	BLDC				
	Fan Motor	Output		Wxn	125 x 2	125 x 2				
		Sound Pressure	Cooling	dB(A)	49	49				
	Sound	Level	Heating	dB(A)	50	51				
		Sound Power Lev		dB(A)	67	69				
		Net Weight		kg(lbs)	100.0 (220.5)	100.0 (220.5)				
		Gross Weight		kg(lbs)	110.0 (242.5)	110.0 (242.5)				
	External	Not Dimensions	(MVHVD)	mm	940 x 1,420 x 330	940 x 1,420 x 330				
	Dimension	Net Dimensions ((MXHXD)	inch	37.01 x 55.91 x 12.99	37.01 x 55.91 x 12.99				
		Not Dimension	(MALIAD)	mm	995 x 1,598 x 426	995 x 1,598 x 426				
		Net Dimensions ((VVXHXD)	inch	37.17 x 62.91 x 16.77	37.17 x 62.91 x 16.77				
	Casing	Material	Body	-	Steel	Steel				
	Operating	Cooling		°C (°F)	-20~50 (-4~122)	-20~50 (-4~122)				
	Temp. Range	Heating		°C (°F)	-25~24 (-13~75)	-25~24 (-13~75)				

NOTE

- Specification may be subject to change without prior notice.
 1) Performances are based on the following test conditions.

 Cooling: Indoor temperature: 80°F(26.7°C) DB, 67°F(19.4°C) WB, Outdoor temperature: 95°F(35°C) DB, 75°F(23.9°C) WB
 Heating: Indoor temperature: 70°F(21.1°C) DB, 60°F(15.6°C) WB, Outdoor temperature: 47°F(8.3°C) DB, 43°F(6.1°C) WB
 Equivalent refrigerant piping length 5m(16.4ft), Level differences: 0m(0ft))

 2) Select wire size based on the value of MCA
 3) Sound pressure level is obtained in an anechoic room.

 Sound pressure level is a relative value, depending on the distance and acoustic environment.
 Sound pressure level may differ depending on operation condition.
 dBA = A-weighted sound pressure level / Reference acoustic pressure 0 dB = 20uPa

 4) Sound power level is an absolute value that a sound source generates.

 dBA = A-weighted sound power level
 Reference power: 1pW / Measured according to ISO 3741

 5) These products contain R410A which is fluorinated greenhouse gas.

2. Summary Table

Wind-Free 4Way Cassette

Performance Characteristics

	Net		Сарас	ity		Airflow	Sound Pressure Level	Cound Downs Lovel
Model Code	Weight (lbs)		Cooling Heating (Btu/h) (Btu/h)		Fan Speed	(Cooling/Heating) (CFM)	(dBA)	(dBA)
		Max.	36,000	40,000	High	996 / 996	37	53
CNH304DB (AC030BN4DCH/AA)	41.9	Std.	30,000	34,000	Mid	833 / 833	34	-
(ACOJODINADCI I/AA)		Min.	13,000	10,000	Low	629 / 629	30	-
		Max.	42,000	45,000	High	1,208 / 1,208	43	59
CNH364DB (AC036BN4DCH/AA)	46.7	Std.	36,000	40,000	Mid	911 / 911	38	-
(ACOJODINADCI I/AA)		Min.	14,000	10,500	Low	671 / 671	33	-



• Sound data is based on cooling operation.

Electric Characteristics

Мо		Outdoor U	nit		Inp	ut Curren	res)	Power Supply			
la da au Hait	Outdoor Unit	Rated	Voltage	e rang	e	Outdo	or Unit	Indoor	Total	MCA(A)	MOD(A)
Indoor Unit	Outdoor Unit	Hz	Volts	Min.	Max	Cooling	Heating	Unit	Total	MCA(A)	MOP(A)
CNH304DB (AC030BN4DCH/AA)	CXH30SCB(AC030BXSCCH/AA)	60	208 to 230	187	253	29.57	29.57	0.79	30.36	30.4	40
CNH364DB (AC036BN4DCH/AA)	CXH36SCB(AC036BXSCCH/AA)	60	208 to 230	187	253	29.57	29.57	0.79	30.36	30.4	40



• MCA: Minimum circuit amperes

• MOP: Maximum Overcurrent Protective Device

• Select wire size based on the value of MCA

3. Capacity Table

Wind-Free 4Way Cassette

(1) CNH304DB(AC030BN4DCH/AA) + CXH30SCB(AC030BXSCCH/AA)

Cooling

TC: Total Capacity, SHC: Sensible Heat Capacity, PI: Power Input

Outdoor								I	ndoor	Tempe	rature (°F, DB	/ WB)								
Temp.	68 / 57		72 / 61		77 / 64			80 / 67		82 / 70				86 / 72		90 / 75					
(°F, DB)	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
(F, DD)	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW
0	30.5	22.0	1.71	32.1	22.7	1.74	33.5	23.4	1.78	34.5	24.2	1.82	35.2	23.9	1.83	36.9	23.7	1.85	38.8	23.2	1.89
70	33.2	24.0	1.71	34.9	24.7	1.74	36.4	25.5	1.78	37.5	26.3	1.82	38.3	26.0	1.83	40.2	25.7	1.85	42.2	25.2	1.89
95	26.5	19.2	2.14	27.9	19.8	2.18	29.1	20.4	2.22	30.0	21.0	2.27	30.6	20.8	2.29	32.1	20.6	2.32	33.7	20.2	2.36
115	31.8	23.0	3.95	33.5	23.7	4.03	34.9	24.4	4.12	36.0	25.2	4.20	36.7	24.9	4.24	38.6	24.7	4.28	40.5	24.2	4.37
122	29.2	21.1	3.63	30.7	21.7	3.71	32.0	22.4	3.78	33.0	23.1	3.86	33.7	22.9	3.90	35.3	22.6	3.94	37.1	22.2	4.01

Heating

TC: Total Capacity, PI: Power Input

Outdoor		Indoor Temperature (°F, DB)												
Temperature	6	51	6	4	6	8	7	0	7	2	7	5		
(°F, DB)	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI		
(F, DD)	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW		
-13	28.0	4.91	27.7	4.87	27.5	4.82	27.2	4.77	26.9	4.72	26.7	4.68		
-4	35.0	5.46	34.7	5.41	34.3	5.35	34.0	5.30	33.7	5.25	33.3	5.19		
14	38.5	4.67	38.2	4.62	37.8	4.58	37.4	4.53	37.0	4.49	36.7	4.44		
32	40.3	4.40	39.9	4.36	39.5	4.32	39.1	4.27	38.7	4.23	38.3	4.19		
47	35.0	2.67	34.7	2.64	34.3	2.62	34.0	2.59	33.7	2.56	33.3	2.54		
75.2	43.8	2.80	43.4	2.77	42.9	2.75	42.5	2.72	42.1	2.69	41.7	2.67		



• The performance table shows the average value of each conditions.

3. Capacity Table

Wind-Free 4Way Cassette

(2) CNH364DB(AC036BN4DCH/AA) + CXH36SCB(AC036BXSCCH/AA)

Cooling

TC : Total Capacity, SHC : Sensible Heat Capacity, PI : Power Input

Outdoor								I	ndoor	Tempe	rature (°F, DB	/WB)									
Temp.	68 / 57			72 / 61			77 / 64				80 / 67			82 / 70			86 / 72			90 / 75		
(°F, DB)	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	
(F, DB)	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	
0	35.0	25.3	2.22	36.9	26.1	2.26	38.4	26.9	2.31	39.6	27.7	2.35	40.4	27.4	2.38	42.4	27.2	2.40	44.5	26.6	2.45	
70	39.8	28.7	2.35	41.9	29.6	2.39	43.7	30.6	2.44	45.0	31.5	2.49	45.9	31.2	2.52	48.2	30.9	2.54	50.6	30.3	2.59	
95	31.8	23.0	2.61	33.5	23.7	2.66	34.9	24.4	2.71	36.0	25.2	2.77	36.7	24.9	2.80	38.6	24.7	2.83	40.5	24.2	2.88	
115	33.4	24.1	4.12	35.2	24.9	4.20	36.7	25.7	4.29	37.8	26.5	4.38	38.6	26.2	4.42	40.5	25.9	4.46	42.5	25.4	4.55	
122	30.3	23.4	3.78	31.8	24.1	3.86	33.2	24.9	3.94	34.2	25.7	4.02	34.9	25.4	4.06	36.6	25.1	4.10	38.5	24.6	4.18	

Heating

TC: Total Capacity, PI: Power Input

Outdoor		Indoor Temperature (°F, DB)													
Temperature	6	51	6	4	6	8	7	0	7	2	75				
(°F, DB)	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI			
(F, DD)	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW			
-13	33.0	5.05	32.6	5.00	32.3	4.95	32.0	4.90	31.7	4.85	31.4	4.80			
-4	41.2	5.67	40.8	5.61	40.4	5.56	40.0	5.50	39.6	5.45	39.2	5.39			
14	43.3	4.87	42.8	4.82	42.4	4.77	42.0	4.73	41.6	4.68	41.2	4.63			
32	47.4	4.71	46.9	4.67	46.5	4.62	46.0	4.58	45.5	4.53	45.1	4.48			
47	41.2	3.14	40.8	3.11	40.4	3.08	40.0	3.05	39.6	3.02	39.2	2.99			
75.2	53.6	3.61	53.0	3.58	52.5	3.54	52.0	3.51	51.5	3.47	51.0	3.44			




• The performance table shows the average value of each conditions.

4. Dimensional Drawing

Wind-Free 4Way Cassette

Units: mm [inches]



No.	Name	Description
1	Liquid pipe connection	Φ 9.52mm(3/8")
2	Gas pipe connection	Φ 15.88mm(5/8")
3	Drain pipe connection	VP25[OD32mm(1.26"), ID25mm(0.98")]
4	Power supply & Communication wiring conduit	
5	Fresh air intake knockout hole	Ф101mm(4") , Use M4 Screw


NOTE

• As for suspension bolt, please use M8 ~ M10. (Procured at local site)

5. Center of Gravity

Wind-Free 4Way Cassette


Units: mm [inches]



A	В
305 [12]	130 [5-1/8]

6. Electrical Wiring Diagram

Wind-Free 4Way Cassette



SUB PBA	Printed Circuit Board(SUB)	SPI	S-Plasma ion	ROOM(10K)	Thermistor ROOM OUT(10K)
M-BLDC	BLDC Motor	EEV	Electronic Expansion Valve	EVA-IN(10K)	Thermistor EVA IN(10K)
		EXT_CONTROL	EXTERNAL_CONTROL	EVA-OUT(10K)	Thermistor EVA OUT(10K)

NOTE

- This wiring diagram applies only to the Indoor unit.
- Symbols show as follow: blk: black, red: red, blu: blue, wht: white, yel: yellow, brn: brown, sky: skyblue: grn: green
- For connection wiring indoor-outdoor transmission F1-F2, indoor-wired remote controller transmission F3-F4.
- Protective earth(screw), 💷 : connector, 🋂 : The wire quantity

7. Sound Data

Wind-Free 4Way Cassette


Sound Pressure level

Unit: dB(A)


1.5m
Microphone

Model	High	Mid	Low
CNH304DB (AC030BN4DCH/AA)	37	34	30
CNH364DB (ACO36BN4DCH/AA)	43	38	33

- NC Curve
 - 1) CNH304DB (AC030BN4DCH/AA)



2) CNH364DB (ACO36BN4DCH/AA)



NOTE

- Specifications may be subject to change without prior notice.
 - Sound pressure level is obtained in an anechoic room.
 - Sound pressure level is a relative value, depending on the distance and acoustic environment.
 - Sound pressure level may differ depending on operation condition.
 - dBA = A weighted sound pressure level
 - Reference acoustic pressure 0 dB = 20µPa

7. Sound Data

Wind-Free 4Way Cassette


Sound Power level

■ NOTE

- Specifications may be subject to change without prior notice
 - Sound power level is an absolute value that a sound source generates.
 - dBA = A-weighted sound power level.
 - Reference power: 1pW.
 - Measured according to ISO 3741.

NC Curve


1) CNH304DB (AC030BN4DCH/AA)



Unit: dB(A)

Model	Cooling
CNH304DB (AC030BN4DCH/AA)	53
CNH364DB (AC036BN4DCH/AA)	59

2) CNH364DB (AC036BN4DCH/AA)




8. Temperature and air flow distribution


Wind-Free 4Way Cassette

CNH304DB (AC030BN4DCH/AA)


• Cooling Air Velocity distribution (Discharge angle : 45 degree)




 Heating Air Velocity distribution (Discharge angle: 52 degree)



 Cooling temperature distribution (Discharge angle: 45 degree)




 Heating temperature distribution (Discharge angle: 52 degree)




CNH364DB (AC036BN4DCH/AA)


 Cooling Air Velocity distribution (Discharge angle: 45 degree)




 Heating Air Velocity distribution (Discharge angle: 52 degree)



 Cooling temperature distribution (Discharge angle: 45 degree)



 Heating temperature distribution (Discharge angle: 52 degree)



Duct S

1. Specification	25
2. Summary Table	27
3. Capacity Table	28
4. Dimensional Drawing	30
5. Center of Gravity	32
6. Electrical Wiring Diagram	33
7. Sound Data	34
8. Temperature and air flow distribution	36

Features & Benefits

Duct S

Overview

Samsung Ducted Type air conditioning units are a smart solution for low-maintenance, consistent cooling and heating performance in any environment. Their compact, slim frame blends seamlessly into ceilings, enhancing the beauty of the interior space and affording users more flexible installation options. Offering a comprehensive lineup, Samsung Ducted Type air conditioning units offer just the right solution for every need--from the office or shop to the restaurant kitchen.

Experience performance and convenient comfort for any weather condition

Samsung Duct S delivers unparalleled cooling and heating and flexible management with customizable comfort settings in any climate—all year round. Plus, it boasts a slim, compact size and multiple access points for easy setup exactly where needed.



Smart pressure control

Samsung Ducted Type units feature a smart pressure control system. This system adjusts the fan speed based on the external static pressure (ESP), delivering consistent cooling and heating power, regardless of the surrounding environment.

Convenient installation

The optional lift-up drain pump lifts condensed water up to 27.6 inch, compared to a limit of 29.5 inch on conventional models, for flexible and convenient installation.

The Duct S indoor air conditioning unit delivers smooth, consistent operation and convenience with features such as:

- Efficient operation. Stage the desired atmosphere with energy-efficient performance and customized airflow.
- Smart management. Cool spaces efficiently and manage the air conditioning unit even while away, with features designed for efficiency and control.
- Easy, flexible setup. Install and maintain even multiple units with a compact and easily accessible design.

1. Specification

Duct S

Model Na	mo	Indoor Unit			AC030BNHDCH/AA	AC036BNHDCH/AA				
Modeling	iiie	Outdoor Unit			AC030BXSCCH/AA	AC036BXSCCH/AA				
US Code		Indoor Unit			CNH30HDB	CNH36HDB				
OJ COGE		Outdoor Unit			CXH30SCB	CXH36SCB				
	Mode			-	Heat Pump	Heat Pump				
				kW	4.10/8.79/10.55	4.25/10.55/12.31				
			Cooling	Btu/h	14,000 / 30,000 / 36,000	14,500 / 36,000 / 42,000				
	Performance	Capacity		US RT	1.17/2.50/3.00	1.21/3.00/3.50				
	Periormance	(Min/Std/Max)		kW	3.08/9.38/11.72	3.22/11.72/14.07				
			Heating	Btu/h	10,500 / 32,000 / 40,000	11,000 / 40,000 / 48,000				
				US RT	0.88/2.67/3.33	0.92/3.33/4.00				
		Power Input	Cooling	kW	0.85 / 2.50 / 3.30	0.87 / 2.95 / 4.00				
		(Min/Std/Max)	Heating	KVV	0.68 / 2.84 / 4.70	0.77 / 3.35 / 5.30				
	Danna	Current Input	Cooling	Δ.	4.5 / 11.4 / 14.5	4.7 / 13.2 / 17.7				
	Power	(Min/Std/Max)	Heating	Α -	3.6 / 13.0 / 20.6	4.2 / 15.0 / 23.3				
		Command	MCA	А	31.7	33.1				
		Current	MFA	A	40	40				
			Cooling	-	3.52	3.58				
		EER	Cooling(US)	(Btu/h)/W	12.0	12.2				
	Efficiency	СОР	Heating	W/W	3.30	3.50				
		SEER		-	18.3	19.3				
System		HSPF		_	11.1	10.0				
				Туре	Flare	Flare				
		Liquid Pipe		Φ, mm(inch)	9.52 (3/8)	9.52 (3/8)				
				Type	Flare	Flare				
		Gas Pipe		Φ, mm(inch)	15.88 (5/8)	15.88 (5/8)				
	Pipe	Heat Insulation		φ, min(men) -	Both liquid and gas pipes	Both liquid and gas pipes				
	Connections	ricat insatation	Standard	m (ft)	7.5 (24.6)	7.5 (24.6)				
		Pipe Length	Max.	m (ft)	7.5 (24.6)	7.5 (24.0)				
		(ODU-IDU)	Elevation	m (ft)						
		(000-100)		m (ft)	30 (98.4) 7.5 (24.6)	30 (98.4) 7.5 (24.6)				
	Mising		Chargeless							
	Wiring	Communication	Min.	mm ²	0.75	0.75				
	Connections	-	Remark	-	F1,F2	F1,F2				
		Туре		-	R410A	R410A				
	Refrigerant	Factory Charging		kg	4.0	4.0				
		, , ,		lbs	8.82	8.82				
	Option Code	Standard		-	01B3FC-1C59B9-275A5E-370020	01B3FC-1C5933-276975-370045				
		Install		-	020010-120000-200000-300000	020010-120000-200000-300000				
	Power Supply	T=-		Ф,#,V,Hz	1,2,208-230,60	1,2,208-230,60				
		Туре	1	-	Fin & Tube	Fin & Tube				
	Heat	Material	Fin	-	Al	Al				
	Exchanger		Tube	-	Cu	Cu				
		Fin Treatment		-	Hydrophile	Hydrophile				
		Туре		-	Sirocco	Sirocco				
		Quantity	1	EA	3	3				
	E			m³/min	26/21.5/17	33/29/24				
	Fan	Air Flow Rate	H/M/L	ft³/min	918/759/600	1165/1024/848				
				l/s	433/358/283	550/483/400				
		External Static	Min/Std/Max	In Wg	0.10/0.58/0.79	0.12/0.58/0.79				
ndoor		Pressure Type		-	DI DC					
Init	Fan Motor	Output			BLDC 153	BLDC 244				
	Drain	Drain Pipe		W x n	OD26.67	0D26.67				
	Drain	Sound Pressure		Φ, mm	UDZU.0/	UDZ0.07				
	Cound		H/M/L	dB(A)	41/37/33	43/39/35				
	Sound		Level		/7					
		Sound Power Leve	21	dB(A)	63	65				
		Net Weight		kg(lbs)	35.0 (77.2)	44.0 (97.0)				
	F 1	Gross Weight		kg(lbs)	39.5 (87.1)	50.0 (110.2)				
	External	Net Dimensions (V	VxHxD)	mm	1,200 x 250 x 700	1,300 x 300 x 700				
	Dimension			inch	51.18 x 11.81 x 25.56	51.18 x 11.81 x 25.56				
		Gross Dimensions	(WxHxD)	mm	1,429 x 320 x 779	1,529 x 370 x 779				
		3.000 011110110110		inch	56.26 x 15.60 x 30.67	60.20 x 14.57 x 30.67				

1. Specification

Duct S

Model Na	mo	Indoor Unit			AC030BNHDCH/AA	AC036BNHDCH/AA			
nouel Na	me	Outdoor Unit			AC030BXSCCH/AA	AC036BXSCCH/AA			
S Code		Indoor Unit			CNH30HDB	CNH36HDB			
2 Code		Outdoor Unit			CXH30SCB	CXH36SCB			
	Casing	Material		-	Steel	Steel			
	Control	Infrared remote co	ontrol	-	AR-EH04U	AR-EH04U			
door	System	Wired remote con	trol	-	MWR-WG00UN/MWR-SH11UN	MWR-WG00UN/MWR-SH11UN			
Indoor Unit	D	Drain Pump		-	Included	Included			
ΊΤ	Drain Pump	Max.lifting Height / Di	splacement	in / gal/h	29.53 / 6.34	29.53 / 6.34			
	Additional Accessories	Air Filter		-	-	-			
	Power Supply			Ф,#,V,Нz	1,2,208-230,60	1,2,208-230,60			
	.17	Туре		-	Fin & Tube	Fin & Tube			
	Heat		Fin	-	Al	Al			
	Exchanger	Material	Tube	-	Cu	Cu			
		Fin Treatment		-	Green Hydrophile	Green Hydrophile			
	Compressor	Model		-	ATO420D1UNT1	ATO420D1UNT1			
	·	Туре		=	BLDC	BLDC			
		Output		kW	3.44	3.44			
		Oil	Type	=	POE	POE			
			Initial Charge	cc (fl oz)	1500	1500			
		Туре	'	-	Propeller	Propeller			
		Discharge direction	n	-	Front	Front			
	_	Quantity		EA	2	2			
	Fan			m³/min	125	125			
utdoor		Air Flow Rate	H/M/L	ft³/min	4,414	4,414			
nit				l/s	2,083	2,083			
	Fan Motor	Туре	'	-	BLDC	BLDC			
	Fall Motor	Output		Wxn	125 x 2	125 x 2			
		Sound Pressure	Cooling	dB(A)	49	49			
	Sound	Level	Heating	dB(A)	50	51			
		Sound Power Leve	el	dB(A)	67	69			
		Net Weight		kg(lbs)	100.0 (220.5)	100.0 (220.5)			
		Gross Weight		kg(lbs)	110.0 (242.5)	110.0 (242.5)			
	External	Net Dimensions (\	N^H^D)	mm	940 x 1,420 x 330	940 x 1,420 x 330			
	Dimension	INCC DIFFICUSIONS (WALIAD)	inch	37.01 x 55.91 x 12.99	37.01 x 55.91 x 12.99			
		Gross Dimensions	(WAHAD)	mm	mm 995 x 1,598 x 426 995 x				
		GLOSS DILLIGISIONS	(WXIIXD)	inch	39.17 x 62.91 x 16.77	39.17 x 62.91 x 16.77			
	Casing	Material	Body	-	Steel	Steel			
	Operating	Cooling		°C (°F)	-20~50 (-4~122)	-20~50 (-4~122)			
	Temp. Range	Heating		°C (°F)	-25~24 (-13~75)	-25~24 (-13~75)			

NOTE

- Specification may be subject to change without prior notice.
 1) Performances are based on the following test conditions.

 Cooling: Indoortemperature: 80°F(26.7°C) DB, 67°F(19.4°C) WB, Outdoortemperature: 95°F(35°C) DB, 75°F(23.9°C) WB
 Heating: Indoortemperature: 70°F(21.1°C) DB, 60°F(15.6°C) WB, Outdoortemperature: 47°F(8.3°C) DB, 43°F(6.1°C) WB
 Equivalent refrigerant piping length 5m(16.4ft), Level differences: 0m(0ft))

 Select wire size based on the value of MCA
 Sound pressure level is obtained in an anechoic room.

 Sound pressure level is a relative value, depending on the distance and acoustic environment.
 Sound pressure level may differ depending on operation condition.
 dBA = A-weighted sound pressure level / Reference acoustic pressure 0 dB = 20uPa

 Sound power level is an absolute value that a sound source generates.

 dBA = A-weighted sound power level
 Reference power: 1pW / Measured according to ISO 3741

 These products contain R410A which is fluorinated greenhouse gas.

2. Summary Table

Duct S

Performance Characteristics

Model Code	Net Weight		Capacity		Fan Speed	Airflow (Cooling/Heating)	Sound Pressure	Sound Power
модет соде	(lbs)		Cooling (Btu/h)	Heating (Btu/h)	ranspeed	(CFM)	Level (dBA)	Level (dBA)
CNH30HDB+CXH30SCB		Max.	36,000	40,000	High	918 / 918	41	63
(AC030BNHDCH/AA	77.2	Std.	30,000	32,000	Mid	759 / 759	37	-
+AC030BXSCCH/AA)		Min.	14,000	10,500	Low	600 / 600	33	-
CNH36HDB+CXH36SCB		Max.	42,000	48,000	High	1,165 / 1,165	43	65
(AC036BNHDCH/AA	97.0	Std.	36,000	40,000	Mid	1,024 / 1,024	39	-
+AC036BXSCCH/AA)		Min.	14,500	11,000	Low	848 / 848	35	=



NOTE • Sound data is based on cooling operation.

Electric Characteristics

Мо		Outdoor U	nit		Inp	ut Curren	Power Supply					
Indoor Unit	Outdoor Unit	Rated	Voltage	e rang	е	Outdo	or Unit	Indoor	Total	MCA(A)	MOD(A)	
indoor Unit	Outdoor Unit	Hz	Volts	Min.	Max	Cooling	Heating	Unit	Total	MCA(A)	MOP(A)	
CNH30HDB (AC030BNHDCH/AA)	CXH30SCB(AC030BXSCCH/AA)	60	208 to 230	187	253	29.57	29.57	2.10	31.67	31.7	40	
CNH36HDB (AC036BNHDCH/AA)	CXH36SCB(AC036BXSCCH/AA)	60	208 to 230	187	253	29.57	29.57	3.50	33.07	33.1	40	



- MCA: Minimum circuit amperes
- MOP: Maximum Overcurrent Protective Device
- Select wire size based on the value of MCA

3. Capacity Table

Duct S

(1) CNH30HDB(AC030BNHDCH/AA) + CXH30SCB (AC030BXSCCH/AA)

Cooling

TC: Total Capacity, SHC: Sensible Heat Capacity, PI: Power Input

Outdoor		Indoor Temperature (°F, DB / WB)																			
Temp.	68 / 57				72 / 61			77 / 64		80 / 67			82 / 70			86 / 72			90 / 75		
(°F, DB)	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
(F, DB)	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW
0	30.5	22.0	1.88	32.1	22.7	1.92	33.5	23.4	1.96	34.5	24.2	2.00	35.2	23.9	2.02	36.9	23.7	2.04	38.8	23.2	2.08
70	33.2	24.0	1.88	34.9	24.7	1.92	36.4	25.5	1.96	37.5	26.3	2.00	38.3	26.0	2.02	40.2	25.7	2.04	42.2	25.2	2.08
95	26.5	19.2	2.35	27.9	19.8	2.40	29.1	20.4	2.45	30.0	21.0	2.50	30.6	20.8	2.53	32.1	20.6	2.55	33.7	20.2	2.60
115	31.8	23.0	4.35	33.5	23.7	4.44	34.9	24.4	4.53	36.0	25.2	4.63	36.7	24.9	4.67	38.6	24.7	4.72	40.5	24.2	4.81
122	29.2	21.1	4.00	30.7	21.7	4.08	32.0	22.4	4.17	33.0	23.1	4.25	33.7	22.9	4.29	35.3	22.6	4.34	37.1	22.2	4.42

Heating

TC: Total Capacity, PI: Power Input

Outdoor	Indoor Temperature (°F, DB)												
Temperature	61		6	64		68		70		72		75	
(°F, DB)	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	
(۲, ۷۵)	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW	
-13	28.0	5.10	27.7	5.05	27.5	5.00	27.2	4.95	26.9	4.90	26.7	4.85	
-4	35.0	5.77	34.7	5.71	34.3	5.66	34.0	5.60	33.7	5.54	33.3	5.49	
14	36.3	5.12	35.9	5.07	35.6	5.02	35.2	4.97	34.8	4.92	34.5	4.87	
32	37.9	4.83	37.5	4.78	37.2	4.73	36.8	4.69	36.4	4.64	36.1	4.59	
47	33.0	2.93	32.6	2.90	32.3	2.87	32.0	2.84	31.7	2.81	31.4	2.78	
75.2	41.2	3.07	40.8	3.04	40.4	3.01	40.0	2.98	39.6	2.95	39.2	2.92	



• The performance table shows the average value of each conditions.

3. Capacity Table

Duct S

(2) CNH36HDB(AC036BNHDCH/AA) + CXH36SCB (AC036BXSCCH/AA)

Cooling

TC: Total Capacity, SHC: Sensible Heat Capacity, PI: Power Input

Outdoor	Indoor Temperature (°F, DB / WB)																				
Temp.		68 / 57			72 / 61			77 / 64			80 / 67			82 / 70			86 / 72			90 / 75	
(°F, DB)	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
(F, DD)	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW
0	35.0	25.3	2.36	36.9	26.1	2.41	38.4	26.9	2.46	39.6	27.7	2.51	40.4	27.4	2.53	42.4	27.2	2.56	44.5	26.6	2.61
70	39.8	28.7	2.50	41.9	29.6	2.55	43.7	30.6	2.60	45.0	31.5	2.66	45.9	31.2	2.68	48.2	30.9	2.71	50.6	30.3	2.76
95	31.8	23.0	2.78	33.5	23.7	2.83	34.9	24.4	2.89	36.0	25.2	2.95	36.7	24.9	2.98	38.6	24.7	3.01	40.5	24.2	3.07
115	33.4	24.1	4.39	35.2	24.9	4.48	36.7	25.7	4.57	37.8	26.5	4.66	38.6	26.2	4.71	40.5	25.9	4.75	42.5	25.4	4.85
122	30.3	23.4	4.03	31.8	24.1	4.11	33.2	24.9	4.19	34.2	25.7	4.28	34.9	25.4	4.32	36.6	25.1	4.36	38.5	24.6	4.45

Heating

TC: Total Capacity, PI: Power Input

Outdoor		Indoor Temperature (°F, DB)												
	61		64		68		70		72		75			
Temperature	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI		
(°F, DB)	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW		
-13	33.0	5.15	32.6	5.10	32.3	5.05	32.0	5.00	31.7	4.95	31.4	4.90		
-4	41.2	5.77	40.8	5.71	40.4	5.66	40.0	5.60	39.6	5.54	39.2	5.49		
14	43.3	5.35	42.8	5.30	42.4	5.24	42.0	5.19	41.6	5.14	41.2	5.09		
32	47.4	5.18	46.9	5.13	46.5	5.08	46.0	5.03	45.5	4.97	45.1	4.93		
47	41.2	3.45	40.8	3.42	40.4	3.38	40.0	3.35	39.6	3.32	39.2	3.28		
75.2	53.6	3.97	53.0	3.93	52.5	3.89	52.0	3.85	51.5	3.81	51.0	3.78		




• The performance table shows the average value of each conditions.

4. Dimensional Drawing

Duct S

CNH30HDB (AC030BNHDCH/AA)




NO	Name	Description
1	Liquid pipe connection	Φ9.52 mm(3/8")
2	Gas pipe connection	Φ15.88 mm(5/8")
3	Drain pipe connection	3/4"[OD26.67mm(1.05")]
4	Power supply connection	-
5	Air discharge flange	-
6	Airfilter	-
7	Hook	M8~M10

4. Dimensional Drawing

Duct S

CNH36HDB (AC036BNHDCH/AA)




NO	Name	Description
1	Liquid pipe connection	Φ9.52 mm(3/8")
2	Gas pipe connection	Φ15.88 mm(5/8")
3	Drain pipe connection	3/4"[OD26.67mm(1.05")]
4	Power supply connection	-
5	Air discharge flange	-
6	Airfilter	-
7	Hook	M8~M10

5. Center of Gravity

Duct S


Units : mm [inches]



Model	А	В	С	D	Е	F
CNH30HDB (AC030BNHDCH/AA)	700 [27-9/16]	265 [10-7/16]	1250 [49-3/16]	565 [18-5/16]	252 [9-15/16]	125 [4-15/16]
CNH36HDB (AC036BNHDCH/AA)	700 [27-9/16]	265 [10-7/16]	1350 [53-1/8]	650 [25-5/8]	301 [11-13/16]	150 [5-15/16]

6. Electrical Wiring Diagram

Duct S



MAIN PBA	Printed circuit board(MAIN)	EEV	Electronic Expansion Valve	ROOM (10K)	Thermistor ROOM in (10K)
EXT_CONTROL	EXTERNAL CONTROL	EVA-IN (10K)	Thermistor EVA IN(10K)	EVA-OUT (10K)	Thermistor EVA OUT(10K)
M-BLDC	BLDC Motor	DISCHARGE(10K)	Thermistor DISCHARGE		

NOTE

- This wiring diagram applies only to the Indoor unit.
- Symbols show as follow: blk: black, red: red, blu: blue, wht: white, yel: yellow, brn: brown, sky: skyblue: grn: green
- For connection wiring indoor-outdoor transmission F1-F2, indoor-wired remote controller transmission F3-F4.
- Protective earth(screw)

7. Sound Data

Duct S


Sound Pressure level

Unit: dB(A)


Discharge	Suction
Duct	Duct
2m	2m
i i	[E]
	<u></u>
	Microphone

Model	High	Mid	Low
CNH30HDB (AC030BNHDCH/AA)	41	37	33
CNH36HDB (AC036BNHDCH/AA)	43	39	35

- NC Curve
 - 1) CNH30HDB (AC030BNHDCH/AA)



2) CNH36HDB (ACO36BNHDCH/AA)



NOTE

- Specifications may be subject to change without prior notice.
 - Sound pressure level is obtained in an anechoic room.
 - Sound pressure level is a relative value, depending on the distance and acoustic environment.
 - Sound pressure level may differ depending on operation condition.
 - dBA = A weighted sound pressure level
 - Reference acoustic pressure 0 dB = 20μPa

7. Sound Data

Duct S


Sound Power level



- Specifications may be subject to change without prior notice
 - Sound power level is an absolute value that a sound source generates.
 - dBA = A-weighted sound power level.
 - Reference power: 1pW.
 - Measured according to ISO 3741.

• NC Curve


1) CNH30HDB (AC030BNHDCH/AA)



Unit: dB(A)

Model	Cooling
CNH30HDB (AC030BNHDCH/AA)	63
CNH36HDB (AC036BNHDCH/AA)	65


2) CNH36HDB (AC036BNHDCH/AA)





8. Temperature and air flow distribution


Duct S


CNH30HDB (AC030BNHDCH/AA)















8. Temperature and air flow distribution

Duct S


CNH30HDB (AC030BNHDCH/AA)




8. Temperature and air flow distribution


Duct S


CNH36HDB (AC036BNHDCH/AA)






	Exte	ernal Static P	ressure	(inWg)		Option Code						
\square		7.5 < F	9≤10	·		01B	3FC-10	54CE-	2769	75-370	0045	
External Static Pressure [inWg]	0.8 0.7 0.6 0.5	7.5 < F	- Upper extern	limit of - al pressure		01B	3FC-10	54CE-	<u>-</u>	75-370	0045	
ernal Si	0.3	- MID	~			_		>	-			
Ext	0.2	LOW			>	е	ower li external tatic pr		_			
	0	900 900 1	000 110				00 15	00 16	500			
			Air	Flow Rate	e [CI	M]						








8. Temperature and air flow distribution

Duct S

CNH36HDB (AC036BNHDCH/AA)



Multi-position AHU

41
43
44
46
47
48
50

1. Specification

Multi-position AHU

Model Na	ıme	Indoor Unit			AC030KNZDCH/AA	AC036KNZDCH/AA
		Outdoor Unit			AC030BXSCCH/AA	AC036BXSCCH/AA
US Code		Indoor Unit			CNH30ZDK	CNH36ZDK
		Outdoor Unit			CXH30SCB	CXH36SCB
	Mode			-	Heat Pump	Heat Pump
				kW	3.81/8.79/10.55	3.96/10.55/12.31
			Cooling	Btu/h	13,000 / 30,000 / 36,000	13,500 / 36,000 / 42,000
	Performance	Capacity		US RT	1.08/2.50/3.00	1.13/3.00/3.50
	Cironnance	(Min/Std/Max)		kW	2.93/9.38/11.72	3.08/11.72/13.19
			Heating	Btu/h	10,000 / 32,000 / 40,000	10,500 / 40,000 / 45,000
				US RT	0.83/2.67/3.33	0.88/3.33/3.75
		Power Input	Cooling	kW	0.87 / 2.29 / 3.30	0.90 / 2.93 / 4.10
		(Min/Std/Max)	Heating	KVV	0.72 / 2.73 / 4.70	0.76 / 3.53 / 5.00
	Power	Current Input	Cooling	Α	4.6 / 10.5 / 14.5	4.9 / 13.1 / 18.0
	I OWEI	(Min/Std/Max)	Heating		3.9 / 12.5 / 20.6	4.0 / 15.8 / 22.0
		Current	MCA	А	31.3	31.3
		Current	MFA	А	40	40
		EER	Cooling	-	3.84	3.60
		LLK	Cooling(US)	(Btu/h)/W	13.1	12.3
	Efficiency	COP	Heating	W/W	3.44	3.32
vetem		SEER		-	20.3	20.0
System		HSPF		-	10.6	10.4
		Liquid Pipe		Type	Flare	Flare
		Liquid Pipe		Φ, mm(inch)	9.52 (3/8)	9.52 (3/8)
		Can Dina		Type	Flare	Flare
	Dina	Gas Pipe		Φ, mm(inch)	15.88 (5/8)	15.88 (5/8)
	Pipe	Heat Insulation		=	Both liquid and gas pipes	Both liquid and gas pipes
	Connections		Standard	m (ft)	7.5 (24.6)	7.5 (24.6)
		Pipe Length	Max.	m (ft)	75 (246.0)	75 (246.0)
		(ODU-IDU)	Elevation	m (ft)	30 (98.4)	30 (98.4)
		, ,	Chargeless	m (ft)	7.5 (24.6)	7.5 (24.6)
	Wiring		Min.	mm ²	0.75	0.75
	Connections	Communication	Remark	-	F1,F2	F1,F2
	Connections	Туре	Kelliaik	-	R410A	R410A
	Refrigerant			kg	4.0	4.0
	Kerrigerant	Factory Charging		lbs	8.82	8.82
		Standard		-	01E06C-105020-275A64-370005	01E06C-105020-276470-370005
	Option Code	Install		_	020000-100000-200000-300000	020000-100000-200000-300000
	Power Supply	mstatt		Ф,#,V,Hz	1,2,208-230,60	1,2,208-230,60
	1 Ower Supply	Туре		Ψ,#, ۷,112	Fin & Tube	Fin & Tube
	Heat	Туре	Fin	_	Al	Al
	Exchanger	Material	Tube	-	Cu	Cu
	Exchanger	Fin Treatment	Tube	_	Green Hydrophile	Green Hydrophile
		Туре		_	Sirocco	Sirocco
		Quantity		EA	1	3110000
		Qualitity			28.5/26.0/24.0	33.0/29.5/25.0
	Fan	Air Flow Data	H/M/L	m³/min		
	T dir	Air Flow Rate	III/IVI/L	ft³/min	1006/918/848	1165/1042/883
		5		l/s	475/433/400	550/492/417
ndoor		External Static Pressure	Min/Std/Max	In Wg	0/0.24/0.98	0/0.24/0.98
Init		Type		_	ECM	ECM
	Fan Motor	Output		Wxn	410 x 1	410 x 1
	Drain	Drain Pipe		Φ, mm	FPT 3/4"	FPT 3/4"
	Sidili	Sound Pressure			· · · · · · · · · · · · · · · · · · ·	
	Sound	Level	H/M/L	dB(A)	41/38/35	42/39/36
	Sourid	Sound Power Leve	ما	dB(A)	59	60
		Net Weight	- t	kg(lbs)	56.0 (123.5)	56.0 (123.5)
		Gross Weight			62.0(136.7)	62.0(136.7)
	External	Gross weight		kg(lbs)		
		Net Dimensions (\	WxHxD)	mm	533 x 1,219 x 533	533 x 1,219 x 533
	Dimension			inch	20.98 x 47.99 x 20.98	20.98 x 47.99 x 20.98
		Gross Dimensions	(WxHxD)	mm	590 x 1,305 x 665	590 x 1,305 x 665
				inch	23.23 x 51.38 x 26.18	23.23 x 51.38 x 26.18

1. Specification

Multi-position AHU

Madal Na		Indoor Unit			AC030KNZDCH/AA	AC036KNZDCH/AA		
Model Na	ime	Outdoor Unit			AC030BXSCCH/AA	AC036BXSCCH/AA		
116.6.1		Indoor Unit			CNH30ZDK	CNH36ZDK		
US Code		Outdoor Unit			CXH30SCB	CXH36SCB		
	Casing	Material		-	Steel	Steel		
	Control	Infrared remote c	ontrol	-	AR-EH04U	AR-EH04U		
	System	Wired remote con	trol	-	MWR-WG00UN / MWR-SH11UN	MWR-WG00UN / MWR-SH11UN		
la da sa		Drain Pump		-	- · · · · · · · · · · · · · · · · · · ·	-		
Indoor	Drain Pump	Max.lifting Height / Di	splacement	in / gal/h	-	-		
Unit		Air Filter Base		, 5-,	VED 2 (MED) (0)	\(\(\text{LED 2 \langle \(\text{LED \langle 0 \rangle} \)		
	Additional	(option, for vercal in	stallation)	-	VFB-2 (MERV 8)	VFB-2 (MERV 8)		
	Accessories	Heater kit (option, se	NOTE E)		VHK-205A	VHK-205A		
		neater kit (option, se	e NOTE 5)	-	VHK-210A	VHK-210A		
	Power Supply	<u> </u>		Ф,#,V,Hz	1,2,208-230,60	1,2,208-230,60		
		Туре		-	Fin & Tube	Fin & Tube		
	Heat	Material	Fin	-	Al	Al		
	Exchanger	Material	Tube	-	Cu	Cu		
		Fin Treatment		-	Anti-Corrosion	Anti-Corrosion		
	Compressor	Model		-	ATQ420D1UNT1	ATQ420D1UNT1		
		Type		-	Twin BLDC	Twin BLDC		
		Output		kW	3.44	3.44		
		Oil	Туре	-	POE	POE		
			Initial Charge	cc (fl oz)	1500 (50.72)	1500 (50.72)		
		Туре	_	-	Propeller	Propeller		
		Discharge direction	on	-	Front	Front		
	_	Quantity		EA	2	2		
	Fan			m ³ /min	125	125		
Outdoor		Air Flow Rate	H/M/L	ft³/min	4,414	4,414		
Unit				l/s	2,083	2,083		
	E M.L.	Туре	_	-	BLDC	BLDC		
	Fan Motor	Output		Wxn	125 x 2	125 x 2		
		Sound Pressure	Cooling	dB(A)	49	49		
	Sound	Level	Heating	dB(A)	50	51		
		Sound Power Lev	el	dB(A)	67	69		
		Net Weight		kg(lbs)	100.0 (220.5)	100.0 (220.5)		
		Gross Weight		kg(lbs)	110.0 (242.5)	110.0 (242.5)		
	External			mm	940 x 1,420 x 330	940 x 1,420 x 330		
	Dimension	Net Dimensions (WXHXD)	inch	37.01 x 55.91 x 12.99			
		Caran Dianan i	(W.H.D)	mm	37.01 x 55.91 x 12.99 995 x 1,598 x 426	995 x 1,598 x 426		
		Gross Dimensions	(WXHXD)	inch	39.17 x 62.91 x 16.77	39.17 x 62.91 x 16.77		
	Casing	Material	Body	-	Steel	Steel		
	Operating	Cooling		°C (°F) -20~50 (-4~122) -20~50 (-4				
	Temp. Range	Heating		°C (°F)	-25~24 (-13~75)	-25~24 (-13~75)		



- Specification may be subject to change without prior notice.

 1) Performances are based on the following test conditions.

 Cooling: Indoortemperature: 80°F(26.7°C) DB, 67°F(19.4°C) WB, Outdoortemperature: 95°F(35°C) DB, 75°F(23.9°C) WB

 Heating: Indoortemperature: 70°F(21.1°C) DB, 60°F(15.6°C) WB, Outdoortemperature: 47°F(8.3°C) DB, 43°F(6.1°C) WB

 Equivalent refrigerant piping length 5m(16.4ft), Level differences: 0m(0ft))

 Select wire size based on the value of MCA

 Sound pressure level is obtained in an anechoic room.

 Sound pressure level is a relative value, depending on the distance and acoustic environment.

 Sound pressure level may differ depending on operation condition.

 dBA = A-weighted sound pressure level / Reference acoustic pressure 0 dB = 20uPa

 Sound power level is an absolute value that a sound source generates.

 dBA = A-weighted sound power level

 Reference power: 1pW / Measured according to ISO 3741

 These products contain R410A which is fluorinated greenhouse gas.

2. Summary Table

Multi-position AHU

Performance Characteristics

	Net		Capac	ity		Airflow	Cound Draggura Lavel	Cound Dower Lovel
Model Code	Weight (lbs)		Cooling (Btu/h)	Heating (Btu/h)	Fan Speed	(Cooling/Heating) (CFM)	Sound Pressure Level (dBA)	(dBA)
CNH30ZDK+CXH30SCB		Max.	36,000	40,000	High	1,006 / 1,006	41	59
(AC030KNZDCH/AA+	123.5	Std.	30,000	34,000	Mid	918 / 918	38	-
AC030BXSCCH/AA)		Min.	13,000	32,000	Low	848 / 848	35	-
CNH36ZDK+CXH36SCB		Max.	42,000	45,000	High	1,165 / 1,165	42	60
(AC036KNZDCH/AA+	123.5	Std.	36,000	40,000	Mid	1,042 / 1,042	39	-
AC036BXSCCH/AA)		Min.	13,500	10,500	Low	883 / 883	36	-



• Sound data is based on cooling operation.

Electric Characteristics

Мо	Model					Inp	ut Currer	es)	Power Supply		
la de en la it	Outdoor Unit	Rated	Voltage	range	е	Outdo	or Unit	Indoor	Tatal	MCA(A)	MOD(A)
Indoor Unit	Outdoor Unit	Hz	Volts	Min.	Max	Cooling	Heating	Unit	Total	MCA(A)	MOP(A)
CNH30ZDK (AC030KNZDCH/AA)	CXH30SCB (AC030BXSCCH/AA)	60	208 to 230	187	253	29.57	29.57	1.66	31.23	31.3	40
CNH36ZDK (AC036KNZDCH/AA)	CXH36SCB (AC036BXSCCH/AA)	60	208 to 230	187	253	29.57	29.57	1.66	31.23	31.3	40



• MCA: Minimum circuit amperes

• MOP: Maximum Overcurrent Protective Device

• Select wire size based on the value of MCA

3. Capacity Table

Multi-position AHU

(1) CNH30ZDK (AC030KNZDCH/AA) + CXH30SCB (AC030BXSCCH/AA)

Cooling

TC : Total Capacity, SHC : Sensible Heat Capacity, PI : Power Input

Outdoor								I	ndoor	or Temperature (°F, DB / WB)											
Temp.		68 / 57	1		72 / 61		77 / 64			80 / 67		82 / 70			86 / 72			90 / 75			
(°F, DB)	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
(F, DD)	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW
0	30.5	22.0	1.72	32.1	22.7	1.76	33.5	23.4	1.80	34.5	24.2	1.83	35.2	23.9	1.85	36.9	23.7	1.87	38.8	23.2	1.91
70	33.2	24.0	1.72	34.9	24.7	1.76	36.4	25.5	1.80	37.5	26.3	1.83	38.3	26.0	1.85	40.2	25.7	1.87	42.2	25.2	1.91
95	26.5	19.2	2.16	27.9	19.8	2.20	29.1	20.4	2.24	30.0	21.0	2.29	30.6	20.8	2.31	32.1	20.6	2.34	33.7	20.2	2.38
115	31.8	23.0	3.99	33.5	23.7	4.07	34.9	24.4	4.15	36.0	25.2	4.24	36.7	24.9	4.28	38.6	24.7	4.32	40.5	24.2	4.41
122	29.2	21.1	3.66	30.7	21.7	3.74	32.0	22.4	3.82	33.0	23.1	3.89	33.7	22.9	3.93	35.3	22.6	3.97	37.1	22.2	4.05

Heating

TC: Total Capacity, PI: Power Input

Outdoor					Indo	or Tempera	ature (°F, D	B)				
Temperature	ć	51	6	4	ć	58	7	0	72		7	5
(°F, DB)	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
(۲, ۵۵)	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW
-13	28.0	4.52	27.7	4.47	27.5	4.43	27.2	4.38	26.9	4.34	26.7	4.30
-4	35.0	5.31	34.7	5.26	34.3	5.20	34.0	5.15	33.7	5.10	33.3	5.05
14	38.5	4.92	38.2	4.87	37.8	4.83	37.4	4.78	37.0	4.73	36.7	4.68
32	40.3	4.64	39.9	4.60	39.5	4.55	39.1	4.50	38.7	4.46	38.3	4.41
47	35.0	2.81	34.7	2.78	34.3	2.76	34.0	2.73	33.7	2.70	33.3	2.68
75.2	43.8	2.95	43.4	2.92	42.9	2.90	42.5	2.87	42.1	2.84	41.7	2.81



• The performance table shows the average value of each conditions.

3. Capacity Table

Multi-position AHU

(2) CNH36ZDK (ACO36KNZDCH/AA) + CXH36SCB (ACO36BXSCCH/AA)

Cooling

TC: Total Capacity, SHC: Sensible Heat Capacity, PI: Power Input

Outdoor							Indoor Temperature (°F, DB / WB)														
Temp.		68 / 57			72 / 61		77 / 64				80 / 67		82 / 70		86 / 72				90 / 75		
(°F, DB)	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
(F, DD)	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW
0	35.0	25.3	2.34	36.9	26.1	2.39	38.4	26.9	2.44	39.6	27.7	2.49	40.4	27.4	2.52	42.4	27.2	2.54	44.5	26.6	2.59
70	39.8	28.7	2.48	41.9	29.6	2.53	43.7	30.6	2.58	45.0	31.5	2.64	45.9	31.2	2.66	48.2	30.9	2.69	50.6	30.3	2.74
95	31.8	23.0	2.76	33.5	23.7	2.81	34.9	24.4	2.87	36.0	25.2	2.93	36.7	24.9	2.96	38.6	24.7	2.99	40.5	24.2	3.05
115	33.4	24.1	4.36	35.2	24.9	4.45	36.7	25.7	4.54	37.8	26.5	4.63	38.6	26.2	4.68	40.5	25.9	4.72	42.5	25.4	4.82
122	30.3	23.4	4.00	31.8	24.1	4.08	33.2	24.9	4.16	34.2	25.7	4.25	34.9	25.4	4.29	36.6	25.1	4.33	38.5	24.6	4.42

Heating

TC: Total Capacity, PI: Power Input

Outdoor		Indoor Temperature (°F, DB)														
Temperature	6	51	64		6	8	7	0	7	'2	75					
•	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI				
(°F, DB)	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW				
-13	30.9	4.87	30.6	4.82	30.3	4.77	30.0	4.73	29.7	4.68	29.4	4.63				
-4	41.2	5.76	40.8	5.71	40.4	5.65	40.0	5.60	39.6	5.54	39.2	5.48				
14	43.3	5.64	42.8	5.58	42.4	5.53	42.0	5.47	41.6	5.42	41.2	5.36				
32	47.4	5.46	46.9	5.40	46.5	5.35	46.0	5.30	45.5	5.24	45.1	5.19				
47	41.2	3.64	40.8	3.60	40.4	3.57	40.0	3.53	39.6	3.49	39.2	3.46				
75.2	53.6	4.18	53.0	4.14	52.5	4.10	52.0	4.06	51.5	4.02	51.0	3.98				




• The performance table shows the average value of each conditions.

4. Dimensional Drawing

Multi-position AHU

CNH30ZD*(AC030*NZDCH/AA), CNH36ZD* (AC036*NZDCH/AA)


Units: mm [inches]



No.	Name	Description
1	Gas pipe connection	Ф15.88(5/8)
2	Liquid pipe connection	Ф9.52(3/8)
3	Drain pipe connection	FPT 3/4"
4	Air outlet	
5	Air intake	

5. Electrical Wiring Diagram

Multi-position AHU



CONTROL BOARD	Printed circuit board(MAIN)	MFSR	MEDIUM FAN SPEED RELAY	EVA-IN(10K)	Thermistor EVA IN
EX-T	EXTERNAL CONTROL	HFSR	HIGH FAN SPEED RELAY	EVA-OUT(10K)	Thermistor EVA OUT
LFSR	LOW FAN SPEED RELAY	ROOM(10K)	Thermistor ROOM	DISCHARGE(10K)	Thermistor DISCHARGE

NOTE

- This wiring diagram applies only to the indoor unit.
- Colors BLK: black, BRN: brown, SKY-BLU: sky-blue, GRN/YEL: green/yellow, RED: red, YEL: yellow, ORG: orange, BLU: blue, WHT:white
- For connection wiring indoor-outdoor transmission F1-F2, indoor-wired remotecontroller transmission F3-F4, refer to the installation manual
- Protective earth(screw)

6. Sound Data

Multi-position AHU


Sound Pressure level

Unit: dB(A)


Discharge F
Microphone Suction

Model	High	Mid	Low
CNH30ZDK (AC030KNZDCH/AA)	41	38	35
CNH36ZDK (AC036KNZDCH/AA)	42	39	36

- NC Curve
 - 1) CNH30ZDK (AC030KNZDCH/AA)



2) CNH36ZDK (AC036KNZDCH/AA)



■ NOTE

- Specifications may be subject to change without prior notice.
 - Sound pressure level is obtained in an anechoic room.
 - Sound pressure level is a relative value, depending on the distance and acoustic environment.
 - Sound pressure level may differ depending on operation condition.
 - dBA = A weighted sound pressure level
 - Reference acoustic pressure 0 dB = 20μPa

6. Sound Data

Multi-position AHU


Sound Power level

● NOTE

- Specifications may be subject to change without prior notice
 - Sound power level is an absolute value that a sound source generates.
 - dBA = A-weighted sound power level.
 - Reference power: 1pW.
 - Measured according to ISO 3741.

• NC Curve


1) CNH30ZDK (AC030KNZDCH/AA)



Unit: dB(A)

Model	Cooling
CNH30ZDK (AC030KNZDCH/AA)	59
CNH36ZDK (AC036KNZDCH/AA)	60


2) CNH36ZDK (AC036KNZDCH/AA)




7. Fan characteristics (P-Q Curve)

Multi-position AHU

CNH30ZD* (AC030*NZDCH/AA)



CNH36ZD* (AC036*NZDCH/AA)



T1	Low speed tap
T2	Medium-low speed tap
T3	Medium speed tap
T4	Medium-high speed tap
T5	High speed tap

Outdoor Units

1. Summary Table	52
2. Dimensional Drawing	53
3. Center of Gravity	54
4. Electrical Wiring Diagram	55
5. Sound Data	56
6. Capacity Correction	58
7. Operation Range	59
8. Piping Diagram	60

1. Summary Table

Outdoor Units

Performance Characteristics

Capacity	Madal Cada	Net Size	Net Weight	Airflow	Sound Pressu	Sound Power	
(Btu/h)	Model Code	(WxHxD inch)	(lbs)	(CFM)	Cooling	Heating	Level (dBA)
30,000	CXH30SCB(AC030BXSCCH/AA)	37.01 x 55.91 x 12.99	220.5	4,414	49	50	67
36,000	CXH36SCB(AC036BXSCCH/AA)	37.01 x 55.91 x 12.99	220.5	4,414	49	51	69




• Sound power level is based on cooling operation.

2. Dimensional Drawing

Outdoor Units

CXH30SCB (AC030BXSCCH/AA), CXH36SCB (AC036BXSCCH/AA)

Units: mm [inches]




No.	Name	Description
1	Refrigerant liquid pipe	Φ 9.52mm(3/8")
2	Refrigerant gas pipe	Φ 15.88mm(5/8")
3	Piping intake knockout hole	Front / Side / Rear / Bottom
4	Power wiring conduit	Front / Side / Rear , Φ 34mm(1-3/8")
5	Communication wiring conduit	Front / Side / Rear , Φ 22mm(7/8")
6	Drain Hole	Connect with the provided drain plug

3. Center of Gravity

Outdoor Units

CXH30SCB (AC030BXSCCH/AA), CXH36SCB (AC036BXSCCH/AA)


Units: mm [inches]



4. Electrical Wiring Diagram

Outdoor Units

CXH30SCB(AC030BXSCCH/AA),CXH36SCB(AC036BXSCCH/AA)



MAIN PCB	Printed circuit board(MAIN)	EEV	Electronic Expansion Valve
INVERTER PCB	Printed circuit board(INVERTER)	M-BLDC	BLDC Motor
EMI	Printed circuit board(EMI)	DIS-TH(200K)	Thermistor DISCHARGE
OLT-TH(200K)	Thermistor OLP	COND-TH(10K)	Thermistor CONDENSOR
OUT-TH(10K)	Thermistor AMBIENT		

NOTE

- This wiring diagram applies only to the outdoor unit.
- Colors blk: black, red: red, blu: blue, wht: white, yel: yellow, brn: brown, sky: skyblue
- When operating, don't shortcircuit the protection device (High Pressure switch)
- For connection wiring indoor-outdoor transmission F1-F2, outdoor-outdoor transmission OF1-OF2, refer to the installation manual.
- ☐ Protective earth(screw), ☐ : connector, → : The wire quantity

5. Sound Data

Outdoor Units


Sound Pressure level

Unit: dB(A)


	phone 1m
1.5m	Front

Model	Cooling	Heating
CXH30SCB (AC030BXSCCH/AA)	49	50
CXH36SCB (AC036BXSCCH/AA)	49	51

- NC Curve
 - 1) CXH30SCB (AC030BXSCCH/AA)



2) CXH36SCB (ACO36BXSCCH/AA)



NOTE

- Specifications may be subject to change without prior notice.
 - Sound pressure level is obtained in an anechoic room.
 - Sound pressure level is a relative value, depending on the distance and acoustic environment.
 - Sound pressure level may differ depending on operation condition.
 - dBA = A weighted sound pressure level
 - Reference acoustic pressure 0 dB = 20μPa

5. Sound Data

Outdoor Units

Sound Power level

NOTE

• Specifications may be subject to change without prior notice

- Sound power level is an absolute value that a sound source generates.


- dBA = A-weighted sound power level.

- Reference power: 1pW.

- Measured according to ISO 3741.

• NC Curve


1) CXH30SCB (AC030BXSCCH/AA)



Unit: dB(A)

Model	Cooling
CXH30SCB (AC030BXSCCH/AA)	67
CXH36SCB (AC036BXSCCH/AA)	69

2) CXH36SCB (AC036BXSCCH/AA)



6. Capacity Correction

Outdoor Units

CNH30*D*(AC030*N*DCH/AA)+CXH30SCB(AC030BXSCCH/AA) CNH36*D*(AC036*N*DCH/AA)+CXH36SCB(AC036BXSCCH/AA)

Cooling



	Pipe Length (ft)															
		24.6	32.8	49.2	65.6	82.0	98.4	114.8	131.2	147.6	164.0	180.4	196.9	213.3	229.7	246.1
	98.4	-	-	ı	-	-	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
	82.0	-	-	ı	-	0.97	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
	65.6	-	-	ı	0.97	0.97	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
	49.2	-	-	0.98	0.97	0.97	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
(£)	32.8	-	0.99	0.98	0.97	0.97	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
Level Difference	16.4	1.00	0.99	0.98	0.97	0.97	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
iffer	0.0	1.00	0.99	0.98	0.97	0.97	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
el D	-16.4	1.00	0.99	0.98	0.97	0.96	0.95	0.95	0.94	0.93	0.92	0.91	0.90	0.89	0.88	0.87
Lev	-32.8	-	0.98	0.98	0.97	0.96	0.95	0.94	0.93	0.93	0.92	0.91	0.90	0.89	0.87	0.85
	-49.2	-	-	0.97	0.97	0.96	0.95	0.94	0.93	0.92	0.91	0.90	0.89	0.88	0.86	0.84
	-65.6	-	-		0.96	0.95	0.95	0.94	0.93	0.92	0.91	0.90	0.89	0.88	0.86	0.83
	-82.0	-	-	-	-	0.95	0.94	0.93	0.93	0.92	0.91	0.90	0.88	0.87	0.85	0.81
	-98.4	-	-	-	-	-	0.94	0.93	0.92	0.91	0.90	0.89	0.88	0.86	0.84	0.80

Heating





	Pipe Length (m)															
		24.6	32.8	49.2	65.6	82.0	98.4	114.8	131.2	147.6	164.0	180.4	196.9	213.3	229.7	246.1
	98.4	•	-	-	-	-	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
	82.0	-	-	-	-	0.97	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
	65.6	-	-	-	0.97	0.97	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
	49.2	-	-	0.98	0.97	0.97	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
(£)	32.8	-	0.99	0.98	0.97	0.97	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
Level Difference	16.4	1.00	0.99	0.98	0.97	0.97	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
iffere	0.0	1.00	0.99	0.98	0.97	0.97	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
e D	-16.4	1.00	0.99	0.98	0.97	0.97	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
Lev	-32.8	-	0.99	0.98	0.97	0.97	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
	-49.2		-	0.98	0.97	0.97	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
	-65.6	1	-	-	0.97	0.97	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
	-82.0	1	-	-	-	0.97	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88
	-98.4	-	-	-	-	-	0.96	0.95	0.94	0.93	0.92	0.91	0.91	0.90	0.89	0.88

7. Operation Range

Outdoor Units

CXH**SCB (AC***BXSCCH/AA)

Mode	Indoor temperature Outdoor temperature		Indoor humidity
Cooling	18°C to 32°C (64°F to 90°F)	-20°C to 50°C (-4°F to 122°F)	80% or less
Drying	18°C to 32°C (64°F to 90°F)	-20°C to 50°C (-4°F to 122°F)	80% or less
Heating	30°C(86°F) or less	-25°C to 24°C (-13°F to 75°F)	-


■ NOTE

- The assumed installation conditions are follows
 - The pipe length(including elbow) is 7.5m(24.6ft).
 - The level difference is 0 m.

8. Piping Diagram

Outdoor Units


CNH304DB(AC030BN4DCH/AA)+CXH30SCB(AC030BXSCCH/AA) CNH364DB(AC036BN4DCH/AA)+CXH36SCB(AC036BXSCCH/AA)



8. Piping Diagram

Outdoor Units

CNH30HDB(AC030BNHDCH/AA)+CXH30SCB(AC030BXSCCH/AA) CNH36HDB(AC036BNHDCH/AA)+CXH36SCB(AC036BXSCCH/AA) CNH30HDK(AC030KNHDCH/AA)+CXH30SCB(AC030BXSCCH/AA) CNH36HDK(AC036KNHDCH/AA)+CXH36SCB(AC036BXSCCH/AA)



4 Way Cassette

Choosing the installation location

Installation location requirements

- There must be no obstacles near the air inlet and outlet.
- Install the indoor unit on a ceiling that can support its weight.
- Maintain sufficient clearance around the indoor unit.
- Before installing the indoor unit, be sure to check whether the chosen location is well-drained.
- The indoor unit must be installed such that it is beyond public access and is not touchable by users.
- A vibration-resistant location that is not inclined (If the indoor unit is installed on a structure that is not sturdy, it may fall and get damaged or cause injury.)
- Where it is not exposed to direct sunshine.
- Where the air filter can be removed and cleaned easily.

↑ CAUTION


- As a rule, the unit cannot be installed at a height of less that 8.2ft (2.5m).
- If you install a cassette type indoor unit on the ceiling when temperature is over 80.6°F (27°C) and humidity is over 80%, you must apply an extra 0.39inch (10mm) thick polyethylene insulation or a similar type of insulation to the body of the indoor unit.

Do not install the air conditioner in following places.

- A place with exposure to mineral oil, oil vapour or cooking area where there is spray (If oil adheres to the heat exchanger, performance degradation, spray or condensation scattering may occur. If oil adheres to a plastic component, the component may deform or get damaged. Such issues may result in a system failure or refrigerant leak.)
- The place where corrosive gas such as sulphuric acid gas generates from the vent pipe or air outlet.
- The copper pipe or connection pipe may corrode and refrigerant may leak.
- The place where there is a machine that generates electromagnetic waves. The air conditioner may not operate normally due to control system.
- The place where there is a danger of existing combustible gas, carbon fibre or flammable dust.
- The place where thinner or gasoline is handled. Gas may leak and it may cause fire.

Spacing requirements


4 way Cassette



Unit: inch(mm)


	AC030BN4DCH AC036BN4DCH
Α	13.19 (335)
В	0.67 (17)

4 Way Cassette



⚠ CAUTION

- The indoor unit must be installed according to the specified distances in order to permit accessibility from each side, to guarantee correct operation, maintenance, and repair of the unit.
 - The components of the indoor unit must be reachable and removable under safe conditions for people and the unit.
- Do not carry the unit by holding the refrigerant or drain pipes to avoid product damage.
- Carry the unit by holding the hanger plates located on the corners of the unit.




Optional: Insulating the body of the indoor unit

If you install a cassette type indoor unit on the ceiling when temperature is over 80.6 °F (27 °C) and humidity is over 80%, you must apply an extra 10 mm thick polyethylene insulation or a similar type of insulation to the body of the indoor unit.

Cut away the part where pipes are pulled out for the insulating work.

4 way Cassette



Insulate the end of the pipe and some curved area by using separate insulator.



• A: Reference for the outer circumference of the unit (When insulating the body of the indoor unit, use A as the reference for its outer circumference.)

4 way Cassette


Ind	oor unit	Α	В	С	D	E
4 way Cassette	AC030BN4DCH AC036BN4DCH					

4 Way Cassette

Installing the indoor unit


When deciding on the location of the air conditioner the following restrictions must be taken into account.

1 Place the pattern sheet on the ceiling at the location where you want to install the indoor unit.




NOTE

- Since the diagram is made of paper, it may shrink or stretch slightly due to temperature or humidity.
 For this reason, before drilling the holes, be sure to maintain the correct dimensions between the markings.
- 2 Insert bolt anchors, use existing ceiling supports or construct a suitable support as shown in figure.



3 Install the suspension bolts, depending on the ceiling type.



⚠ CAUTION


- Make sure that the ceiling is strong enough to support the weight of the indoor unit. Before hanging the unit, test the strength of each attached suspension bolt.
- If the length of the suspension bolt is more than 4.92ft(1.5m), vibration prevention is recommended. If this is not possible, create an opening on the false ceiling in order to be able to use it to perform the required operations on the indoor unit.
- **4** Screw eight nuts and washers to the suspension bolts, making space for hanging the indoor unit.

A CAUTION


- You must install all of the suspension rods.
- It is important to leave sufficient space in the false ceiling to allow access for maintenance or repairs to the drainage pipe connection, the refrigerant pipe connection, or to remove the unit if necessary.

4 Way Cassette

5 Hang the indoor unit to the suspension bolts between two nuts. Screw the nuts to suspend the unit.




- **6** Check the level of the indoor unit by using a Level.
 - A tilt of the indoor unit may cause malfunction of a built-in float switch and water leaks.



- **7** Adjust the unit to the appropriate position, taking into account the installation area for the front panel.
 - Place the pattern sheet on the indoor unit.
 - Adjust the space between the ceiling and the indoor unit by using a Tape measure.
 - Fix the indoor unit securely after adjusting the level of the unit by using a level.
 - Remove the pattern sheet and install the front panel.


When the installation template is made of paper

4 way Cassette




Installing the drain hose and drain pipe

- 1 Push the supplied drain hose as far as possible over the drain socket.
- 2 Tighten the metal clamp as shown in the picture.




- **3** Wrap the supplied large sealing pad over the metal clamp and drain hose to insulate and fix it with clamps.
- 4 Insulate the complete drain piping inside the building (field supply).
 If the drain hose cannot be sufficiently set on a slope, fit the hose with drain raising piping (field supply).
- **5** Push the drain hose up to insulation when connecting the drain hose to drain socket.

4 way Cassette




4 Way Cassette




A CAUTION

Check that the indoor unit is level with the ceiling by using by using a level.


• Install air ventilation to drain condensation smoothly.




• If it is necessary to increase the height of the drain pipe, install the drain pipe straight within 11.81 inch(300 mm) from the drain hose port. If it is raised higher than 21.65 inch (550 mm), there may be water leaks.




 Do not give the hose an upward gradient beyond the connection port. This will cause water to flow backwards when the unit is stopped, resulting in water leaks.



 Do not apply force to the piping on the unit side when connecting the drain hose. The hose should not be allowed to hang loose from its connection to the unit. Fasten the hose to a wall, frame or other support as close to the unit as possible.




• Install horizontally.




4 Way Cassette

• Max. allowable aixs gap




• Max. allowable bending angle



NOTE

 If a concentrated drain pipe is installed, refer to the figure below.




- If 3 or more units are installed, install a main air vent in front of the farthest indoor unit from the main drain pipe.
- To prevent water from flowing back to indoor units, install an individual air vent at the top of each indoor unit.
 - The air vents should be T or 7 shaped to prevent dust or foreign substances from entering.
 - You may not need to install an air vent if the horizontal drain pipe has a proper slope.

Connecting the power and communication cables

Bushing bracket installation

When connecting the power supply wire conduit, the supplied bracket must be installed as shown in the picture below.

4 way Cassette



NOTE

 Please follow national and local electrical codes. Additional electrical connection components may be required.


↑ CAUTION

- Always remember to connect the refrigerant pipes before performing the electric connections.
 When disconnecting the system, always disconnect the electric cables before disconnecting the refrigerant pipes.
- Always remember to connect the air conditioner to the grounding system before performing the electric connections.
 Use a crimp ring terminal at the end of each wire.

4 Way Cassette


The indoor unit is powered through the outdoor unit by means of a H05 RN-F connection cable (or a more power model), with insulation in synthetic rubber and a jacket in polychloroprene (neoprene), in accordance with the requirements specified in the standard EN 60335-2-40.

- 1 Remove the screw on the electrical component box and remove the cover plate.
- 2 Route the connection cord through the side of the indoor unit and connect the cable to the terminals refer to the figure below.
- **3** Route the other end of the cable to the outdoor unit through the ceiling & the hole on the wall.
- **4** Reassemble the electrical component box cover, carefully tightening the screw.




Indoor power supply								
Power supply Max/Min(V) Indoor power cable								
208 to 230V, 60 Hz	±10%	0.0012 inch² ↑ (0.75mm²↑), 3 wires						
Communication cable								
0.0012 inch² ↑(0.75mm²↑), 2 wires								

Unit: inch(mm)



Tightening torque lbf·ft (kgf • cm)					
M3.5	0.58 to 0.87 (8.0 to 12.0)				
M4	0.87 to 1.30 (12.0 to 18.0)				

- Power supply cords of parts of appliances for outdoor use shall not be lighter than polychloroprene sheathed flexible cord. (Code designation IEC:60245 IEC 57 / CENELEC: H05RN-F)
- Since it has the external power supply, refer to the outdoor unit installation manual for MAIN POWER.



A CAUTION

- When installing the indoor unit in a computer room or network room, use the double shielded communication cable (tape aluminum / polyester braid + copper) of FROHH2R type.
- Select the power cable in accordance with relevant local and national.
- Wire size must comply with local and national code.
- You should connect the power cable into the power cable terminal and fasten it with a clamp.
- The unbalanced power must be maintained within 10% of supply rating among whole indoor units.
- If the power is unbalanced greatly, it may shorten the life of the condenser. If the unbalanced power is exceeded by more than 10% of supply rating, the indoor unit will protect itself by stopping and displaying an error code.
- Connect the power cable to the auxiliary circuit breaker. An all pole disconnection from the power supply must be incorporated in the fixed wiring (≥0.12inch (3mm)).
- You must keep the cable in a protection tube.
- Maximum length of power cables are decided within 10% of power drop. If it exceeds, you must consider another power supplying method.
- The circuit breaker (MCCB, ELB) should be considered more capacity if many indoor units are connected from one breaker.
- Use round pressure terminal for connections to the power terminal block.
- For wiring, use the designated power cable and connect it firmly, then secure to prevent outside pressure being exerted on the terminal board.
- Use an appropriate screwdriver for tightening the terminal screws. A screwdriver with a small head will strip the head and make proper tightening impossible.
- Over-tightening the terminal screws may break them.

Duct


Spacing requirements


Space requirements for installation & service.

Construction Standard for Inspection opening

An inspection opening is required for service and unit replacement.


- 1) If the ceiling is a grid type, an inspection opening is not required.
- 2) If the ceiling is plaster board, an inspection opening is required. The size of the opening will vary based on the height inside the ceiling.
 - a. Height is more than 1.64ft (0.5m): Only "B" [Inspection for PBA] is applied.
 - b. Height is less than 1.64ft (0.5m): Both "A"&"B" are applied.
 - c. "A"&"B" are inspection opening.





- You must have 0.79 inch (20 mm) or more space between the ceiling and the bottom of indoor unit to prevent transmission of noise and vibration from the unit into the space.
- It is possible to install the unit at an height of between 7.2~8.2 ft (2.2~2.5m) from the ground, if the unit has a duct with a well defined length [11.81inch (300 mm) or more], to avoid fan motor blower contact.
- If you install the cassette or duct type indoor unit on the ceiling with humidity over 80%, you must apply extra 0.39 inch (10mm) of polyethylene foam or other insulation with similar material on the body of the indoor unit.

Optional: Insulating the body of the indoor unit



Thickness: more than 0.39 inch(10mm) Unit: inch(mm)

Indoor Unit	AC030BNHDCH	AC036BNHDCH		
Offic	47.24X27.56X9.84 (1200X700X250)	51.18X27.56X11.81 (1300X700X300)		
А	47.24X27.5 (1200X700)	51.18X27.56 (1300X700)		
В	47.24X27.5 (1200X700)	51.18X27.56 (1300X700)		
С	27.56X9.84 (700X250)	27.56X11.81 (700X300)		
D	27.56X9.84 (700X250)	27.56X11.81 (700X300)		
Front/Back Insulate the front and back side in proper size at the same time when insulating the suction duct and discharge duct.				




- Insulate the end of the pipe and some curved area by using separate insulator.
- Insulate the discharge and suction part at the same time when you insulate connection duct.

Duct

Installing the indoor unit


When deciding on the location of the air conditioner with the owner, the following restrictions must be taken into account

1 Place the pattern sheet on the ceiling at the spot where you want to install the indoor unit.




NOTE

- Since the diagram is made of paper, it may shrink or stretch slightly due to temperature or humidity. For this reason, before drilling the holes maintain the correct dimensions between the markings.
- 2 Insert bolt anchors. Use existing ceiling supports or construct a suitable support as shown in figure.



3 Install the suspension bolts depending on the ceiling type.




⚠ CAUTION

- Ensure that the ceiling is strong enough to support the weight of the indoor unit. Before hanging the unit, test the strength of each attached suspension bolt.
- If the length of suspension bolt is more than 4.92 ft (1.5m), it is required to prevent vibration.
- If this is not possible, create an opening on the false ceiling in order to be able to use it to perform the required operations on the indoor unit.

4 Screw eight nuts to the suspension bolts making space for hanging the indoor unit.



- You must install all the suspension rods.
- 5 Hang the indoor unit to the suspension bolts between two nuts.




♠ CAUTION

- Piping must be laid and connected inside the ceiling when suspending the unit. If the ceiling is already constructed, lay the piping into position for connection to the unit before placing the unit inside the ceiling.
- 6 Screw the nuts to suspend the unit.
- 7 Adjust level of the unit by using measurement plate for all 4 sides.

↑ CAUTION


For proper drainage of condensate, give a 0.118 inch (3mm) slant to the left or right side of the unit which will be connected with the drain hose, as shown in the figure. Make a tilt when you wish to install the drain pump, too.



 When installing the indoor unit, make sure it is not tilted toward front or back side.

↑ CAUTION


 Noise will increase 3~6 dB(A) when the air flow enters from the bottom side (Only for AC***BNLDCH indoor unit product).




Duct

Installing the drain hose and drain pipe

- 1 Push the supplied drain hose as far as possible over the drain
- 2 Tighten the metal clamp as shown in the picture.




- Wrap the supplied large sealing pad over the metal clamp and drain hose to insulate and fix it with clamps.
- 4 Insulate the complete drain piping inside the building (field supply). If the drain hose cannot be sufficiently set on a slope, fit the hose with drain raising piping (field supply).
- Push the drain hose up to insulation when connecting the drain hose to drain socket.



Without the drain pump

- 1 Install horizontal drainpipe with a slope of 1/100 or more and fix it by hanger space of 3.28~4.92ft(1~1.5m).
- 2 Install U-trap at the end of the drainpipe to prevent a nasty smell to reach the indoor unit.
- Do not install the drainpipe to upward position. It may cause water flow back to the unit.



With the drain pump


- The drain pipe should be installed within 11.81inch(300mm) to 21.65inch(550mm) from the flexible hose and then lift down 0.79inch(20mm) or more.
- Install horizontal drainpipe with a slope of 1/100 or more and fix it by hanger space of 3.28~4.92ft(1~1.5m).
- 3 Install the air vent in the horizontal drainpipe to prevent water flow back to the indoor unit.



- You may not need to install it if there were proper slope in the horizontal drainpipe.
- The flexible hose should not be installed upward position, it may cause water flow back to the indoor unit.


Centralized drainage without the drain pump

- Install horizontal drainpipe with a slope of 1/100 or more and fix it by hanger space of 3.28~4.92ft(1~1.5m).
- Install U-trap at the end of the drainpipe to prevent a nasty smell to reach the indoor unit.



Centralized drainage with the drain pump

- Install main air vent at the front of the farthest indoor unit from the main drain when installed indoor units are more than 3.
- You may need to install individual air vent to prevent water flow back at the top of each indoor unit drainpipe.



Duct

Connecting the power and communication cables

A CAUTION

Always remember to connect the refrigerant pipes before performing the electric connections. When disconnecting the system, always disconnect the electric cables before disconnecting the refrigerant pipes.


⚠ CAUTION

Always remember to connect the air conditioner to the grounding system before performing the electric connections. Use a crimp ring terminal at the end of each wire.

The indoor unit is powered through the outdoor unit by means of a H05 RN-F connection cable (or a more power model), with insulation in synthetic rubber and a jacket in polychloroprene (neoprene), in accordance with the requirements specified in the standard EN 60335-2-40.

- 1 Remove the screw on the electrical component box and remove the cover plate.
- 2 Route the connection cord through the side of the indoor unit and connect the cable to the terminals refer to the figure below.
- 3 Route the other end of the cable to the outdoor unit through the ceiling & the hole on the wall.
- 4 Reassemble the electrical component box cover, carefully tightening the screw.

AC***BNHDCH






NOTE

Terminal Block of the outdoor unit may be different from the diagram depending on the model. Refer to the manual of the outdoor unit for the configuration of the terminal block of the outdoor unit.

Indoorpowersupply							
Power supply	Max/Min(V)	Indoor power cable					
208 to 230V, 60 Hz	±10%	0.0023 inch² ↑ (1.5mm² ↑), 3 wires					
Communication cable							
0.0012 inch ² ↑ (0.75mm ² ↑), 2 wires							

Duct

AC***BNHDCH




Tightening torque lbf-ft (kgf • cm)						
M3.5	0.58 to 0.87 (8.0 to 12.0)					
M4	0.87 to 1.30 (12.0 to 18.0)					

- Power supply cords of parts of appliances for outdoor use shall not be lighter than polychloroprene sheathed flexible cord.
 - -Code designation

[1-phase] IEC: 60245 IEC 57 / CENELEC: H05RN-F grade or more


 Be sure to run the power supply cable and the communication cable through electrical conduit as seen in the picture.

AC***BNHDCH



∴ CAUTION

- Be sure not to put your finger into the conduit.
- Since it has the external power supply, refer to the outdoor unit installation manual for MAIN POWER.



A CAUTION

• When installing the indoor unit in a computer room or a server room, use the double shielded communication cable (tape aluminum / polyester braid + copper) of FROHH2R type.

Multi-position AHU

Selecting the installation location

Decide the installation location, with the consideration of the following conditions, under user's approval.

- · Place where airflow is not disturbed.
- Place on flat surface where the structure can bear the weight and vibration of the indoor unit. (If the structure is not strong enough, indoor unit may fall and be damaged or cause personal injury.)
- Place where sufficient space can be guaranteed for maintenance and other services.
- Place where condensation can be drained easily.
- Place that allows refrigerant pipe connection within allowable distance.
- Place where indoor unit will not be exposed to direct sunlight.
- Place that can keep the distance of at least 3.28 ft (1 m) between power/communication cable and any electronic devices (depending on the circumstances, problem may occur even if you secure 3.28 ft (1 m) of distance).


Indoor unit installation

Refrigerant pipe work must be done before installing the indoor unit.

Location

Access for servicing is an important factor in the location of any air handler. Provide a minimum of 30 inches in front of the appliance for access to the control box, heating elements, blower and air filters. This access may be provided by a closet door or by locating the appliance so that a wall or partition is not less than 30 inches from the front access panel. Location is usually predetermined. Refer to figure below. Check with owner's or dealer's installation plans. If location has not been decided, consider the following in choosing a suitable location.

- Select a location with adequate structural support, space for service access, and clearance for return and supply duct connections
- 2. Normal operating sound levels may be objectionable if the air handler is placed directly over or under some rooms such as bedrooms, study, etc.
- Caution should be taken to locate the unit so that supply and return air ducts are about the same length causing even air distribution of supply and return air to and from the living spaces.
- Locate appliance where electrical supply wiring can be easily routed to main electrical panel and where electrical wiring will
 not be damaged.
- 5. Locate appliance where control wiring can be easily routed to the controller and where the wiring will not be damaged.
- 6. Locate appliance where refrigerant lines can be easily routed from the evaporator coil to the system.
- 7. Locate the appliance where condensate lines can be easily routed to an available drain. Be sure to route condensate drain piping so as not to obstruct access to the air filter.
- 8. The coil is installed in a draw-thru application and will create a negative pressure situation in the condensate drain system. To prevent condensate from being drawn into the blower it is recommended to trap the primary (Main) and secondary (Overflow) drain line. Refer to Drain Pipe and Drain Hose section in these instructions. If the secondary drain is not used, it must be capped. This unit has a connection terminal for drain system monitoring. Refer to Wiring Work section for information regarding connection of field-provided condensate overflow devices in these instructions.
- 9. The draw-thru design will cause exterior surface of cabinet to sweat when unit is installed in a non-conditioned space such as an attic or garage. Installer must provide protection such as full size auxiliary drain pan on all units installed in a non-conditioned space to prevent damage from condensation runoff. Some states, cities and counties require additional insulation to be installed on the exterior casing of the air handler to prevent sweating. Refer to the state, city, county or local code for insulation requirement to be sure the installation is in compliance. It is recommended that air handlers installed in non-conditioned spaces be insulated on the exterior of the entire cabinet, including the front access panel with one (1) inch thick fiberglass with the vapor barrier on the outside.
- 10. Ensure sufficient space for the bottom of the product (H dimension) so that a downward slope of 1/100 can be maintained for drain piping, as described for the intake duct installation and in "Drain pipe installation".




Multi-position AHU

This appliance is approved for zero (0) inches clearance to combustible material on any part of the air handler exterior casing and the inlet or outlet ducts providing NO electric heater is being used. There is a one (1) inch clearance on the supply plenum and supply air duct when an electric heater is installed in the appliance. Refer to Table below for clearance to combustibles information.

Tan (inches)	Dagle (inches)	Sides (inches)	Front	of unit	Duct (inches)
Top (inches)	Back (inches)	Sides (Iliches)	Alcove (inches)	Closet (inches)	Duct (Iliches)
0	0	0	30	6	1*

^{*} when electric heat kit accessory is installed

Return air requirements



Return Air Requirements

In order for the air handler to work properly, a closet or alcove must have a certain total free area opening for the return air.

For A/C and HP Air Handlers 1/3 HP Blower Motor

Minimum 200 in² free area opening

• Use Return Grille that can supply sufficient air to ensure proper performance.


For A/C and HP Air Handlers 1/2 HP Blower Motors

- Minimum 250 in² free area opening
- Use Return Grille that can supply sufficient air to ensure proper performance.

For A/C and HP Air Handlers with Electric Heat use 3/4 HP Blower Motor

- Minimum 390 in² free area opening
- Use Return Grille that can supply sufficient air to ensure proper performance.

The return air opening can be located in the floor, on a closet front door or in a side wall above the air handler casing. If opening for the return air is located in the floor, side walls, or closet door anywhere below the appliance casing, a 6 inch minimum clearance between the appliance and the wall or door must be provided on the side where the return is located to provide for proper air flow. The 6 inch minimum clearance is not required if there is a return grille installed above the appliance casing, providing the grille has a sufficient return air opening.



Typical Closet Installations

Provisions shall be made to permit the air in the rooms and the living spaces to return to the air handler. Failure to comply may cause a reduction in the amount of return air available to the blower, causing reduced air flow resulting in improper heating and cooling of the living space. The reduced air may cause the air flow handler to cycle on the limit causing premature heating element failure (if electric heat kits are installed).


Upflow Accessory Filter Box Kit

An accessory filter box kit can be used on the return air end of the air handler when configured in the upflow position. The filter kit is placed over the return plenum in the floor and sealed to the plenum using sealant or caulking material and/or tape. The air handler is placed on top of the return filter box and the return opening sealed to prevent leaks.

Multi-position AHU



Make sure the flow arrow on the air filter is pointing towards the coil.



Accessory Air Filter Box for 1" or 2" Air Filters. Filter Size Adjustment knob is on both sides.

FILTER BASE ASSEMBLY KIT MODEL NUMBERS - FIELD INSTALLED, PURCHASED SEPARATELY


VFB-1 - 16" X 20" X 2" Small Cabinet (12/18/24K)

VFB-2 - 20" X 20" X 2" Medium Cabinet (30/36K)

VFB-3 - 20" X 24" X 2" Large Cabinet (42/48K)

Arrangement:

Unit is shipped from the factory arranged to be installed in an upflow or horizontal left (right to left air flow) position. Horizontal left means when the unit is laid on its side and you are facing the unit, the supply air opening is to the left and the return opening is to the right. These models are field convertible to a horizontal right (left to right) air flow position.



Upflow application

In an upflow installation the discharge outlet is at the top. Care should be taken to insure unit is level to permit proper condensate drainage. Normal upflow installation will be in a closet or basement. If installed in a closet, it must have a platform framed in. The platform must have an opening centered in the closet that measures at least 12 inches in height from the floor. A filter frame and filter can be used that covers the opening and is sealed to prevent air by-passing the filter. A filter grille can be used that is located as described in RETURN AIR REQUIREMENTS section. The minimum filter size is shown in the table below.

Standard throw away air filter @ 300 ft/min or less	Pleated Air Filter @ 500 ft/min or less
800 CFM = 20 x 20 x 1	800 CFM = 16 x 16 x 1
1000 CFM = 20 x 25 x 1	1000 CFM = 18 x 20 x 1
1200 CFM = 20 x 30 x 1	1200 CFM = 20 x 20 x 1
1400 CFM = 25 x 30 x 1	1400 CFM = 20 x 20 x 1
1600 CFM = 25 x 30 x 1	1600 CFM = 20 x 25 x 1
1800 CFM = 30 x 30 x 1	1800 CFM = 20 x 30 x 1 or two 20 x 15 x 1
2000 CFM = 30 x 40 x 1 or two 30 x 20 x 1	$2000 \text{ CFM} = 20 \times 30 \times 1 \text{ or two } 20 \times 15 \times 1$
2400 CFM = 30 x 40 x 1 or two 30 x 20 x 1	2400 CFM = 25 x 30 x 1 or two 14 x 30 x 1

Another option is to use the Filter Base Accessory Kit. This filter base is placed on the closet floor and secured with screws. The unit is placed on top of the filter base and secured to the base with screws. Use seal strip, tape or calking to seal between the unit and the base.


Connect the supply air outlet to a plenum to the top of the unit and secure it with screws. Use a Non-tape sealant such as mastic or an aerosol sealant to seal duct leakage. If installed in a basement, run supply and return duct work in accordance with local codes. Use a Non-tape sealant such as mastic or an aerosol sealant to seal duct leakage.

Multi-position AHU

Horizontal application

Horizontal applications will normally be used in an attic or crawl space. This type of installation requires supply air plenum or duct to be connected to the supply collar and a return air plenum or duct be attached to the unit inlet collar. The supply ducts will be connected to the supply air plenum and routed through the attic to a register in each room. Use a Non-tape sealant such as mastic or an aerosol sealant to prevent leaks in the ducts and the plenum.


The opposite end of the return air duct is attached to a return filter grille housing. The filter grille is usually located in a wall, just below the ceiling or the ceiling in a hallway. Use a Nontape sealant such as mastic or an aerosol sealant to prevent leaks in the ducts and the plenum.



Horizontal right application (left to right)

The unit is shipped to be installed without modification in a right to left configuration. For left to right applications:

- 1. Remove the unit access panels
- 2. Remove the cooling coil after disassembling bracket coil and plate.
- 3. Move the condensate drain pan to the right side of the unit chassis.
- 4. Move the Evap In temperature sensor to holder of the right side.
- 5. Reinstall the cooling coil.
- 6. Connect the condensate drains and refrigerant lines. DRY NITROGEN MUST BE FLOWED THROUGH REFRIGERANT LINES DURING SOLDERING OPERATION.
- 7. Reinstall unit access panels.
 - * In all horizontal applications in which the unit is installed above a finished ceiling and/or living space, it is recommended that a secondary drain pan (field supplied) is installed under the entire unit to avoid damage to the ceiling in the event of condensate overflow.



Closet installation

Prior to installing the air handler make sure holes are cut into the floor for refrigerant tubing, drain line, electrical wiring, and control wiring.

- 1. Remove the top shipping cover and corner posts.
- 2. Remove the bottom shipping cover.
- 3. Remove the blower and control box access panel (door).
- 4. Remove the coil compartment access panel (door).
- 5. Place the unit into position by sliding the unit over the duct opening until the opening in the unit lines up with the duct opening in the floor.
- 6. Secure the unit to the floor by drilling two holes through the air handler base at the left and right front inside corners of the cabinet. Use two screws to secure the unit to the floor.
- 7. Use calking, sealers, and/or tape to seal between the floor base and the opening on the unit or between the opening on the unit and the duct in the floor.
- 8. Connect the electrical supply wires and the control wires in the control box.
- 9. Connect the refrigerant lines to the coil. DRY NITROGEN MUST BE FLOWED THROUGH REFRIGERANT LINES DURING SOLDERING OPERATION.
- 10. Re-install the coil compartment access panel (door) and secure with the screws that were removed in step 3.
- 11. Re-install the blower and control box access panel (door) and secure with the screws that were removed in step 2.

Multi-position AHU

Air Handlers with DX type evaporator coils require liquid and suction piping sized in accordance with condensing unit manufacturer's instructions. The evaporator coils have sweat copper connections. Refrigerant lines should be soldered with silver solder or high temperature brazing alloy.

DRY NITROGEN MUST BE FLOWED THROUGH REFRIGERANT LINES DURING SOLDERING OPERATION.

REFER TO OUTDOOR UNIT INSTALLATION MANUALS FOR PRESSURE CHECKING AND VACUUM DRYING PROCEDURES.

There are two refrigerant pipes of differing diameters:

- A smaller one for the liquid refrigerant
- A larger one for the gas refrigerant
- The inside of copper pipe must be clean & have no dust.

Prepare the connecting pipe referring to the list below.


· Refrigerant pipe diameters

Unit: inch(mm)

	AC030/036*NZDCH
Liquid pipe	3/8 (9.52)
Gas pipe	5/8 (15.88)

Drain pipe installation

The air handler "A" coil drain pan has two ¾" NPT (Φ19.05mm) female primary and two secondary connections (left or right hand). The horizontal pan has two ¾" NPT (Φ19.05mm) female, one primary and one secondary. Piping from each fitting used is to have 2 inch (50.8mm) minimum trap and each run in such a manner as to provide enough slope for adequate drainage to a visible area. Do not pipe these two fittings together into a common drain. Prime drain with water before operating the unit by pouring water into the condensate pan. Cap unused connections.





- Make sure to keep the drain hose from getting tangled or loosened (on the connection part).
- Insulate all condensate pipes connected to the indoor unit to prevent condensation formation.
 Condensate formation on condensate pipes can lead to property damage and unsafe environment conditions.

When passing the drain hose through the hole drilled in the wall, make sure to avoid following cases.



- Since the draining is of natural drain type, install the drain hose in downward direction.
- If you do not tie the drain hose with a cable tie, leakage may occur
- Drain pipe may get clogged if there is any foreign substances within the drain pan, so you must remove any foreign substances after completing the installation.

Multi-position AHU

Wiring Work




- For personal safety be sure to turn the electrical power "OFF" at the main entrance (Home Circuit Breaker Box) and at the unit control box circuit breakers before attempting any service or maintenance operations. Homeowners should never attempt to perform any maintenance which requires opening the air handler control box door.
- This air handler is not equipped with a shield that covers the line voltage electrical supply wires and the circuit breaker connections. Take precautions to prevent accidental electrical shock. Be sure to turn the electrical power "OFF" at the main entrance (Home Circuit Breaker Box) and at the control box circuit breakers before removing the front panel.

Power supply wiring

- The unit internal wiring is complete except for the power supply and control wires.
- The use of cable connectors on incoming power supply wires to relieve any strain on wiring is recommended.
- Follow the steps below to connect the power supply wires.
- Supply voltage is 208/230V, 1ø, 60 Hz.
- If you are installing optional heat kits, refer to the heat kit installation instructions for line voltage connection instructions

Wiring diagram



Outdoor Unit


Between Indoor and Outdoor Connection cable Specifications(Common in use)


Power Supply	Max/Min(V)	Indoor Power cable	Communication Cable
208~230V/60Hz	±10%	0.0039in ² ↑,3wires (2.5mm ² ↑,3wires)	0.0012 inch ² ↑, 2 wires (0.75mm ² ↑, 2 wires)

- Selecting wire size must comply with local and national code.
- Power supply cords of parts of appliances for outdoor use shall not be lighter than polychloroprene sheathed flexible cord. (Code designation IEC:60245 IEC 57 / CENELEC: H05RN-F)
- Screws on terminal block must not be unscrewed with the torque less than 12 kgf•cm (0.86 lbf•ft).
- Since it has the external power supply, refer to the outdoor unit installation manual for MAIN POWER.

Multi-position AHU

Terminal Block SPEC (Indoor)






Wiring Work

Single circuit line wiring connections



If an accessory heat kit is installed, power must enter the unit on the top or the top-left side of the unit as shown below (A).

- 1. Before wiring work, you must turn off all power source.
- 2. Only copper power cables should be used.
- 3. Remove the blower and control box access panel (door).
- 4. Install the cable connectors on the 7/8" diameter holes on the right side of the control box.
- 5. Insert the wires through the holes in the casing and through the cable connectors.
- 6. Connect the black supply wire to the L1[1(L)] high voltage connection terminal with compressed ring terminals.
- 7. Connect the white supply wire to the L2[2(N)] high voltage connection terminal with compressed ring terminals.
- 8. Connect the green wire to the ground lug near the supply wire connections with a compressed ring terminal and tighten the ground screw. Make sure to leave extra slack in the ground wire to allow service to the unit without disconnecting the ground wire.



- installing accessory electric heat kit).
- B Power conduit connection opening (do not use when installing accessory electric heat kit).
- C Communication wire conduit connection opening


IMPORTANT - All insulation on field wiring must be rated at 140°F (60°C) or higher. Please refer to the wiring diagrams on the air handler or the tables in this manual for more information.


IMPORTANT - Refer to the NEC National Electrical Code (NFPA 70) or the Canadian Electrical Code, Part I (CSA C22.1) and local codes for wiring material requirements.

Multi-position AHU


Power supply wiring with accessory electric heat kit

- 1. Before wiring work, you must turn off all power source.
- 2. Only copper power cables should be used.
- 3. Remove the blower and control box access panel (door).
- 4. Install the cable connectors on the 7/8" diameter holes on the left side of the control box.
- Connect the included power pigtail leads with ring connectors (included with heat kit) to 1(L) and 2(N) terminals located on the right side of the control box.
- Route the power pigtail leads through the control box opening pictured below and route to the left side of the control box for connection to the heat breakers in a later step.





- 7. Swing the hinged control plate outward exposing the back side of the control box. Remove the screws holding the electric heat kit block off plate. Save the screws.
- 8. Carefully pass the accessory heating element through the rectangular opening in the discharge of the air handler and secure the heating element with the screws from step 8. Heating element support rod must be seated in the hole on the opposite side of the discharge.




- 9. Install the breakers at the front-left of the control box.
- 10. Connect the power pigtail leads that are connected to 1(L) and 2(N) to the bottom of the breakers.
- 11. Insert the power wires through the holes in the casing and through the cable connectors.
- 12. In order to use heating function, you need change the installation option code. Set SEG10 to 1. For more information on changing the option code, refer to "Setting an indoor unit installation option".

Power supply wiring with accessory electric heat kit


- 13. Strip 1/2" of the insulation on the end of each power wire.
- 14. Connect the black supply wire to the high voltage connection lug on the accessory heat kit breaker.
- 15. Connect the white supply wire to the other high voltage connection lug on the accessory heat kit breaker.

Multi-position AHU

16. Connect the green (ground) wire to the ground lug to the left of the accessory heat kit breakers and tighten the ground lug screw. Make sure to leave extra slack in the ground wire to allow service to the unit without disconnecting the ground wire. If the heat kit requires 2 circuits (dual circuit), both circuit ground wires must be connected to a ground lug (dual circuit kits have two individual ground lugs).



- 17. Connect the six pin male plug on the electric heater assembly to the six pin female plug mounted at the bottom of the control assembly door.
- 18. Remove the wiring diagram from the accessory heat kit. Remove the paper that covers the adhesive back and place the electric heat wiring diagram over the wiring diagram located on the blower housing.
- 19. Route temperature sensor from the accessory electric heat kit to the lower section of the AHU cabinet. Attach the sensor to the bottom of the liquid pipe as shown below with included wire ties.



- 20. Wrap included insulation around the sensor and secure with included wire ties.
- 21. Remove the breaker opening cover plate on the AHU door and secure the doors to the unit.

NOTE: The electric heat kits are equipped with either one or two circuit breakers. These circuit breakers protect the wiring inside of the AHU in the event of a short circuit. Additionally, these breakers provide a means of disconnecting the power to the unit. The circuit breakers in the AHU's are not meant to protect the branch circuit wiring between the furnace and the building's breaker panel. If sheathed cable is used, refer to NEC National Electrical Code (NFPA 70) or the Canadian Electrical Code, Part I (CSA C22.1) and local codes for additional requirements concerning supply circuit wiring. Electrical data can be found in page 21.

IMPORTANT - All installation on field wiring must be rated at 60°C or higher. Please refer to the wiring diagrams on the furnace or the tables this manual for more information. The 15kW and 20kW models may be connected to a single or dual branch circuit. Refer to the NEC National Electrical Code (NFPA 70) or the Canadian Electrical Code, Part I (CSA C22.1) and local codes for wiring material requirements.

Multi-position AHU

Power supply connections

If the air handler has been installed prior to installing the electric heaters or if an older unit is being replaced, the supply power wires must be checked to make sure the wires are the proper sizes to handle the current load for the heaters. Refer to table below for correct wire size. If the supply power wire size is incorrect, new wires will need to be installed. Follow the instructions "Power supply wiring" of these instructions for proper installation.

	ELECTRICAL DATA																				
	Electric Heater Data					Minimum Circuit Ampacity (MCA)			Maximum Overcurrent Protection (MOCP)			Minimum Wire Size (AWG)			Short-0 Current						
				Amps		Amps	208V	208V	240V	240V	208V	208V	240V	240V	Circu	it 1	Circu	ıit 2	"SCC	R"	
Indoor Unit			208V	208V	240V	240V	2001	2001	2400	2401	(3,4)	(3,4)	(3,4)	(3,4)							
Model			Kw (2)	Circuit 1	Circuit 2	Circuit 1	Circuit 2	Circuit 1	Circuit 2	Circuit 1	Circuit 2	Circuit 1	Circuit 2	Circuit 1	Circuit 2	167°F (75°C) / 194°F (90°C)	140°F (60°C)	167°F (75°C) / 194°F (90°C)	140°F (60°C)	kA rms symmetrical	V maximum
						ME	DIUM C	ABINE	Γ-NOMI	NAL 2.5	5, 3.0 TC	NS (01	o 10 Kv	v)							
AC030KNZDCH /AA	1	5	18.03	-	20.83	-	24.20	-	27.70	-	30.0	-	30.0	-	#10	#10	-	-	n/a	n/a	
AC036KNZDCH /AA	1	10	36.06	-	41.67	-	46.73	-	53.74	-	50.0	-	60.0	-	#6	#4	-	1	n/a	n/a	

- 1. Rated Motor Amps (at DOE External Static Rating Point)
- 2. Nominal Kw At 240V (Derate 25% For 208V)
- 3. Fuse or HACR Breaker
- 4. Maximum Overcurrent Device, Overcurrent Protection Installed On Breaker Models Are Sized Per MCA
- To prevent damage, carefully insert the electric heating assembly through the rectangular opening in the front of the discharge opening so the heat element support rod is seated into the hole on the back side of the discharge opening.
- After installing the electric heater, a one inch clearance must be maintained on all sides of the supply air duct and/or plenum for a minimum of thirty six inches from the air handler discharge opening.

Multi-position AHU


Communication wiring connections

- Communication wires connect through side of air handler.
- Use an approved connector at the cabinet of the unit to prevent pulling or shorting of control wires.



- Control wire must be rated for 600V minimum.
- Control wire insulation must be rated for temperatures up to 90°C.
- 1. Insert the wires through the holes of the right side on the top casing and through the cable connectors.
- 2. Connect the communication wires to the F1/F2 connection terminal with compressed ring terminals.
- 3. Connect F3, F4 (for communication) when installing the wired remote control.

PBA ground screw/connection to chassis—




Outdoor Units

Choosing the installation location

Installation location requirements

- Do not place the outdoor unit on its side or upside down. Failing to do so may cause the compressor lubrication oil to run into the cooling circuit and lead to serious damage to the unit.
- Install the unit in a well-ventilated location away from direct sunlight or strong winds.
- Install the unit in a location that would not obstruct any passageways or thoroughfares.
- Install the unit in a location that would not inconvenience or disturb your neighbors, as they could be affected by the noise or the airflow coming from the unit.
- Install the unit in a location where the pipes and the cables can be easily connected to the indoor unit.
- Install the unit on a flat, stable surface that can withstand the weight of the unit. Otherwise, the unit can generate noise and vibration during operation.
- Install the unit so that the air flow is directed towards the open area.
- Maintain sufficient clearance around the outdoor unit, especially from a radio, computer, stereo system, etc.




⚠ CAUTION


- You have just purchased a system air conditioner and it has been installed by your installation specialist.
- This device must be installed according to the national electrical rules.
- If your outdoor unit exceeds a net weight of 132.2 lb(60 kg), do not install it on a suspended wall, but stand it on a floor.
- The reliability of our product cannot be guaranteed under conditions of "A" or less.

Outdoor Model	"A"
AC030/036BXSCCH	-13°F(-25°C)

- When installing the outdoor unit at the seaside, make sure that it is not directly exposed to sea breeze. If you cannot find an adequate place free from direct sea breeze, construct a protection wall or a protective fence.
 - Install the outdoor unit in a place (such as near buildings etc.) where it can be prevented from sea breeze. Failure to do so may cause a damage to the outdoor unit.



- If you cannot avoid installing the outdoor unit at the seaside, construct a protection wall around to block the sea breeze.
- Construct a protection wall with a solid material such as concrete to block the sea breeze. Make sure that the height and the width of the wall are 1.5 times larger than the size of the outdoor unit. Also, secure a space larger than 27.6 inch(700mm) between the protection wall and the outdoor unit for exhausted air to ventilate.



! CAUTION


 Depending on the condition of the power supply, unstable power or voltage may cause malfunction of parts or control system (example: on a boat or places using power supplied from electric generator, etc.).

Outdoor Units

- Install the unit in a place where water can drain smoothly.
- If you have any difficulty finding installation location as prescribed above, contact your manufacturer for details.
- Consider that the salinity particles clinging to the external panels should be sufficiently washed out. Be sure to clean sea water and dust from the outdoor unit heat exchanger and apply a corrosion inhibitor on it at least once a year.
- Because the residual water at the bottom of the outdoor unit significantly promotes corrosion, make sure that the slope does not disturb drainage.
 - Keep the floor level so that rain does not accumulate.
 - Be careful not to block the drain hole due to foreign substance.
- Check the condition of the product periodically.
 - Check the installation site every 3 months and perform anti-corrosion treatment such as R-Pro supplied by SAMSUNG (Code: MOK-220SA) or commercial water repellent grease and wax, etc., based on the product condition.
 - When the product is to be shut down for a long period of time, such as off-peak hours, take appropriate measures like covering the product.
- If the product installed within 1640.4 ft of seashore, special anti-corrosion treatment is required.
 - * Please contact your local SAMSUNG representative for further details.


A CAUTION

 In areas with heavy snow fall, piled snow could block the air intake. To avoid this incident, install a frame that is higher than estimated snow fall. In addition, install a snow-proof hood to avoid snow from piling on the outdoor unit.



Outdoor unit dimensions

Unit: inch (mm)



Outdoor Units

23.62 (600) or more

Minimum clearances for the outdoor unit

When installing 1 outdoor unit

Jo (0051) 90.65

11.81 (00051) 90.65


11.81 (00051) 90.65


78.74 (2000) or more or mor

Unit: inch (mm)

When installing more than 1 outdoor unit

11.81 (300) or more






↑ CAUTION

 The outdoor unit must be installed according to the specified distances in order to permit accessibility from each side, to guarantee correct operation, maintenance, and repair of the unit.
 The components of the outdoor unit must be reachable and removable under safe conditions for people and the unit.

⚠ WARNING

• Should adopt bar type louver. Don't use a type of rain resistance louver.





- Louver specifications.
 - Angle criteria : less than 20°
 - Opening ratio criteria: greater than 80%

Outdoor Units

Moving the outdoor unit with wire rope

- 1 Before carrying the outdoor unit, fasten two wire ropes of 26.25 ft (8m) or longer, as shown in the figure.
- 2 To prevent damages or scratches effectively, insert a piece of cloth between the outdoor unit and the ropes.
- 3 Move the outdoor unit.






Fixing the outdoor unit in place

Install the outdoor unit on a rigid and stable base to prevent disturbance from any noise caused by vibration. When installing the unit on tall stands or in a location exposed to strong winds, fix the unit securely to the ground or structure.

- 1 Position the outdoor unit so that the air flow is directed towards the outside, as indicated by the arrows on the top of the unit.
- **2** Attach the outdoor unit to the appropriate support using anchor bolts.
 - The ground wire for the telephone line cannot be used to ground the air conditioner.
- **3** DIf the outdoor unit is exposed to strong winds, install shield plates around the outdoor unit, so that the fan can operate correctly.




• Install provided rubber legs to prevent vibration and noise.




A CAUTION

- Install a drain outlet at the lowest end around the base for outdoor unit drainage
- When installing the outdoor unit on the roof, waterproof the unit and check the ceiling strength.



Optional: Fixing the outdoor unit to a wall with a rack



• Install a proper grommet in order to reduce noise and residual vibration transferred by the outdoor unit towards the wall.

Outdoor Units

↑ CAUTION

- Make sure that the wall can support the weights of the rack and the outdoor unit.
- Install the rack close to the column as much as possible.
- When installing an air guide duct, be sure to check the following:
 - The screws do not damage the copper pipe.
 - The air guide duct is fixed firmly on the guard fan.

Connecting the power cables, communication cable, and controllers

You must connect the following three electrical cables to the outdoor unit:

- The main power cable between the auxiliary circuit breaker and the outdoor unit.
- The outdoor-to-indoor power cable between the outdoor unit and the indoor unit.
- The communication cable between the outdoor unit and the indoor unit.

! CAUTION

- During installation, make first the refrigerant connections and then the electrical connections. If the unit is being removed, first disconnect the electrical cables and then the refrigerant connections.
- Connect the air conditioner to the earthing system before making the electrical connections.

Connecting wire conduits


When connecting cables between the indoor unit and the outdoor unit, use conduits to protect the cables.

1 Drill holes on the conduit plate in accordance with their use and quantity.

• AC030/036BXSCCH

 Use a nipper to remove conduit holes from the lower part of the cabinet.

(Do not remove it by hammering.)



Outdoor Units


- 2 Insert the cables through the conduits, and then fix the conduits to the conduit plate with the lock nuts.
- **3** Apply silicone to the end of the hose to prevent rain from entering the hose.




- **4** Connect the cables to the outdoor units. For how to connect the cables, refer to the next page.
- **5** Attach the conduit plate to the product.

Air conditioning system examples

When using earth leakage circuit breaker (ELCB) for a single phase





* The appearance of the unit may be different from the picture depending on the model.


! CAUTION

- If the outdoor unit is installed in a location vulnerable to an electric leak or submergence, make sure to install an ELCB.
- AC030/036BXSCCH: ELCB must be installed since this product is equipped with a base heater.

Outdoor Units

Connecting the main power cable

When using ELB for AC030/036BXSCCH (1-phase)




Outdoor Units

! CAUTION

- You should connect the power cable into the power cable terminal and fasten it with a clamp.
- The unbalanced power must be maintained within 2% of supply rating.
- If the power is unbalanced greatly, it may shorten the life of the condenser. If the unbalanced power is exceeded over 4% of supply rating, the indoor unit is protected, stopped and the error mode indicates.
- To protect the product from water and possible shock, you should keep the power cable and the connection cord of the indoor and outdoor units within ducts. (with appropriate IP rating and material selection for your application)
- Ensure that main supply connection is made through a switch that disconnects all poles, with contact gap of a least 0.12 inch(3mm).
- Devices disconnected from the power supply should be completely disconnected in the condition of overvoltage category.
- Keep distances of 1.97 inch(50mm) or more between power cable and communication cable.

Main power terminal block specifications

[Unit:inch(mm)]



Main power cable specifications

The power cable is not supplied with air conditioner.

- Select the power supply cable in accordance with relevant local and national regulations.
- Wire size must comply with the applicable local and national code.
- Specifications for local wiring power cord and branch wiring are in compliance with local cord.

Single phase

Model				Out	door	Indoor				
Outdoor	Indoor	Power Source	RLA (A)	Mi	OC	Rated input current of the power conversion equipment	MCA (A)	MOP (A)		
				FAN1(A)	FAN2(A)	FAN(A)				
	AC030BN4DCH	0BNHDCH 0BNZDCH 0KNZDCH 208~230V/60Hz		1.25	1.25	0.79	30.4	40.0		
AC030BXSCCH	AC030BNHDCH		21.0			2.10	31.7	40.0		
ACUSUBASCCH	AC030BNZDCH		21.0			2.50	32.1	40.0		
	AC030KNZDCH		200~230\//40□>	208~230V/A0Hz	~230\//60Hz			1.66	31.3	40.0
	AC036BN4DCH					0.79	30.4	40.0		
AC036BXSCCH	AC036BNHDCH		21.0	1 25	1.25	3.50	33.1	40.0		
	AC036BNZDCH		21.0	1.25	1.25	3.60	33.2	40.0		
	AC036KNZDCH					1.66	31.3	40.0		

Outdoor Units




NOTE

- RLA is based on AHRI 210/240 cooling standard condition [Indoor temp.: 26.7 °C / 80 °F(DB) / 19.46 °C / 67 °F(WB), Outdoor temp.: 35 °C / 95 °F(DB)]
- Voltage tolerance is ± 10 %.
- Maximum allowable voltage between phases is 2 %.


Symbols

- RLA: Rated Load Ampere (A)
- MOC: Maximum Operating Current (A)
- MCA: Minimum Circuit Ampere (A)
- MOP: Maximum Overcurrent Protective Device (A)
- Voltage range
 - Units are suitable for use on electrical systems where voltage supplied to unit terminal is not below or above listed range limits.
- Maximum allowable voltage variation between phases is 2%
- Wire size & type must comply with the applicable local and national code.
 - Wire size: Based on the value of MCA.
 - Wire type:
 1-phase: 60245 IEC57(IEC) or H05RN-F(CENELEC)
 grade or more

Silence mode controller wiring diagram with External controller



Connecting the outdoor-to-indoor power cable and the communication cable




NOTE

- Lay the electrical wiring so that the front cover does not rise up when doing wiring work and attach the front cover securely.
- Ground wire for the indoor unit and outdoor unit connection cable must be clamped to a soft copper tin-plated eyelet terminal with M4 screw hole(NOT SUPPLIED WITH UNIT ACCESSORIES).
- The appearance of the unit may be different from the picture depending on the model.

Outdoor-to-indoor power terminal specifications

- Connect the cables to the terminal board using the compressed ring terminal.
- Cover a solderless ring terminal and a connector part of the power cable and then connect it.



Outdoor Units

Nominal	Nominal	E	3		D		1	Е	F	L	(d2	t	
dimensions for cable [mm2(inch2)]	dimensions for screw [mm(inch)]	Standard dimension [mm(inch)]	Allowance [mm(inch)]	Standard dimension [mm(inch)]	Allowance [mm(inch)]	Standard dimension [mm(inch)]	Allowance [mm(inch)]	Min. [mm (inch)]	Min. [mm (inch)]	Max. [mm (inch)]	Standard dimension [mm(inch)]	Allowance [mm(inch)]	Min. [mm (inch)]	
4/6	4(3/8)	9.5(3/8)	±0.2	5.6(1/4)	+0.3(+0.011)	3.4(1/8)	±0.2		5 (3/16)	20 (3/4)	4.3 (3/16)	+0.2 (+0.007) 0(0)	0.9	
(0.006/ 0.009)	8(3/16)	15(9/16)	(±0.007)	3.0(1/4)	-0.2(-0.007)	3.4(1/0)	(±0.007)	6 (1/4)	9 (3/8)	28.5 (1-1/8)	8.4 (1-3/16)	+0.4 (+0.015) 0(0)	(0.03)	
10(0.01)	8(3/16)	15(9/16)	±0.2 (±0.007)	7.1(1/4)	+0.3(+0.011) -0.2(-0.007)	4.5(3/16)	±0.2 (±0.007)	7.9 (5/16)	9 (3/8)	30 (1-3/16)	8.4 (1-3/16)	+0.4 (+0.015) 0(0)	1.15 (0.04)	
16(0.02)	8(3/16)	16(10/16)	±0.2 (±0.007)	9(3/8)	+0.3(+0.011) -0.2(-0.007)	5.8(1/4)	±0.2 (±0.007)			33 (1-5/16)		+0.4 (+0.015) 0(0)	1.45 (0.05)	
25(0.03)	8(3/16)	12(1/2)	±0.3	±0.3 11 5(7/16)	11.5(7/16) +0.5(+0.019)	7.7(5/16)	±0.2	11 (3/8)	15	34 (1-	8.4 (1-3/16)	+0.4 (+0.015)	1.7	
25(0.05)	8(3/16)	16.5(10/16)	(±0.011)	11.5(7/10)	-0.2(-0.007)	7.7(3/10)	(±0.007)			13 (1/2)	3/8)	8.4 (1-3/16)	0(0)	(0.06)
7E/0.0E)	8(3/16)	16(10/16)	±0.3	17 7/1 /2\	+0.5(+0.019)	0.4/7./0)	±0.2	12.5	13 (1/2)	38 (1-1/2)	8.4 (1-3/16)	+0.4 (+0.015)	1.8	
35(0.05)	8(3/16)	22(7/8)	(±0.011)	13.3(1/2)	-0.2(-0.007)	1 9/1/4/81	(±0.007)	(1/2)	13 (1/2)	43 (1- 11/16)	8.4 (1-3/16)	0(0)	(0.07)	
50(0.07)	8(3/16)	22(7/8)	±0.3 (±0.011)	13.5(1/2)	+0.5(+0.019) -0.2(-0.007)	11.4(7/16)	±0.3 (±0.011)	17.5 (11/16)	14 (9/16)	50 (2)	8.4 (1-3/16)	+ 0.4(+0.015) 0(0)	1.8 (0.07)	
70(0.10)	8(3/16)	24(1)	±0.4 (±0.015)	17.5(11/16)	+0.5(+0.019) -0.4(-0.015)	13.3(1/2)	±0.4 (±0.015)	18.5 (3/4)	20 (3/4)	51 (2)	8.4 (1-3/16)	+ 0.4(+0.015) 0(0)	2.0 (0.078)	

- Connect the rated cables only.
- Connect using a driver which is able to apply the rated torque to the screws.
- If the terminal is loose, fire may occur caused by arc. If the terminal is connected too firmly, the terminal may be damaged.

_ Tightening torque							
	lbf•ft	N•m					
M4	0.87 to 1.30	0.8 to 1.2					
M5	1.45 to 2.17	2.0 to 3.0					

! CAUTION

- When connecting cables, you can connect the cables to the electrical part or connect them through the holes below depending on the spot.
- Connect the communication cable between the indoor and outdoor units through a conduit to protect against external forces, and feed the conduit through the wall together with refrigerant piping.
- Remove all burrs at the edge of the knock-out hole and secure the cable to the outdoor knock-out using lining and bushing with an electrical insulation such as rubber and so on.
- Must keep the cable in a protection tube.
- Keep distances of 1.97 inch(50mm) or more between power cable and communication cable.
- When the cables are connected through the hole, remove the Plate bottom.

Outdoor Units

Outdoor-to-indoor power and communication cables specifications

Indoor unit: 4WAY CST(AC***BN4***)

Indoor power supply								
Power supply	Max/Min (V)	Indoor power cable						
1Ф, 208-230V~, 60Hz	±10%	0.0012 inch ² ↑ (0.75mm ² ↑), 3 wires						
Communication cable								
0.0012 inch ² ↑ (0.75mm ² ↑), 2 wires								


• Duct(AC***BNL***, AC***BNH***)

Indoor power supply								
Powersupply	Max/Min (V)	Indoor power cable						
1Ф, 208-230V~, 60Hz	±10%	0.0023 inch ² ↑ (1.5mm ² ↑), 3 wires						
Communication cable								
0.0012 inch ² ↑ (0.75mm ² ↑), 2 wires								

• MPAH(AC****NZ***)

Indoor power supply		
Power supply	Max/Min (V)	Indoor power cable
1Ф, 208-230V~, 60Hz	±10%	0.0039 inch ² ↑ (2.5mm ² ↑), 3 wires
Communication cable		
0.0012 inch ² ↑ (0.75mm ² ↑), 2 wires		

- Power supply cords of parts of appliances for outdoor use shall not be lighter than polychloroprene sheathed flexible cord. (Code designation IEC:60245 IEC 57 / CENELEC: H05RN-F)
- When installing the indoor unit in a computer room or network room, use the double shielded (tape aluminum / polyester braid + copper) cable of FROHH2R type.





Images and data in this book may subject to change without prior notice.