Heat Pump Dry Charged 13 SEER 3 Phase

Split System Heat Pump

NITROGEN CHARGED

Form No. 2SHP13LC-100 (06/2012)

2SHP13 **Features and Benefits**

COMPRESSOR

- Nitrogen charged for replacement of R22 components only
- High-efficiency scroll compressor
- Grommet-mounted compressor for quiet operation
- Internally protected against high temperature motor overload conditions

COMPONENTS

- Full metal louvered panels remove with just two screws per panel for easy coil cleaning
- Bi-directional filter drier for long-lasting durability and system protection
- Discharge muffler for quiet operation
- Reliable, solid-state, time-initiated, temperature-terminated defrost system
- Service valves positioned for quick installation and easy service
- Low pressure switch for loss of charge system protection
- Trade-available components
- Defrost control features built-in diagnostics for easier service
- Defrost control has short cycle protection to protect compressor
- Defrost control is Quiet Shift™ capable
- Defrost cycle is field selectable 30/60/90 minutes

COIL

- Enhanced aluminum fins and copper tubing for high efficiency and capacity
- Raised coil prevents debris from collecting in bottom of coil and causing loss of airflow



DESIGN

• Designed for ambients up to 125°F

CABINET


- Full metal louvered panel coil guard protection
- Controls located in corner post for easy installation and service
- Rounded corners for safety and attractive, clean appearance
- Baked polyester paint finish over galvanized steel for maximum durability
- External gauge ports for easy service
- Raised base pan with ports allows for excellent water and debris drainage

WARRANTIES

• 1 year parts; 5 year compressor



Model Number Guide



Electrical and Physical Data


	Voltage/		Min.	Max.	Comp	ressor	Outdo	or Fan M	lotor	Field Supplied	Shipping Weight (lbs)
Model	Hz/ Phase	Voltage Range	Circuit (Amps)	Fuse (Amps)	Rated Load (Amps)	Locked Rotor (Amps)	Full Load (Amps)	Rated HP	Nom. RPM	R22 Charge (oz.)	
2SHP13LC136T	208-230/3/60	197-253	14.5	25	10.8	73	1.1	1/5	1075	138	192
2SHP13LC148T	208-230/3/60	197-253	20.8	35	15.4	114	1.7	1/4	825	188	248
2SHP13LC160T	208-230/3/60	197-253	21.0	35	15.4	114	1.8	1/4	825	224	

Note:

Units are factory shipped with dry nitrogen holding charge

Unit Dimensions & Sound Ratings

		Sound				
Model	A - width (in.)	B - depth (in.)	C - height (in.)	Ratings (dBa)		
2SHP13LC136T	24-3/4	26-3/4	33-3/4	76		
2SHP13LC148T	29-3/8	31-1/4	37-3/4	78		
2SHP13LC160T	35-3/4	37-3/4	37-3/4	80		



Cooling Performance with Air Handlers and Furnaces

Outdoor Model Evap	Indoor Model	Cooling				Heating					Refrigerant Connection			Refrig. Line Size		Indoor Coil Orifice			
	Evaporator			ARI	Rated Sensible Capacity Btuh		47		17		CFM	Outdoor		Ind	oor	uo	p	Required	Optional
	Coil or Air Handler ²	SEER E	EER	Rated Capacity ¹ Btuh		HSPF	Btuh	СОР	Btuh	СОР		Suction	Liquid	Suction	Liquid	Suction	Liquid	Indoor Orifice ²	Field Inst. TXV
2SHP13LC136T	BCS2M36C00NA-1P	13	11	35200	26400	7.7	33800	3.5	21000	2.4	1200	7/8	3/8	7/8	3/8	7/8	3/8	0.074	H2TXV02
2SHP13LC148T	BCS2M48C00NA-1P	13	11	48000	35500	7.7	47500	3.4	30600	2.4	1600	7/8	3/8	7/8	3/8	7/8	3/8	0.088	H2TXV02
2SHP13LC160T	BCS2M60C00NA-1P	13	11	55000	41300	7.7	55000	3.6	35000	2.5	1800	7/8	3/8	7/8	3/8	1-1/8	3/8	0.09	H2TXV03

Note: EPA rules prohibit system installations (condensing unit coupled with an air handler or evaporator coil).

Accessories

Accessories										
Catalog / Kit Number	Description	Used with								
58M81	BLOWER OFF DELAY KIT	ALL 2SHP'S								
45F08	COMPRESSOR LOW AMBIENT CUT-OFF	ALL 2SHP'S								
94J46	HIGH PRESSURE SWITCH KIT	ALL 2SHP'S								
47J27	COMPRESSOR TIME-OFF CONTROL	ALL 2SHP'S								
93M05	CRANK CASE HEATER	ALL 2SHP'S								
33M07	MILD AMBIENT KIT	ALL 2SHP'S								
27J00	LOW AMBIENT KIT	ALL 2SHP'S								
84M23	LOSS OF CHARGE KIT	ALL 2SHP'S								
93G35	FREEZESTATS (3/8" TUBING)	ALL 2SHP'S								
50A93	FREEZESTATS (5/8" TUBING)	ALL 2SHP'S								
H2TX02	TXV KIT	2SHP 36 & 48								
H2TX03	TXV KIT	2SHP 60								

Certified in accordance with Unitary Air Conditioner Certification Program, which is based on AHRI Standard 210/240
Required to achieve AHRI rating. If NA (Not Applicable) is in the piston column, then TXV is required
A blower time delay is required to achieve AHRI rating. This feature is standard on all Allied Air Enterprises furnaces and Air Handler products



215 Metropolitan Drive West Columbia, SC 29170 800.448.5872 www.allied-commercial.com

Form No. 2SHP13LC-100 (06/2012)

©2012 Allied Air Enterprises LLC, a Lennox International Inc. Company

Printed in the U.S.A.